

PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

DIABLO CANYON POWER PLANT
PO. Box 56 • Avila Beach, California 93424 • (805) 595-7351

R.C. THORNBERRY
PLANT MANAGER

February 13, 1985

Mr. William Briam, Administrator
San Luis Obispo County
Administrative Office
County Government Center
San Luis Obispo, CA 93408

Dear Mr. Briam:


Pursuant to NUREG-0654, Revision 1, Appendix 1, the following is a summary report concerning an Unusual Event at the Diablo Canyon Nuclear Power Plant site.

On February 13, 1985, a "Steam Line High Delta-P" safety injection signal was received. The safety injection signal caused the Emergency Core Cooling System to initiate and discharge to the Reactor Coolant System. The cause of the event is still being investigated.

An Unusual Event was declared by the Shift Foreman at 0050 hours and emergency notifications were started. After the protection system completed its safety functions, all systems were returned to their normal status.

The Unusual Event was concluded at 0118 hours, February 13, 1985 and all response organizations were notified. This event has in no way affected the health and safety of the public and no discharge of radioactive materials were made to the environment.

Sincerely,


R. C. THORNBERRY

RCT:jhr

50-275

8503070173 850213
PDR ADOCK 05000275
S PDR

IE22
1/0

cc: Mr. William Medigovich, Director
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Mr. John J. Kearns
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Ms. Ann Vasquez
California Office of Emergency Services
P. O. Box 9577
Sacramento, CA 95823

Mr. John B. Martin, Administrator
U. S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368

Mr. George Whiting, Sheriff
San Luis Obispo County
P. O. Box 32
San Luis Obispo, CA 93401

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Director, Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555