

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Washington Nuclear Plant - Unit 2										DOCKET NUMBER (2) 0 5 0 0 0 3 9 1 7				PAGE (3) 1 OF 0 2									
TITLE (4) Isolation of Reactor Water Cleanup																							
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)													
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)										
0 1	2	7	8	5	8	5	0	1	0	0	0	2	2	6	8	5	0	5	0	0	0	0	0
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)																					
2		20.402(b)				20.405(e)				<input checked="" type="checkbox"/> 50.73(a)(2)(iv)				73.71(b)									
POWER LEVEL (10)		0 0 4				20.405(a)(1)(i)				50.38(e)(1)				50.73(a)(2)(v)				73.71(c)					
		20.405(a)(1)(ii)				50.38(e)(2)				50.73(a)(2)(vi)				<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 368A)									
		20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(vii)(A)				50.72(b)(2)(ii)									
		20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(vii)(B)													
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)													
LICENSEE CONTACT FOR THIS LER (12)																							
NAME R. L. Koenigs, Compliance Engineer										TELEPHONE NUMBER 5 1 0 1 9 3 1 7 7 1 - 1 2 1 5 0 1 1													
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13) Ext. 2279																							
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC				
B	CIF	FEIT	R36	9	N																		
SUPPLEMENTAL REPORT EXPECTED (14)																							
YES (If yes, complete EXPECTED SUBMISSION DATE)										<input checked="" type="checkbox"/> NO													
EXPECTED SUBMISSION DATE (15)										MONTH DAY YEAR													

ABSTRACT (Limit to 400 words; if 400 words are used, underline space typewritten lines) (16)

During plant operation, a Reactor Water Cleanup System (RWCU) isolation occurred, due to an spurious RWCU high delta flow trip. Isolation of RWCU is an ESF actuation.

This isolation was reported to the NRC at 0358 hours on January 27, 1985.

8503080427 850226  
PDR ADOCK 05000397  
S PDR

1822  
1/

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104

EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (8)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
Washington Nuclear Plant - Unit 2	0500039785	85	010	00	02	OF	02

TEXT (If more space is required, use additional NRC Form 285A-1) (17)

Plant Condition

- a) Plant Mode - 2  
b) Power Level - 4%

Event

During reactor plant heatup, the RWCU system was lined up to blowdown to the main condenser. Blowdown flow in excess of the guidelines established by plant procedures was established which caused RWCU delta flow to exceed the trip point of 58.5 GPM. Blowdown flow was not reduced after receiving the high delta flow alarm, due to other demands on the operator during the Plant startup, and the 45 sec. time delay was exceeded, which actuated an NSSSS isolation signal, resulting in closure of RWCU-V-1 and RWCU-V-4.

Immediate Corrective Action

Operators verified that no actual leak existed, the isolation signals for RWCU-V-1 and RWCU-V-4 were reset and the RWCU system was returned to service, with reduced blowdown flow.

Further Corrective Action

None required

Safety Significance

The occurrence of this event did not affect the safety of the plant or that of the public. The system functioned to isolate in accordance with its design basis and no actual leak existed in the RWCU system.

Similar Events

See LER Nos: 84-035; 84-072-01; 84-072-02; 84-072-03; 84-097; 84-101, 84-119 & 85-009

## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

Docket No. 50-397

February 26, 1985

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: NUCLEAR PLANT NO. 2  
LICENSEE EVENT REPORT NO. 85-010

Dear Sir:

Transmitted herewith is Licensee Event Report No. 85-010 for WNP-2 Plant. This report is submitted in response to the report requirements of 10CFR50.73 and discusses the item of reportability, corrective action taken, and action taken to preclude recurrence.

This is the follow-up report to the verbal notification given at 0358 hours on January 27, 1985.

Very truly yours,

*J. D. Martin for*  
J. D. Martin (M/D 927M)  
WNP-2 Plant Manager

JDM:mm

Enclosure:  
Licensee Event Report No. 85-010

cc: Mr. John B. Martin, NRC - Region V  
Mr. A. D. Toth, NRC - Site (901A)  
Ms. Dottie Sherman, ANI  
INPO Records Center - Atlanta, GA

IE22  
1/1