



J. D. Woodard  
Vice President  
Farley Project

Southern Nuclear Operating Company  
*the southern electric system*

July 27, 1992

Docket Nos. 50-348  
50-364

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555

Joseph M. Farley Nuclear Plant - Units 1 and 2  
Failure of Thermo-Lag 330 Fire Barrier System to Maintain  
Cabling in Wide Cable Trays and Small Conduits Free From Fire Damage  
Nuclear Regulatory Commission Bulletin 92-01


Gentlemen:

On June 24, 1992, the NRC Staff issued Bulletin 92-01 entitled, "Failure of Thermo-Lag 330 Fire Barrier System to Maintain Cabling in Wide Cable Trays and Small Conduits Free From Fire Damage," to notify licensees of concerns related to this fire barrier system. The Bulletin required licensees to determine if the Thermo-Lag 330 Fire Barrier System had been installed in its facilities and to provide a written response outlining its findings.

In response to this Bulletin, Southern Nuclear Operating Company has determined that Thermo-Lag 330 Fire Barrier System has not been installed in either Unit 1 or Unit 2 of Farley Nuclear Plant (FNP). As such, the concerns documented in the subject Bulletin do not apply to FNP, and all actions related to this Bulletin at FNP are considered complete.

The information provided herein is true to the best of our knowledge and belief. If there are any questions relating to the information provided herein, please advise.

Respectfully submitted,

  
J. D. Woodard

JDW/RWS:cht-92.1595

cc: Mr. S. D. Ebner  
Mr. S. T. Hoffman  
Mr. G. F. Maxwell

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 27th DAY OF July, 1992

  
Notary Public

My Commission Expires: 7-14-92

JEH 1/0