

TENNESSEE VALLEY AUTHORITY
KNOXVILLE, TENNESSEE 37902

MAR 5 1985

Mr. John Marlar, Chief
Facilities Performance Branch
Water Management Division
U.S. Environmental Protection Agency
Region IV
345 Courtland Street, NE.
Atlanta, Georgia 30365

NOTIFICATION OF NONCOMPLIANCE WITH EFFLUENT LIMITATIONS - NPDES PERMIT
NO. TN0026450 - SEQUOYAH NUCLEAR PLANT (SQN)

The enclosed notice of noncompliance was not included with the August
discharge monitoring report (DMR) for the subject facility. However,
these two noncompliances were noted in the DMR.

If you have questions, please call Michael Hines or Stephen R. Wells at
(205) 386-2971 or FTS 872-8971 in Muscle Shoals, Alabama.

Sincerely,

Original signed by
Martin E. Rivers

Martin E. Rivers, Director
Environmental Quality

Enclosure

cc (Enclosure):

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Document Control Desk
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, D.C. 20555

Mr. Jack R. McCormick, Manager
Chattanooga Basin Office
Division of Water Management
2501 Milne Street
Chattanooga, Tennessee 37406

8503140575 850305
PDR ADOCK 05000327
S PDR

IE23
11

MAR 5 1985

Mr. John Marlar

Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Tennessee Department of Health
and Environment
Division of Water Management
TERRA Building
150 Ninth Avenue, North
Nashville, Tennessee 37203

NOTIFICATION OF NONCOMPLIANCE WITH EFFLUENT LIMITATIONS - NPDES PERMIT
NO. TN0026450 - SEQUOYAH NUCLEAR PLANT (SQN)

Description of the discharge--Discharge No. 112 - Sewage treatment plant effluent. Grab samples collected at 0940 on August 8, 1984, and at 1225 on August 10, 1984, had total residual chlorine (TRC) concentrations of 6.1 and 2.5 mg/L, respectively, exceeding the permit limitation of 2.0 mg/L.

Cause and period of the noncompliance--Malfunction of the sodium hypochlorite (NaOCl) pumps caused the TRC noncompliances. Additional grab samples collected and analyzed were as follows.

<u>Date</u>	<u>Time</u>	<u>TRC Concentrations (mg/L)</u>
8/07	0745	0.1
8/09	0815	2.0
8/10	1615	1.8

Thus, the maximum periods of noncompliance for the August 8 and 10 noncompliances were approximately 26 hours and 4 hours, respectively.

Steps taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge--The NaOCl feed pumps have been repaired. Additionally, efforts are being made by SQN personnel to establish a steady TRC effluent concentration by varying concentrations of NaOCl feed solutions and by adjusting the stroke(s) of the feed pump(s).