

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-285
 UNIT NAME Fort Calhoun St.
 DATE July 8, 1992
 COMPLETED BY G. R. Cavanaugh
 TELEPHONE (402) 636-2474

REPORT MONTH June 1992

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
92-04	920531 /	F	30.3	A	1	92-019	RB	CONROD	On May 31, 1992, Control Element Assembly (CEA) No. 35 dropped into the reactor core. Reactor power was reduced to 70% within one hour per Technical Specifications. Attempts to recover the CEA while at 70% power were unsuccessful. The generator was taken off-line early in the morning on June 1, 1992.

1
 F: Forced
 S: Scheduled

2
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for Licensee
 Event Report (LER) File (NUREG-0161)

5
 Exhibit I - Same Source

9208170141 920814
 PDR ADOCK 05000285
 PDR