

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1)  
LaSalle County Station Unit 1

DOCKET NUMBER (2)

0 5 0 0 0 3 7 3 1 OF 0 2

PAGE (3)

TITLE (4)

Unsecured High Radiation Door

EVENT DATE (6)			LER NUMBER (8)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)	
02	08	85	85	016	00	03	07	85	NA	0 5 0 0 0	
										0 5 0 0 0	

OPERATING  
MODE (9)

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8. (Check one or more of the following) (11)

POWER  
LEVEL  
(10)

0100

20.402(b)

20.406(a)(1)(i)

20.406(a)(1)(ii)

20.406(a)(1)(iii)

20.406(a)(1)(iv)

20.406(a)(1)(v)

20.406(c)

60.30(c)(1)

60.30(c)(2)

60.73(a)(2)(i)

60.73(a)(2)(ii)

60.73(a)(2)(iii)

60.73(a)(2)(iv)

60.73(a)(2)(v)

60.73(a)(2)(vi)

60.73(a)(2)(vii)(A)

60.73(a)(2)(vii)(B)

60.73(a)(2)(ix)

73.71(b)

73.71(c)

OTHER (Specify in Abstract  
below and in Text, NRC Form  
365A)

LICENSEE CONTACT FOR THIS LER (12)

NAME

TELEPHONE NUMBER

L. R. Aldrich, extension 238

AREA CODE

811 15 315 17 16 17 16 11

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC
A	Z1Z	Z191919	Z191919	N					

SUPPLEMENTAL REPORT EXPECTED (14)

EXPECTED  
SUBMISSION  
DATE (15)

MONTH DAY YEAR

YES (If yes, complete EXPECTED SUBMISSION DATE)

X NO

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 1510 on 2/8/85 with Unit 1 in Hot Shutdown, door #426, entrance to the Unit 1 Reactor Water Cleanup B Heat Exchanger Room, was found to be unsecured and unattended. This is contrary to Technical Specification 6.1.1. An individual leaving the area failed to properly secure the door. Upon discovery of the open door, a Radiation Chemistry Technician closed and secured the door. The door was verified closed and secured at 1515 on 2/8/85. The individual responsible was counseled as to the responsibility of insuring that high radiation doors remain secured.

8503150132 850307  
PDR ADOCK 05000373  
S PDRIC22  
11

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO 3150-0104  
EXPIRES 8/31/85

FACILITY NAME (1):  LaSalle County Station Unit 1	DOCKET NUMBER (2):  0500037385-016-0002 OF 02	LER NUMBER (8):			PAGE (3):		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			

TEXT (If more space is required, use additional NRC Form 305A's) (17)

I. EVENT DESCRIPTION

At 1510 on February 8, 1985, door #426, entrance to the Unit 1 Reactor Water Cleanup (CE) B Heat Exchanger Room, was found to be unsecured and unattended. This is contrary to Technical Specification 6.1.1. At the time of the event the Unit was in Hot Shutdown.

II. CAUSE

An individual leaving the area failed to secure the door.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 mrem occurred.

IV. CORRECTIVE ACTION

Upon finding the door open, a Radiation Chemistry Technician closed and secured the door. The door was verified closed and secured at 1515 on February 8, 1985. The individual involved was counseled as to his responsibility of ensuring that high radiation area access doors are properly secured at all times.

V. PREVIOUS OCCURRENCES

There have been five occurrences of a similar nature as follows:

LER 373/84-034  
LER 374/84-022  
LER 374/84-038  
LER 374/84-070  
LER 373/85-004

VI. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



**Commonwealth Edison**  
LaSalle County Nuclear Station  
Rural Route #1, Box 220  
Marseilles, Illinois 61341  
Telephone 815/357-6761

March 7, 1985

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #85-016-00, Docket #050-373 is being submitted to your office in accordance with 10CFR 50.73.

*for R.D. Bulger*  
G. J. Diederich  
Superintendent  
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director  
INPO- Records Center  
File/NRC

ZE22  
11