

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-364  
 UNIT NAME J. M. FARLEY - UNIT 2  
 DATE July 6, 1992  
 COMPLETED BY R. D. HILL  
 TELEPHONE (205)899-5156

REPORT MONTH JUNE

NO.	DATE	TYPE <sup>1</sup>	DURATION (HOURS)	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	LICENSEE EVENT REPORT #	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
009	920601	F	137.8	A	N/A	N/A	SL	N/A	Power reduction continued into the month of June from 05-28-92 to repair and monitor 2A steam generator feedwater pump. The unit returned to 100% power at 1745 on 6-6-92.
010	920606	F	54.8	B	N/A	N/A	SL	N/A	At approximately 2025 on 6-6-92, power was reduced to 70 percent power because the deviation among the over-temperature delta-temperature setpoint channels was in excess of channel check criteria. Deviation was elevated as a result of hot leg streaming following RTD bypass removal. Westinghouse revised the criteria for expected channel variation on 6-8-92. Existing deviation was determined to be acceptable. The unit returned to 100 percent power at 0312 on 6-9-92.

<sup>1</sup>F: Forced  
 S: Scheduled

<sup>2</sup>Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative

<sup>3</sup>Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>Exhibit G-Instructions  
 for Preparation of Data  
 Entry Sheets for Licensee  
 Event Report(LER) File (NUREG-  
 0161)

<sup>5</sup>Exhibit I -Same Source

9208180059 920812  
 PDR ADOCK 05000348  
 PDR