

CONTAINMENT SYSTEMS

CONTAINMENT VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.6 The containment purge supply and exhaust isolation valves shall be closed and handswitch keys removed.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more containment purge supply or exhaust isolation valve(s) not closed with the handswitch keys removed, place the valve(s) in the closed position with handswitch key(s) removed within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.6 The containment purge supply and exhaust isolation valves shall be determined closed at least once per 31 days.