

USNRC REGION I  
ATLANTA, GEORGIA



84 NOV 14 A8:25

November 8, 1984  
L-84-318

Mr. James P. O'Reilly  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, NW  
Atlanta, GA 30323

Dear Mr. O'Reilly:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
IE Bulletin 83-06

Our letter L-84-259 dated September 28, 1984 provided additional information to supplement our response to IE Bulletin 83-06 (Non-Conforming Materials Supplied by Tube-Line Corporation, etc.). The purpose of this letter is to provide additional information on Tube-Line material at Turkey Point Units 3 and 4.

Samples of the Tube-Line material supplied by Gulfalloy on Purchase Order 38497-39056C were sent out for testing as described in our previous correspondence. The results of the test have been received and are being reviewed by our engineering department. A report on this material will be submitted by December 15, 1984.

The Tube-Line material supplied by Gulfalloy on Purchase Order 38497-24503C has been documented on a Non-Conformance Report (NCR) and has been forwarded to our engineering department for disposition. A list of the material involved is attached. An interim report on this material will be submitted by December 15, 1984.


We are continuing to review all documentation on materials received from Gulfalloy to determine the manufacturer of the components. To date, no additional Tube-Line material has been discovered. This review is now expected to be completed and a report submitted by January 4, 1985.

8412010044 841108  
PDR ADDCK 05000250  
PDR  
Q

Mr. James P. O'Reilly  
November 8, 1984  
Page 2

Should you or your staff have any questions on this information, please contact us.

Very truly yours,

A handwritten signature in cursive script, appearing to read "J. W. Williams, Jr.", written in dark ink.

J. W. Williams, Jr.  
Group Vice President  
Nuclear Energy

JWW/PLP/js

cc: Harold F. Reis, Esquire  
PNS-LI-84-396-2

ATTACHMENT

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250, 50-251  
IE Bulletin 83-06

Gulfalloy supplied Tube-Line Corporation materials under  
Purchase Order 38497-24503C dated November 10, 1981

Auxiliary Feedwater Upgrade

55 ea. 4" - 90° EL (L.R.) HT #3017 Code ENZ

20 ea. 4" - 45° EL HT #23240 Code NEWM

25 ea. 4" x 4" x 4" Tee. HT 3 3127 Code NBFF