

LICENSEE EVENT REPORT (LER)


FACILITY NAME (1) JAMES A. FITZPATRICK NUCLEAR POWER PLANT										DOCKET NUMBER (2) 0 5 0 0 0 3 3 3				PAGE (3) 1 OF 0 1		
TITLE (4) EXCESSIVE LEAKAGE OF PRIMARY CONTAINMENT ISOLATION VALVE																
EVENT DATE (5)			LER NUMBER (8)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 3	0 1	8 5	8 5	0 0 8	0 0 0	3 1	4 8	5					0 5 0 0 0			
OPERATING MODE (9) N		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5: (Check one or more of the following) (11)														
POWER LEVEL (10) 0 0 0		20.402(b)				20.405(e)				50.73(a)(2)(iv)				73.71(b)		
		20.405(a)(1)(i)				50.38(a)(1)				50.73(a)(2)(v)				73.71(a)		
		20.405(a)(1)(ii)				50.38(a)(2)				50.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)		
		20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(viii)(A)						
		20.405(a)(1)(iv)				X 50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)						
		20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(x)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME Douglas J. Lindsey, Assistant Operations Superintendent										TELEPHONE NUMBER 3 1 5 3 4 2 - 3 8 4 0						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS						
X	NH	ISV	V 0 8 5	Y												
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR
X YES (If yes, complete EXPECTED SUBMISSION DATE)												NO		0 8	1 5	8 5

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

During the performance of Local Leak Rate Testing (LLRT), Reactor Recirculation Pump Mini-Purge penetration X-31Ac was found with leakage that may exceed the limit of .6 La contained in Technical Specification 4.7.A.2.b.2. The cause of the leakage was valve disc to seat leakage. Valve repairs have been completed for this penetration. Additional Local Leak Rate Testing remains incomplete at this time. Details of the completed Local Leak Rate Testing will be provided in the supplemental report.

IF22
1/18503260223 850314
PDR ADOCK 05000333
S PDR

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840



Harold A. Glovier
Resident Manager

March 14, 1985
JAFP 85-0255

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 85-008-00

Dear Sir:

We have enclosed the referenced Licensee Event Report in accordance with 10CFR50.73.

If there are any questions concerning this report, please contact Mr. Douglas J. Lindsey at (315) 342-3840, Extension 302.

A handwritten signature in cursive script, appearing to read 'HAG', followed by the name 'Glovier'.

HAROLD A. GLOVIER

HAG:DJL:dmh

Enclosure

CC: USNRC, Region I (1)
INPO Records Center, Atlanta, Georgia (1)
Internal Power Authority Distribution
American Nuclear Insurers (1)
NRC Resident Inspector
Document Control Center
LER/OR File

LE22
1/1