

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

November 30, 1984

TELEPHONE
(704) 373-4531

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Subject: McGuire Nuclear Station - Docket No. 50-369/370
Catawba Nuclear Station - Docket No. 50-413/414
Response Request for Additional Information Regarding
Topical Report DPC-NF-2010, "Nuclear Physics Metodology
for Reload Design"

In response to your request (Reference Letter, E. G. Adensam to H. B. Tucker, November 5, 1984) for additional information regarding the subject topical report, attached are Duke Power Company's answers to the six questions in the request.

If any additional information or discussion is desired, please feel free to call Scott Gewehr, Duke Power Licensing at (704) 373-7581.

Very truly yours,

H. B. Tucker

Hal B. Tucker

SAG/mjf

Attachment

cc: Dr. John Carew
Building 475 B
Brookhaven National Laboratory
Upton, N. Y. 11973

Mr. Jesse L. Riley, President
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28208

James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

8412040083 841130
PDR ADOCK 05000369
P PDR

13021
11

Mr. Harold R. Denton, Director
November 30, 1984
Page Two

cc: Mr. Robert Guild, Esq.
P. O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135 1/2 Devine Street
Columbia, South Carolina 29205

Mr. W. T. Orders
Senior Resident Inspector
McGuire Nuclear Station

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Q.1 Please provide additional information regarding the NUC-MARGINS code and its use in the Dropped Rod Analysis. Provide short descriptions of the input, output, calculational models used, benchmark calculations performed and the conservatisms assumed in the analysis.

A.1 Under the terms of the current fuel contract with Westinghouse, Duke Power will provide physics data for the rod drop transient to Westinghouse who will then perform the safety evaluation and/or reanalysis. This relationship will exist until Duke submits its thermal-hydraulic and safety analysis methodology reports to the NRC.

The physics methods described in Section 4.2.2.5, 6.2.2.4, and 9.1.3.3 will be further elaborated herein.

A. Initial conditions for analysis:

1. Control Bank D is inserted to the Rod Insertion Limit.
2. Core Power is 102% Full Power (2% calorimetric error included).
3. A full power xenon distribution is used which would produce a DNB limiting axial power profile.

B. Assumptions for system response upon rod drop:

1. No trip occurs.
2. Control Bank D is withdrawn to compensate for the dropped rod.
3. A short duration reactor power overshoot will occur with the turbine-reactor control system eventually leveling out the reactor power to the initial power level.

Search cases are performed as described in Section 4.2.2.5 and 6.2.2.4. EPRI-NODE assembly average powers are converted to $F_{\Delta H}^N$ using the method described below. This method is employed for all $F_{\Delta H}^N$ evaluations. All physics codes employed are static, therefore, "before" and "after" rod drop power distributions are calculated.

The mathematical formulation of $F_{\Delta H}^C$ employs the Section 6.2.1.2 definitions as follows:

$$F_{\Delta H,j}^C = \left[\sum_{i=1}^K F_{i,j}^{\text{node}} \times RL_j^N + FR_j \times F_{K,j}^{\text{node}} \times RL_j^N + (1-FR_j) \times F_{K,J}^{\text{node}} \times RL_j^R \right. \\ \left. + \sum_{i=N+1}^M F_{i,j}^{\text{node}} \times RL_j^R \right] \div M$$

and then:

$$F_{\Delta H}^C = \text{Max}_j (F_{\Delta H,j}^C)$$

Where:

M = Number of axial nodes.

RL_j^N = Non-rodded radial local factor for assembly j .

RL_j^R = Rodded radial local factor for assembly j .

FR_j = Linear fraction of assembly j which does not contain a control rod.

Radial local factors are edited by PDQ-EDIT using fine mesh PDQ07 mesh average powers. The PDQ07 cases are two-dimensional simulations with control bank(s) explicitly represented.

The nodal powers, $P_{i,j}^{node}$, are steady state three-dimensional calculations which explicitly model; control bank insertion, boron and xenon conditions, and other reactor state point variables necessary for a best estimate power distribution calculation.

$F_{\Delta H}^C$ is then evaluated by the NUC-MARGINS code or by hand calculations using the nodal powers from NODE-P and the RL from PDQ07. The NUC-MARGINS code has been independently verified to yield the correct $F_{\Delta H}^N$. $F_{\Delta H}^T$ is the ultimate output as defined by equation 6-2 for DNB analysis.

The system transient response and the transient DNB calculations would be performed by Westinghouse if the physics parameters exceeded the bounds of the previous analyses.

Q.2 Identify the nominal and various off-nominal cross-section sets that are generated in order to evaluate the different reactivity coefficients and defects.

A.2 The various fuel cross-section sets that are generated in order to evaluate different reactivity coefficients and defects are identified in Table 2.1. Nominal cross-sections are generated as a function of burnup at an average moderator temperature of 594°F and an average fuel temperature of 1250°F. The off-nominal cross-sections are generated at various burnups with varying moderator and fuel temperatures.

The cross-section representation in PDQØ7 differs between the quarter-core discrete pin and colorset models. The representation employed in the quarter-core model is discussed first and then the colorset discussion follows. All sets, except the baffle, use combined macroscopic and microscopic cross-sections.

Fuel cross-sections in quarter-core PDQØ7 are calculated according to the following relation:

$$\Sigma(T_M, T_F, Bu) = \Sigma_O(Bu) + \frac{\Delta\Sigma}{\Delta T_M} \times (T_M - T_M^{Ref}) + \frac{\Delta\Sigma}{\Delta \sqrt{T_F}} \times (\sqrt{T_F} - \sqrt{T_F}^{Ref})$$

where $\Sigma(T_M, T_F, Bu)$ = the total macroscopic cross-section as a function of moderator temperature, fuel temperature, and burnup.

$\Sigma_O(Bu)$ = the nominal macroscopic cross section as a function of burnup.

$\frac{\Delta\Sigma}{\Delta T_M}$ = the moderator temperature pseudo-microscopic cross-section which relates the change in macroscopic cross-section to change in moderator temperature.

$\frac{\Delta\Sigma}{\Delta \sqrt{T_F}}$ = the fuel temperature pseudo-microscopic cross-section which relates the change in macroscopic cross-section to a change in fuel temperature.

The macroscopic cross-sections given here may be of any type, e.g. transport, absorption, removal, or fission. The pseudo-microscopic cross-sections (or pseudo-micros) account for the change in the macroscopic cross-section as a result of a change from reference conditions. These pseudo-micros are input to PDQØ7 as a function of burnup. The moderator temperature pseudo-micros are determined from the cross-section sets at moderator temperatures of 630°F and 530°F (fuel temperature held constant at 1250°F).

The fuel temperature pseudo-micros are determined from the cross-section sets at fuel temperatures of 1250°F and 594°F (moderator temperature held constant at 594°F).

Most nonfuel cross-sections employed in quarter core calculations are evaluated as shown in Table 2.4, and are consistent with the core average moderator temperature of interest.

The reflector constants are evaluated at T_{inlet} (usually 557°F) and, at Hot Zero Power, are identical to the water gap constants. Baffle constants are evaluated using the method shown in Chapter 4 of EPRI NP-3642-SR (Few-Group Baffle and/or Reflector Constants for Diffusion Calculation Application, EPRI Special Report, August 1984).

Colorset PDQ07 calculations are performed which provide sufficient data to characterize operation from Hot Full Power (HFP) to Cold Zero Power (CZP) conditions. A breakpoint is designated at Hot Zero Power (HZP). Two sets of data (B-Constants) are then used in EPRI-NODE-P calculations:

1. Normal Operation - HFP to HZP
2. Low Temperature - HZP to CZP

B-Constants for the Normal Operation and Low Temperature models are generated following the sequence described in Section 3 of DPC-NF-2010.

Tables 2.1 and 2.4 describe conditions for fuel and non-fuel cross-section sets. The Normal Operation cross-sections input to colorset PDQ07 calculations are shown by the matrices in Table 2.2. Table 2.3 shows matrices of cross section sets for Low Temperature colorset calculations. Nonfuel cross-section sets (Table 2.4) are used which are consistent with the fuel moderator temperature.

Table 2.1
McGuire/Catawba
Fuel Cross-Section Sets

<u>Cross-Section Set Type</u>	<u>T_{mod} (°F)</u>	<u>T_{fuel} (°F)</u>	<u>Power</u>	<u>Burnup Timesteps (GWD/MTU)</u>	<u>Application</u>
P1	594	594	Zero	0.0	HFT → HZP
P2 (Nominal)	594	1250	Full	0.0	"
P3	630	1250	Full	0.0	"
P4	530	1250	Full	0.0	"
P8 (Nominal)	594	1250	Full	0.0, 0.1, 0.5, 1.0, 2.0, 4.0, 6.0, ..., 58.0, 60.0	"
P8B6	594	594	Full	"	"
P8B7	530	1250	Full	"	"
P8B8	630	1250	Full	"	"
P5	200	200	Zero	0.0	HZP → CZP
P9	200	200	Zero	0.0, 0.1, 0.5, 1.0, 2.0, 4.0, 6.0, ..., 58.0, 60.0	"
P6	557	557	Zero	0.0	"
P7	68	68	Zero	0.0	"

Table 2.2

Cross-Section Sets for Normal Operation
PDQ07 Colorsets

<u>BOL</u>				
Cross-Section Set Type				
<u>Effect</u>	<u>P2(Nominal)</u>	<u>P1</u>	<u>P3</u>	<u>P4</u>
Soluble Boron	X			
K-inf vs. T_{mod}	X		X	X
Migration Area vs. T_{mod}	X		X	X
Doppler	X	X		

<u>Depletion</u>				
Cross-Section Set Type				
<u>Reactivity Effect</u>	<u>P8(Nominal)</u>	<u>P8B6</u>	<u>P8B7</u>	<u>P8B8</u>
Exposure	X			
Soluble Boron	X			
Control Rods	X			
Xenon	X			
Doppler	X	X		
Moderator			X	X

Table 2.3

Cross-Section Sets for Low Temperature
PDQØ7 Colorsets

<u>BCL</u>			
Cross-Section Set Type			
<u>Effect</u>	<u>P5</u>	<u>P6</u>	<u>P7</u>
Soluble Boron	X		
K-inf. vs. T_{mod}	X	X	X
Migration Area vs. T_{mod}	X	X	X

<u>DEPLETION</u>	
<u>Reactivity Effect</u>	<u>Cross-Section Set Type P9</u>
Exposure	X
Soluble Boron	X
Control Rods	X

Table 2.4

McGuire/Catawba
Non-fuel Cross-Section Sets

<u>Material</u>	<u>Moderator Temperatures (°F)</u>
Water Cap/Reflector	630, 594, 557, 530, 200, 68
Guide Tube/Inst. Tube	630, 594, 557, 530, 200, 68
Control Rod	594, 557, 200, 68
Burnable Poison Rod	594, 557, 200, 68
Baffle	EPRI NP-3642-SR

Q.3 Provide a short description of the PDQ-EDIT code and describe the verification program that was undertaken to test data generated with PDQ-EDIT for use in SNA-CORE.

A.3 PDQ-EDIT is a utility code written by Duke Power Company that is capable of reading Internal File Management (IFM) files written by PDQ07. This code is primarily used to develop theoretical factors for SNA-CORE, and to edit and process data contained on pointwise flux, power and concentration IFM files. PDQ-EDIT, like all Nuclear Design software used in safety related analysis, is quality assured as required by Duke Power Company's Administrative Policy Manual for Nuclear Stations.

SNA-CORE theoretical factors are generated from PDQ-EDIT in what is commonly known as theoretical factor sets. Each theoretical factor set is valid over a user defined burnup range. Theoretical factor sets consist of assembly average powers, assembly peak pin powers, and detector mesh average two-group fluxes.

Verification of theoretical factor sets is accomplished by the utility code SNAVER. SNAVER compares the symmetric assembly average and peak pin powers on either a 1/4-core or 1/8-core basis, and then calculates a percent difference for each power at a given location with respect to the average at that location. Percent differences greater than 0.1% are flagged by the program. The cognizant engineer must then verify whether these errors are justified. SNAVER also checks for consistency between detector fluxes at symmetric locations, and for correct data format.

The formal benchmarking of theoretical factors developed from PDQ-EDIT was accomplished by comparing measured powers from Westinghouse's INCORE code, to those calculated from SNA-CORE for Sequoyah Unit 1 Cycle 1. All measured powers were inferred from plant supplied flux traces. Results from these comparisons are shown in Figures 1 thru 7. Good agreement between the two codes was observed. A summary of the average absolute relative error, and the standard deviation associated with these errors are presented in Table 1.

In conclusion, comparisons between measured data from Westinghouse's INCORE code and Duke's SNA-CORE code demonstrate the accuracy of the PDQ07, PDQ-EDIT, SNA-CORE code package. Also, in addition to the software quality assurance program employed at Duke, SNAVER provides an independent means of verifying the correctness of theoretical factor sets before they are used in a production environment.

Table 1

Statistical Summary of INCORE versus SNA-CORE
Measured Powers for Sequoyah 1 Cycle 1

<u>CASE</u>	<u>Burnup EFPD</u>	<u>Average Absolute Relative Error (%)</u>	<u>Standard Derration %</u>
1	71.82	1.34	1.84
2	101.62	1.06	1.43
3	133.30	1.14	1.48
4	166.04	1.28	1.64
5	231.70	1.21	1.48
6	292.04	1.20	1.51
7	378.92	1.05	1.34

Average Absolute
Relative Error $(\bar{D}) \equiv \left| \frac{[(\text{SNA-CORE} - \text{INCORE}) / \text{INCORE}]}{N} \right| * 100$

$$\bar{D} \equiv \sum_{i=1}^N D_i / N$$

FIGURE 1

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
71.82 EFPD 100(X)FP CONTROL BANK D AT 200 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.12 *	* 1.05 *	* 1.17 *	* 1.11 *	* 1.15 *	* 1.05 *	* 1.01 *	* .71 *
8	* 1.17 *	* 1.08 *	* 1.17 *	* 1.14 *	* 1.18 *	* 1.07 *	* 1.01 *	* .71 *
	* *	* *	* *	* *	* *	* *	* *	

	* 1.16 *	* 1.11 *	* 1.19 *	* 1.16 *	* 1.13 *	* 1.01 *	* .77 *	
9	* 1.17 *	* 1.13 *	* 1.19 *	* 1.17 *	* 1.13 *	* 1.03 *	* .77 *	
	* *	* *	* *	* *	* *	* *	* *	

	* 1.18 *	* 1.12 *	* 1.18 *	* 1.09 *	* .98 *	* .66 *		
10	* 1.17 *	* 1.14 *	* 1.18 *	* 1.11 *	* .97 *	* .65 *		
	* *	* *	* *	* *	* *	* *		

	* 1.18 *	* 1.13 *	* 1.08 *	* .92 *	* .56 *			
11	* 1.19 *	* 1.16 *	* 1.08 *	* .92 *	* .55 *			
	* *	* *	* *	* *	* *			

	* 1.09 *	* .99 *	* .86 *					
12	* 1.12 *	* .99 *	* .83 *					
	* *	* *	* *					

	* 1.02 *	* .51 *	SNA-CORE					
13	* .99 *	* .49 *	INCORE					
	* *	* *						

FIGURE 2

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
101.62 EFPD 100(X)FP CONTROL BANK D AT 218 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.14 *	* 1.06 *	* 1.16 *	* 1.13 *	* 1.17 *	* 1.06 *	* 1.00 *	* .71 *
8	* 1.16 *	* 1.09 *	* 1.17 *	* 1.15 *	* 1.17 *	* 1.08 *	* 1.00 *	* .71 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.16 *	* 1.12 *	* 1.18 *	* 1.16 *	* 1.12 *	* 1.01 *	* .76 *	* .76 *
9	* 1.17 *	* 1.14 *	* 1.18 *	* 1.18 *	* 1.13 *	* 1.03 *	* .76 *	* .76 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.18 *	* 1.13 *	* 1.17 *	* 1.09 *	* .97 *	* .65 *	* .65 *	* .65 *
10	* 1.17 *	* 1.15 *	* 1.17 *	* 1.11 *	* .96 *	* .65 *	* .65 *	* .65 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.17 *	* 1.13 *	* 1.08 *	* .91 *	* .55 *	* .55 *	* .55 *	* .55 *
11	* 1.18 *	* 1.16 *	* 1.08 *	* .92 *	* .55 *	* .55 *	* .55 *	* .55 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.11 *	* 1.00 *	* .85 *	* .83 *	* .83 *	* .83 *	* .83 *	* .83 *
12	* 1.11 *	* 1.00 *	* .83 *	* .83 *	* .83 *	* .83 *	* .83 *	* .83 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.02 *	* .51 *	* SNA-CORE	* .51 *	* .51 *	* .51 *	* .51 *	* .51 *
13	* .99 *	* .50 *	* INCORE	* .50 *	* .50 *	* .50 *	* .50 *	* .50 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

FIGURE 3

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
133.30 EFPD 100(Z)FP CONTROL BANK D AT 216 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.14 *	* 1.08 *	* 1.17 *	* 1.14 *	* 1.16 *	* 1.07 *	* .99 *	* .70 *
8	* 1.16 *	* 1.11 *	* 1.17 *	* 1.17 *	* 1.17 *	* 1.09 *	* .99 *	* .71 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.17 *	* 1.14 *	* 1.19 *	* 1.17 *	* 1.12 *	* 1.01 *	* .76 *	
9	* 1.17 *	* 1.16 *	* 1.18 *	* 1.19 *	* 1.12 *	* 1.03 *	* .76 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

		* 1.18 *	* 1.14 *	* 1.17 *	* 1.09 *	* .96 *	* .65 *	
10		* 1.17 *	* 1.16 *	* 1.16 *	* 1.11 *	* .95 *	* .65 *	
		* * *	* * *	* * *	* * *	* * *	* * *	

			* 1.16 *	* 1.13 *	* 1.06 *	* .91 *	* .55 *	
11			* 1.17 *	* 1.16 *	* 1.06 *	* .92 *	* .55 *	
			* * *	* * *	* * *	* * *	* * *	

				* 1.09 *	* 1.00 *	* .84 *		
12				* 1.10 *	* 1.00 *	* .82 *		
				* * *	* * *	* * *		

					* 1.01 *	* .51 *	* SNA-CORE	
13					* .98 *	* .50 *	* INCORE	
					* * *	* * *	* * *	

FIGURE 4

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
166.04 EFPD 100(X)FP CONTROL BANK D AT 210 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.13 *	* 1.09 *	* 1.17 *	* 1.15 *	* 1.14 *	* 1.08 *	* .99 *	* .71 *
8	* 1.16 *	* 1.11 *	* 1.17 *	* 1.10 *	* 1.15 *	* 1.10 *	* .99 *	* .71 *
	* *	* *	* *	* *	* *	* *	* *	* *

	* 1.16 *	* 1.15 *	* 1.19 *	* 1.17 *	* 1.11 *	* 1.01 *	* .76 *	
9	* 1.17 *	* 1.18 *	* 1.18 *	* 1.19 *	* 1.11 *	* 1.03 *	* .76 *	
	* *	* *	* *	* *	* *	* *	* *	

	* 1.18 *	* 1.15 *	* 1.16 *	* 1.09 *	* .96 *	* .66 *		
10	* 1.17 *	* 1.18 *	* 1.15 *	* 1.11 *	* .95 *	* .65 *		
	* *	* *	* *	* *	* *	* *		

	* 1.16 *	* 1.13 *	* 1.06 *	* .91 *	* .55 *			
11	* 1.17 *	* 1.17 *	* 1.06 *	* .92 *	* .55 *			
	* *	* *	* *	* *	* *			

	* 1.08 *	* 1.00 *	* .84 *					
12	* 1.09 *	* 1.00 *	* .82 *					
	* *	* *	* *					

	* 1.00 *	* .51 *	SNA-CORE					
13	* .97 *	* .50 *	INCORE					
	* *	* *						

FIGURE 5

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
231.70 EFPD 100(X)FP CONTROL BANK D AT 216 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.10 *	* 1.08 *	* 1.14 *	* 1.16 *	* 1.13 *	* 1.09 *	* .99 *	* .72 *
8	* 1.12 *	* 1.10 *	* 1.14 *	* 1.19 *	* 1.13 *	* 1.12 *	* .99 *	* .73 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.13 *	* 1.16 *	* 1.16 *	* 1.17 *	* 1.09 *	* 1.02 *	* .76 *	
9	* 1.14 *	* 1.18 *	* 1.15 *	* 1.19 *	* 1.09 *	* 1.04 *	* .77 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

	* 1.16 *	* 1.16 *	* 1.14 *	* 1.10 *	* .96 *	* .67 *		
10	* 1.15 *	* 1.18 *	* 1.13 *	* 1.12 *	* .95 *	* .68 *		
	* * *	* * *	* * *	* * *	* * *	* * *		

	* 1.14 *	* 1.14 *	* 1.05 *	* .92 *	* .56 *			
11	* 1.14 *	* 1.17 *	* 1.05 *	* .93 *	* .56 *			
	* * *	* * *	* * *	* * *	* * *			

	* 1.07 *	* 1.02 *	* .84 *					
12	* 1.08 *	* 1.02 *	* .82 *					
	* * *	* * *	* * *					

	* 1.00 *	* .53 *	SNA-CORE					
13	* .98 *	* .52 *	INCORE					
	* * *	* * *						

FIGURE 6

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
292.04 EFPD 100(X)FP CONTROL BANK D AT 216 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* 1.07 *	* 1.07 *	* 1.12 *	* 1.15 *	* 1.11 *	* 1.10 *	* .99 *	* .74 *
8	* 1.09 *	* 1.09 *	* 1.12 *	* 1.18 *	* 1.12 *	* 1.13 *	* .99 *	* .75 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.11 *	* 1.15 *	* 1.14 *	* 1.16 *	* 1.08 *	* 1.03 *	* .78 *	
9	* 1.11 *	* 1.18 *	* 1.13 *	* 1.18 *	* 1.08 *	* 1.05 *	* .78 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

		* 1.14 *	* 1.16 *	* 1.12 *	* 1.11 *	* .97 *	* .69 *	
10		* 1.13 *	* 1.18 *	* 1.11 *	* 1.13 *	* .96 *	* .69 *	
		* * *	* * *	* * *	* * *	* * *	* * *	

			* 1.12 *	* 1.13 *	* 1.05 *	* .93 *	* .58 *	
11			* 1.12 *	* 1.16 *	* 1.05 *	* .94 *	* .57 *	
			* * *	* * *	* * *	* * *	* * *	

				* 1.06 *	* 1.04 *	* .85 *		
12				* 1.07 *	* 1.04 *	* .83 *		
				* * *	* * *	* * *		

					* 1.00 *	* .55 *	SNA-CORE	
13					* .98 *	* .54 *	INCORE	
					* * *	* * *		

FIGURE 7

SEQUOYAH 1 CYCLE 1 SNA-CORE VS. INCORE MEASURED POWERS
 378.92 EFPD 100(X)FP CONTROL BANK D AT 222 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A
	* 1.02 *	* 1.04 *	* 1.08 *	* 1.14 *	* 1.09 *	* 1.10 *	* 1.00 *	* .77 *
8	* 1.06 *	* 1.06 *	* 1.08 *	* 1.15 *	* 1.09 *	* 1.13 *	* 1.01 *	* .79 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *
	* 1.07 *	* 1.13 *	* 1.10 *	* 1.14 *	* 1.07 *	* 1.05 *	* .80 *	
9	* 1.08 *	* 1.15 *	* 1.10 *	* 1.15 *	* 1.07 *	* 1.07 *	* .81 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	
	* 1.10 *	* 1.14 *	* 1.09 *	* 1.11 *	* .98 *	* .73 *		
10	* 1.09 *	* 1.15 *	* 1.09 *	* 1.13 *	* .97 *	* .74 *		
	* * *	* * *	* * *	* * *	* * *	* * *		
	* 1.09 *	* 1.13 *	* 1.05 *	* .96 *	* .60 *			
11	* 1.10 *	* 1.15 *	* 1.05 *	* .97 *	* .60 *			
	* * *	* * *	* * *	* * *	* * *			
	* 1.06 *	* 1.06 *	* .87 *					
12	* 1.07 *	* 1.06 *	* .85 *					
	* * *	* * *	* * *					
	* 1.02 *	* .58 *	* SNA-CORE					
13	* 1.00 *	* .57 *	* INCORE					
	* * *	* * *	* * *					

Q.4. Comment on the reasons for the 3.1% non-conservative bias in the calculated peak axial powers (Section 11.5.4). Describe the model refinements, if any, that have been undertaken to reduce this bias.

A.4. The reason there is a -0.031 bias on the calculated peak axial powers (Section 11.5.4) is that the models used by Duke at the time of this report underpredicted the peak axial power. This -0.031 bias is the mean difference (\bar{D}) and is defined by equation 11-2. This value is a difference and not a percentage difference. The mean percent difference for all cases considered was -2.195% (Table 11-10). Again, it should be pointed out, that this number applies to all peak C, M pairs ≥ 1.0 .

Although Dukes' models underpredict the peak axial power on an average of -2.195%, the Observed Nuclear Reliability Factor (ONRF) directly reflects this non-conservative prediction. This can be seen by examining equation 11-11. Because \bar{D} is subtracted from \bar{M} , this equation is conservative for all cases of \bar{D} . (That is, \bar{D} being positive, negative, or 0)

Consider the ONRF calculation of the peak axial power on Table 11-6. In this example if \bar{D} were 0 the ONRF would be 1.035. With a \bar{D} of -0.031 the ONRF is 1.058. This is a 2.2% increase in ONRF. The \bar{D} of -0.031 represents a 2.195% underprediction of measured peak axial power. (Table 11-10). Therefore, it can be seen from this example, that there is a 1% increase in ONRF for each 1% that the model underpredicts the measured peak axial power.

In summary, even though the models used by Duke underpredict the peak axial power, the ONRF reflects this underprediction. As shown in the above example, there is a 1 to 1 correspondence in the percentage of the underprediction to the percentage increase in the ONRF.

The model refinements undertaken to reduce this underprediction are discussed in the answer to question 6 parts one and two. The refinements are; 1) normalization of EPRI-NODE-P to include unrodded M^2 adjustments, and 2) an increase in the number of axial nodes. Attached are the results of some maps compared to predictions using 12 levels and 18 levels of EPRI-NODE-P. Attached are the Difference Means and Standard Deviations for Assembly Peak Axial Powers (C, $M \geq 1.0$), and Assembly Radial Powers. Also attached are Percent Difference Means (C, $M \geq 1.0$) for Assembly Peak Axial Powers and Assembly Radial Powers.

Table 4-1

Difference Means and Standard Deviations for Assembly Radial Powers
(C, M \geq 1.0)

Unit/Cycle	EPRI-NODE-P Model	N	\bar{D}	S(\bar{D})	$\overline{ABS(D)}$	S(ABS(D))
M1/C2	12 Level	144	-0.002	0.017	0.014	0.010
M1/C2	18 Level	144	-0.002	0.015	0.012	0.010

Difference Means and Standard Deviations for Assembly Peak Axial Powers
(C, M \geq 1.0)

Unit/Cycle	EPRI-NODE-P Model	N	\bar{D}	S(\bar{D})	$\overline{ABS(D)}$	S(ABS(D))
M1/C2	12 Level	232	-0.004	0.031	0.025	0.018
M1/C2	18 Level	246	0.030	0.035	0.036	0.029

Percent Difference Means for Assembly Radial Powers
(C, M \geq 1.0)

Unit/Cycle	EPRI-NODE-P Model	Mean % Difference	Mean Absolute % Difference
M1/C2	12 Level	-0.170	1.35
M1/C2	18 Level	-0.142	1.17

Percent Difference Means for Assembly Peak Axial Powers
(C, M \geq 1.0)

Unit/Cycle	EPRI-NODE-P Model	Mean % Difference	Mean Absolute % Difference
M1/C2	12 Level	-0.407	2.039
M1/C2	18 Level	2.382	2.890

FIGURE 4.1

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

18 EFPD 100XFP CONTROL BANK D AT 207 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A
8	.95	1.08	1.24	.97	.93	.80	1.09	1.28
9	.93	1.06	1.27	.98	1.00	.85	1.19	1.27
10	1.10	1.27	1.25	1.03	.98	.93	1.50	1.30
11	1.09	1.27	1.25	1.03	1.02	.95	1.53	1.28
12	1.24	1.25	1.25	1.28	1.00	.96	1.13	1.19
13	1.28	1.27	1.27	1.32	1.03	1.00	1.19	1.16
14	.98	1.04	1.28	1.25	1.27	1.14	1.52	.92
15	1.00	1.04	1.32	1.28	1.29	1.15	1.48	.91
16	.94	.99	1.01	1.27	1.43	1.43	1.29	
17	1.02	1.04	1.02	1.30	1.40	1.41	1.26	
18	.81	.93	.97	1.14	1.43	.99	.79	
19	.88	.98	1.05	1.17	1.44	.98	.77	
20	1.10	1.51	1.14	1.52	1.30	.80		
21	1.12	1.46	1.14	1.44	1.26	.79		
22	1.28	1.31	1.19	.93	CALC			
23	1.27	1.26	1.15	.90	MEAS			

FIGURE 4.2

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

30 EFPD 100XFP CONTROL BANK D AT 194 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* .90 *	* 1.04 *	* 1.21 *	* .95 *	* .92 *	* .82 *	* 1.12 *	* 1.30 *
8	* .92 *	* 1.06 *	* 1.26 *	* .98 *	* 1.02 *	* .89 *	* 1.20 *	* 1.30 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.05 *	* 1.24 *	* 1.22 *	* 1.00 *	* .98 *	* .95 *	* 1.53 *	* 1.33 *
9	* 1.08 *	* 1.26 *	* 1.25 *	* 1.03 *	* 1.04 *	* 1.00 *	* 1.53 *	* 1.29 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.22 *	* 1.23 *	* 1.24 *	* 1.30 *	* 1.01 *	* .98 *	* 1.16 *	* 1.21 *
10	* 1.27 *	* 1.26 *	* 1.26 *	* 1.32 *	* 1.04 *	* 1.04 *	* 1.21 *	* 1.19 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .95 *	* 1.01 *	* 1.30 *	* 1.26 *	* 1.28 *	* 1.15 *	* 1.54 *	* .94 *
11	* 1.00 *	* 1.04 *	* 1.33 *	* 1.29 *	* 1.31 *	* 1.17 *	* 1.52 *	* .94 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .92 *	* .98 *	* 1.02 *	* 1.28 *	* 1.43 *	* 1.43 *	* 1.31 *	* * *
12	* 1.03 *	* 1.05 *	* 1.04 *	* 1.31 *	* 1.42 *	* 1.44 *	* 1.29 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .83 *	* .96 *	* .98 *	* 1.16 *	* 1.44 *	* 1.00 *	* .80 *	* * *
13	* .90 *	* 1.01 *	* 1.08 *	* 1.19 *	* 1.46 *	* 1.01 *	* .79 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.12 *	* 1.54 *	* 1.16 *	* 1.55 *	* 1.31 *	* .81 *	* * *	* * *
14	* 1.15 *	* 1.50 *	* 1.16 *	* 1.45 *	* 1.28 *	* .81 *	* * *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.31 *	* 1.33 *	* 1.21 *	* .94 *	* CALC			
15	* 1.30 *	* 1.30 *	* 1.16 *	* .90 *	* MEAS			
	* * *	* * *	* * *	* * *	* * *			

FIGURE 4.3

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

48 EFPD 100ZFP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .94 *	* 1.08 *	* 1.22 *	* .98 *	* .95 *	* .81 *	* 1.07 *	* 1.24 *
	* .92 *	* 1.04 *	* 1.23 *	* .97 *	* 1.00 *	* .86 *	* 1.16 *	* 1.25 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.10 *	* 1.25 *	* 1.23 *	* 1.04 *	* 1.00 *	* .92 *	* 1.46 *	* 1.27 *
	* 1.07 *	* 1.24 *	* 1.22 *	* 1.01 *	* 1.01 *	* .97 *	* 1.48 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.23 *	* 1.24 *	* 1.24 *	* 1.26 *	* 1.01 *	* .94 *	* 1.11 *	* 1.15 *
	* 1.25 *	* 1.23 *	* 1.22 *	* 1.27 *	* 1.00 *	* 1.01 *	* 1.17 *	* 1.14 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .99 *	* 1.04 *	* 1.26 *	* 1.22 *	* 1.22 *	* 1.10 *	* 1.47 *	* .90 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.25 *	* 1.12 *	* 1.45 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .96 *	* 1.01 *	* 1.01 *	* 1.22 *	* 1.35 *	* 1.36 *	* 1.24 *	*
	* 1.00 *	* 1.02 *	* 1.00 *	* 1.25 *	* 1.34 *	* 1.37 *	* 1.23 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

13	* .82 *	* .92 *	* .94 *	* 1.10 *	* 1.36 *	* .95 *	* .77 *	*
	* .87 *	* .97 *	* 1.04 *	* 1.14 *	* 1.39 *	* .96 *	* .76 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

14	* 1.08 *	* 1.47 *	* 1.11 *	* 1.47 *	* 1.24 *	* .78 *	*	
	* 1.11 *	* 1.45 *	* 1.12 *	* 1.39 *	* 1.23 *	* .78 *	*	
	* * *	* * *	* * *	* * *	* * *	* * *	*	

15	* 1.24 *	* 1.27 *	* 1.16 *	* .90 *	CALC			
	* 1.26 *	* 1.25 *	* 1.12 *	* .87 *	MEAS			
	* * *	* * *	* * *	* * *				

FIGURE 4.4

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

61 EFPD 100ZFP CONTROL BANK D AT 220 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .92 *	* 1.05 *	* 1.19 *	* .97 *	* .94 *	* .81 *	* 1.08 *	* 1.25 *
	* .91 *	* 1.03 *	* 1.23 *	* .96 *	* 1.00 *	* .86 *	* 1.15 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.07 *	* 1.22 *	* 1.20 *	* 1.02 *	* .99 *	* .93 *	* 1.47 *	* 1.27 *
	* 1.06 *	* 1.23 *	* 1.21 *	* 1.00 *	* 1.00 *	* .96 *	* 1.47 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.20 *	* 1.21 *	* 1.21 *	* 1.24 *	* 1.00 *	* .95 *	* 1.12 *	* 1.16 *
	* 1.24 *	* 1.22 *	* 1.21 *	* 1.26 *	* 1.00 *	* 1.01 *	* 1.17 *	* 1.14 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .97 *	* 1.02 *	* 1.24 *	* 1.20 *	* 1.22 *	* 1.11 *	* 1.47 *	* .91 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.24 *	* 1.12 *	* 1.45 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .95 *	* 1.00 *	* 1.00 *	* 1.22 *	* 1.35 *	* 1.36 *	* 1.24 *	*
	* 1.01 *	* 1.02 *	* 1.00 *	* 1.24 *	* 1.33 *	* 1.35 *	* 1.22 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

13	* .82 *	* .93 *	* .95 *	* 1.11 *	* 1.36 *	* .95 *	* .77 *	*
	* .88 *	* .98 *	* 1.04 *	* 1.14 *	* 1.38 *	* .96 *	* .75 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

14	* 1.09 *	* 1.48 *	* 1.12 *	* 1.48 *	* 1.24 *	* .78 *	*	
	* 1.10 *	* 1.44 *	* 1.12 *	* 1.38 *	* 1.22 *	* .77 *	*	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

15	* 1.25 *	* 1.27 *	* 1.16 *	* .91 *	CALC			
	* 1.24 *	* 1.23 *	* 1.11 *	* .87 *	MEAS			
	* * *	* * *	* * *	* * *				

FIGURE 4.5

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

101 EFPD 100ZFP CONTROL BANK D AT 223 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .91 *	* 1.03 *	* 1.16 *	* .96 *	* .95 *	* .83 *	* 1.08 *	* 1.22 *
	* .90 *	* 1.03 *	* 1.23 *	* .97 *	* 1.01 *	* .88 *	* 1.14 *	* 1.21 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.04 *	* 1.19 *	* 1.17 *	* 1.00 *	* .99 *	* .94 *	* 1.46 *	* 1.25 *
	* 1.04 *	* 1.21 *	* 1.19 *	* 1.00 *	* 1.01 *	* .97 *	* 1.45 *	* 1.21 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.17 *	* 1.17 *	* 1.17 *	* 1.23 *	* .99 *	* .96 *	* 1.11 *	* 1.14 *
	* 1.22 *	* 1.20 *	* 1.19 *	* 1.25 *	* 1.00 *	* 1.01 *	* 1.15 *	* 1.13 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .96 *	* 1.01 *	* 1.23 *	* 1.19 *	* 1.20 *	* 1.09 *	* 1.45 *	* .90 *
	* .99 *	* 1.02 *	* 1.25 *	* 1.21 *	* 1.23 *	* 1.10 *	* 1.41 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .95 *	* 1.00 *	* .99 *	* 1.20 *	* 1.31 *	* 1.32 *	* 1.21 *	* * *
	* 1.01 *	* 1.02 *	* 1.00 *	* 1.23 *	* 1.30 *	* 1.32 *	* 1.20 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

13	* .84 *	* .94 *	* .96 *	* 1.09 *	* 1.32 *	* .94 *	* .77 *	* * *
	* .89 *	* .98 *	* 1.03 *	* 1.12 *	* 1.34 *	* .95 *	* .76 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

14	* 1.09 *	* 1.46 *	* 1.11 *	* 1.45 *	* 1.21 *	* .77 *	* * *	* * *
	* 1.10 *	* 1.43 *	* 1.11 *	* 1.37 *	* 1.20 *	* .77 *	* * *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

15	* 1.22 *	* 1.25 *	* 1.14 *	* .90 *	CALC			
	* 1.21 *	* 1.20 *	* 1.10 *	* .87 *	MEAS			
	* * *	* * *	* * *	* * *	*****			

FIGURE 4.6

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (12 LEVEL) VS. MEAS

130 EFPD 100ZFP CONTROL BANK D AT 216 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .90 *	* 1.02 *	* 1.18 *	* .95 *	* .95 *	* .85 *	* 1.09 *	* 1.21 *
	* .93 *	* 1.04 *	* 1.23 *	* .98 *	* 1.01 *	* .89 *	* 1.14 *	* 1.20 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.04 *	* 1.20 *	* 1.18 *	* 1.00 *	* .99 *	* .96 *	* 1.46 *	* 1.24 *
	* 1.07 *	* 1.23 *	* 1.20 *	* 1.01 *	* 1.02 *	* .98 *	* 1.45 *	* 1.20 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.18 *	* 1.18 *	* 1.18 *	* 1.24 *	* 1.00 *	* .97 *	* 1.12 *	* 1.14 *
	* 1.23 *	* 1.22 *	* 1.20 *	* 1.26 *	* 1.01 *	* 1.02 *	* 1.14 *	* 1.11 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .95 *	* 1.00 *	* 1.24 *	* 1.19 *	* 1.20 *	* 1.10 *	* 1.44 *	* .90 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.24 *	* 1.11 *	* 1.41 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .95 *	* 1.00 *	* 1.00 *	* 1.20 *	* 1.30 *	* 1.31 *	* 1.20 *	*
	* 1.03 *	* 1.04 *	* 1.02 *	* 1.24 *	* 1.31 *	* 1.32 *	* 1.19 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

13	* .85 *	* .96 *	* .97 *	* 1.10 *	* 1.31 *	* .95 *	* .77 *	*
	* .90 *	* 1.00 *	* 1.05 *	* 1.13 *	* 1.34 *	* .95 *	* .76 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

14	* 1.09 *	* 1.46 *	* 1.12 *	* 1.44 *	* 1.20 *	* .78 *	*	*
	* 1.10 *	* 1.43 *	* 1.11 *	* 1.37 *	* 1.19 *	* .77 *	*	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

15	* 1.21 *	* 1.24 *	* 1.14 *	* .90 *	* CALC			
	* 1.19 *	* 1.20 *	* 1.10 *	* .87 *	* MEAS			
	* * *	* * *	* * *	* * *	*			

FIGURE 4.7

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

18 EFPD 100XFP CONTROL BANK D AT 207 STEPS WITHDRAWN

	H		G		F		E		D		C		B		A		

8	*	.96	*	1.11	*	1.27	*	1.00	*	.96	*	.82	*	1.13	*	1.32	*
	*	.93	*	1.06	*	1.27	*	.98	*	1.00	*	.85	*	1.19	*	1.27	*
	*		*		*		*		*		*		*		*		*

9	*	1.13	*	1.30	*	1.28	*	1.06	*	1.01	*	.95	*	1.55	*	1.35	*
	*	1.09	*	1.27	*	1.25	*	1.03	*	1.02	*	.95	*	1.53	*	1.28	*
	*		*		*		*		*		*		*		*		*

10	*	1.27	*	1.28	*	1.29	*	1.32	*	1.03	*	.99	*	1.17	*	1.23	*
	*	1.28	*	1.27	*	1.27	*	1.32	*	1.03	*	1.00	*	1.19	*	1.16	*
	*		*		*		*		*		*		*		*		*

11	*	1.00	*	1.06	*	1.32	*	1.29	*	1.31	*	1.17	*	1.57	*	.95	*
	*	1.00	*	1.04	*	1.32	*	1.28	*	1.29	*	1.15	*	1.48	*	.91	*
	*		*		*		*		*		*		*		*		*

12	*	.97	*	1.02	*	1.03	*	1.31	*	1.47	*	1.47	*	1.33	*		*
	*	1.02	*	1.04	*	1.02	*	1.30	*	1.40	*	1.41	*	1.26	*		*
	*		*		*		*		*		*		*		*		*

13	*	.83	*	.96	*	.99	*	1.17	*	1.47	*	1.01	*	.82	*		*
	*	.88	*	.98	*	1.05	*	1.17	*	1.44	*	.98	*	.77	*		*
	*		*		*		*		*		*		*		*		*

14	*	1.13	*	1.56	*	1.17	*	1.57	*	1.34	*	.82	*		*		*
	*	1.12	*	1.46	*	1.14	*	1.44	*	1.26	*	.79	*		*		*
	*		*		*		*		*		*		*		*		*

15	*	1.33	*	1.35	*	1.23	*	.96	*	CALC							
	*	1.27	*	1.26	*	1.15	*	.90	*	MEAS							
	*		*		*		*		*								

FIGURE 4.8

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

30 EFPD 100XFP CONTROL BANK D AT 194 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .92 *	* 1.06 *	* 1.24 *	* .97 *	* .94 *	* .84 *	* 1.15 *	* 1.34 *
	* .92 *	* 1.06 *	* 1.26 *	* .98 *	* 1.02 *	* .89 *	* 1.20 *	* 1.30 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.08 *	* 1.27 *	* 1.26 *	* 1.03 *	* 1.01 *	* .98 *	* 1.58 *	* 1.37 *
	* 1.08 *	* 1.26 *	* 1.25 *	* 1.03 *	* 1.04 *	* 1.00 *	* 1.53 *	* 1.29 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.25 *	* 1.26 *	* 1.27 *	* 1.34 *	* 1.04 *	* 1.01 *	* 1.19 *	* 1.25 *
	* 1.27 *	* 1.26 *	* 1.26 *	* 1.32 *	* 1.04 *	* 1.04 *	* 1.21 *	* 1.19 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .98 *	* 1.04 *	* 1.34 *	* 1.30 *	* 1.32 *	* 1.19 *	* 1.59 *	* .97 *
	* 1.00 *	* 1.04 *	* 1.33 *	* 1.29 *	* 1.31 *	* 1.17 *	* 1.52 *	* .94 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .95 *	* 1.01 *	* 1.04 *	* 1.32 *	* 1.47 *	* 1.48 *	* 1.35 *	*
	* 1.03 *	* 1.05 *	* 1.04 *	* 1.31 *	* 1.42 *	* 1.44 *	* 1.29 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

13	* .85 *	* .98 *	* 1.01 *	* 1.19 *	* 1.48 *	* 1.03 *	* .83 *	*
	* .90 *	* 1.01 *	* 1.08 *	* 1.19 *	* 1.46 *	* 1.01 *	* .79 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

14	* 1.16 *	* 1.59 *	* 1.20 *	* 1.59 *	* 1.35 *	* .84 *	*	*
	* 1.15 *	* 1.50 *	* 1.16 *	* 1.45 *	* 1.28 *	* .81 *	*	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

15	* 1.35 *	* 1.38 *	* 1.25 *	* .97 *	* CALC			
	* 1.30 *	* 1.30 *	* 1.16 *	* .90 *	* MEAS			
	* * *	* * *	* * *	* * *	* * *			

FIGURE 4.9

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

48 EFPD 100ZFP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A
8	.96	1.10	1.25	1.00	.98	.84	1.11	1.28
9	.92	1.04	1.23	.97	1.00	.86	1.16	1.25
9	1.12	1.28	1.26	1.06	1.03	.95	1.51	1.31
10	1.07	1.24	1.22	1.01	1.01	.97	1.48	1.24
10	1.26	1.27	1.27	1.30	1.04	.97	1.14	1.19
11	1.25	1.23	1.22	1.27	1.00	1.01	1.17	1.14
11	1.01	1.07	1.30	1.26	1.26	1.14	1.52	.93
12	.99	1.03	1.26	1.22	1.25	1.12	1.45	.90
12	.98	1.03	1.04	1.26	1.39	1.40	1.28	
13	1.00	1.02	1.00	1.25	1.34	1.37	1.23	
13	.84	.95	.97	1.14	1.40	.98	.79	
14	.87	.97	1.04	1.14	1.39	.96	.76	
14	1.11	1.52	1.15	1.52	1.28	.80		
15	1.11	1.45	1.12	1.39	1.23	.78		
15	1.29	1.31	1.20	.93	CALC			
	1.26	1.25	1.12	.87	MEAS			

FIGURE 4.10

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

61 EFPD 100ZFP CONTROL BANK D AT 220 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .95 *	* 1.08 *	* 1.23 *	* .99 *	* .97 *	* .84 *	* 1.12 *	* 1.29 *
	* .91 *	* 1.03 *	* 1.23 *	* .96 *	* 1.00 *	* .86 *	* 1.15 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.10 *	* 1.25 *	* 1.24 *	* 1.05 *	* 1.02 *	* .96 *	* 1.52 *	* 1.31 *
	* 1.06 *	* 1.23 *	* 1.21 *	* 1.00 *	* 1.00 *	* .96 *	* 1.47 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.23 *	* 1.24 *	* 1.25 *	* 1.28 *	* 1.03 *	* .98 *	* 1.15 *	* 1.20 *
	* 1.24 *	* 1.22 *	* 1.21 *	* 1.26 *	* 1.00 *	* 1.01 *	* 1.17 *	* 1.14 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* 1.00 *	* 1.05 *	* 1.28 *	* 1.24 *	* 1.26 *	* 1.14 *	* 1.52 *	* .93 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.24 *	* 1.12 *	* 1.45 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .98 *	* 1.02 *	* 1.03 *	* 1.26 *	* 1.39 *	* 1.40 *	* 1.28 *	* * *
	* 1.01 *	* 1.02 *	* 1.00 *	* 1.24 *	* 1.33 *	* 1.35 *	* 1.22 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

13	* .85 *	* .96 *	* .98 *	* 1.14 *	* 1.40 *	* .98 *	* .80 *	* * *
	* .88 *	* .98 *	* 1.04 *	* 1.14 *	* 1.38 *	* .96 *	* .75 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

14	* 1.12 *	* 1.53 *	* 1.16 *	* 1.52 *	* 1.28 *	* .80 *	* * *	* * *
	* 1.10 *	* 1.44 *	* 1.12 *	* 1.38 *	* 1.22 *	* .77 *	* * *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

15	* 1.29 *	* 1.31 *	* 1.20 *	* .94 *	CALC			
	* 1.24 *	* 1.23 *	* 1.11 *	* .87 *	MEAS			
	* * *	* * *	* * *	* * *	*****			

FIGURE 4.11

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

101 EFPD 100XFP CONTROL BANK D AT 223 STEPS WITHDRAWN

	H		G		F		E		D		C		B		A		

8	*	.93	*	1.05	*	1.20	*	.98	*	.97	*	.85	*	1.12	*	1.26	*
	*	.90	*	1.03	*	1.23	*	.97	*	1.01	*	.88	*	1.14	*	1.21	*
	*		*		*		*		*		*		*		*		*

9	*	1.07	*	1.23	*	1.21	*	1.03	*	1.02	*	.97	*	1.51	*	1.29	*
	*	1.04	*	1.21	*	1.19	*	1.00	*	1.01	*	.97	*	1.45	*	1.21	*
	*		*		*		*		*		*		*		*		*

10	*	1.21	*	1.21	*	1.21	*	1.27	*	1.02	*	.99	*	1.15	*	1.18	*
	*	1.22	*	1.20	*	1.19	*	1.25	*	1.00	*	1.01	*	1.15	*	1.13	*
	*		*		*		*		*		*		*		*		*

11	*	.98	*	1.03	*	1.27	*	1.23	*	1.24	*	1.13	*	1.49	*	.93	*
	*	.99	*	1.02	*	1.25	*	1.21	*	1.23	*	1.10	*	1.41	*	.90	*
	*		*		*		*		*		*		*		*		*

12	*	.98	*	1.02	*	1.02	*	1.24	*	1.35	*	1.36	*	1.25	*		
	*	1.01	*	1.02	*	1.00	*	1.23	*	1.30	*	1.32	*	1.20	*		
	*		*		*		*		*		*		*		*		

13	*	.86	*	.98	*	.99	*	1.13	*	1.36	*	.97	*	.79	*		
	*	.89	*	.98	*	1.03	*	1.12	*	1.34	*	.95	*	.76	*		
	*		*		*		*		*		*		*		*		

14	*	1.12	*	1.51	*	1.15	*	1.49	*	1.25	*	.80	*				
	*	1.10	*	1.43	*	1.11	*	1.37	*	1.20	*	.77	*				
	*		*		*		*		*		*		*				

15	*	1.26	*	1.29	*	1.18	*	.93	*	CALC							
	*	1.21	*	1.20	*	1.10	*	.87	*	MEAS							
	*		*		*		*		*								

FIGURE 4.12

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

130 EFPD 100XFP CONTROL BANK D AT 216 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

	* .93 *	* 1.05 *	* 1.21 *	* .98 *	* .97 *	* .88 *	* 1.13 *	* 1.25 *
8	* .93 *	* 1.04 *	* 1.23 *	* .98 *	* 1.01 *	* .89 *	* 1.14 *	* 1.20 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.07 *	* 1.24 *	* 1.22 *	* 1.03 *	* 1.02 *	* .99 *	* 1.50 *	* 1.27 *
9	* 1.07 *	* 1.23 *	* 1.20 *	* 1.01 *	* 1.02 *	* .99 *	* 1.45 *	* 1.20 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.22 *	* 1.22 *	* 1.22 *	* 1.27 *	* 1.03 *	* 1.00 *	* 1.15 *	* 1.17 *
10	* 1.23 *	* 1.22 *	* 1.20 *	* 1.26 *	* 1.01 *	* 1.02 *	* 1.14 *	* 1.11 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .98 *	* 1.03 *	* 1.27 *	* 1.23 *	* 1.24 *	* 1.13 *	* 1.48 *	* .93 *
11	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.24 *	* 1.11 *	* 1.41 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .98 *	* 1.03 *	* 1.03 *	* 1.24 *	* 1.34 *	* 1.35 *	* 1.24 *	* * *
12	* 1.03 *	* 1.04 *	* 1.02 *	* 1.24 *	* 1.31 *	* 1.32 *	* 1.19 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* .88 *	* .99 *	* 1.00 *	* 1.13 *	* 1.35 *	* .98 *	* .80 *	* * *
13	* .90 *	* 1.00 *	* 1.05 *	* 1.13 *	* 1.34 *	* .95 *	* .76 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.13 *	* 1.50 *	* 1.15 *	* 1.48 *	* 1.24 *	* .80 *	* * *	* * *
14	* 1.10 *	* 1.43 *	* 1.11 *	* 1.37 *	* 1.19 *	* .77 *	* * *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

	* 1.25 *	* 1.27 *	* 1.17 *	* .93 *	* CALC			
15	* 1.19 *	* 1.20 *	* 1.10 *	* .87 *	* MEAS			
	* * *	* * *	* * *	* * *	* * *			

Q.5 Duke Power Company's contention that no uncertainty in calculated pin powers needs to be accounted for has not been adequately established. One of a set of standard problems, recently developed at Brookhaven National Laboratory for a licensee to assess its ability to calculate typical PWR fuel assemblies, is attached. The licensee's solution using PDQ07 will be an important means of determining the uncertainty in the calculated pin peaking factors.

A.5 Both NFS-1001A and Section 8 of DPC-NF-2010 presented justification the the PDQ07 model using two group MND cross sections overpredicts the maximum rod powers when compared to both measured criticals and more advanced transport theory calculations. These comparisons covered different assembly designs, different enrichments, different burnable absorbers, different fuel and moderator temperatures, and different soluble boron concentrations.

Duke Power as prime contractor to DOE has recently performed additional cold criticals at B&W. Results from two of the criticals, compared to EPRI-CELL/PDQ07 calculations are attached (Report DOE/ET/34212-41, April, 1984). Core 1 represents a no burnable absorber B&W fuel assembly and Core 5 a gadolinium poisoned B&W fuel assembly.

Figure A-3 (Figure 5.1, Answer 5) and A-4 (Figure 5.2) show comparisons of measured to calculated powers for these cores. The maximum rod powers were overpredicted by EPRI-CELL/PDQ07 by 1.2% and 1.4% respectively. An analysis of the eight highest measured pins for each critical assembly shows that the average pin power difference was + 0.0061 (Core 1) and + 0.0104 (Core 5) with PDQ07 overpredicting relative to measured.

Page A-4 of DOE/ET/34212-41 attributes the overprediction of pin powers near the water holes to use of MND thermal cross sections.

Duke Power has performed the requested calculations on the BNL benchmark assembly problem using EPRI-CELL/PDQ07. The results of those calculations are attached. Figures 5.3 through 5.16 present PDQ07 calculated rod powers for the non-rodded and 16 BP cases. Table 5.1 presents rod power summary data for these analyses. Table 5.2 presents summary reactivity information as requested in section II of the benchmark problem. In accordance with the Duke-NRC telephone agreement, data for items I.2 through I.5 of the problem will not be presented.

From the information presented in NFS-1001A, DPC-NF-2010, DOE/ET/34212-41, and the benchmark assembly calculations, sufficient analyses have been performed to show that no additional pin peak uncertainty is necessary.

Table 5.1

Benchmark Problem
 EPRI-CELL/PDQØ7 Analysis
 Maximum Rod Power Summary

<u>Exposure</u> <u>(MWD/MT)</u>	<u>Non-BP</u> <u>Assembly</u>	<u>16-BP</u> <u>Assembly</u>
0	1.060	1.107
500	1.059	1.104
5000	1.054	1.073
10000	1.046	1.041
20000	1.028	1.021
30000	1.014	1.016
40000	1.008	1.010

Table 5.2

Benchmark Problem
Reactivity Defect Calculations

No BP's

Case	Description	0 MWD/MTU		30000 MWD/MTU	
		K-Infinity	% $\Delta\rho$	K-Infinity	% $\Delta\rho$
0	Base	1.183699	--	0.896243	-
1	Doppler	1.194852	-0.789	0.907013	-1.325
2	MTC	1.186067	-0.169	0.897301	-0.132
3	68°F	1.211947	-1.969	0.898143	-0.236
4	300°F	1.204695	-1.472	0.904724	-1.046
5	SOLB	1.241994	-3.965	0.937659	-4.928
6	Xe	1.223867	-2.773	0.921068	-3.007
7	Rods	0.789700	42.149	0.605476	53.583

16 BP's

Case	Description	0 MWD/MTU		30000 MWD/MTU	
		K-Infinity	% $\Delta\rho$	K-Infinity	% $\Delta\rho$
0	Base	1.020581	--	0.901031	--
1	Doppler	1.030387	-0.932	0.912429	-1.386
2	MTC	1.025619	-0.481	0.903525	-0.306
3	68°F	1.069628	-4.493	0.912266	-1.367
4	300°F	1.053687	-3.079	0.916026	-1.817
5	SOLB	1.060567	-3.694	0.938213	-4.398
6	Xe	1.049333	-2.685	0.926059	-3.000

Table 5.2
(Continued)

Additional Xenon Defect Data

No BP's

	<u>0 MWD/MTU</u>	<u>30,000 MWD/MTU</u>
Xenon Defect (% $\Delta\rho$)	-2.773	-3.007
Xenon Concentration (Atoms/cm ³) ¹	2.1337×10^{15}	1.8623×10^{15}
Xenon Defect (% $\Delta\rho$ /atoms/cm ³) ²	-1.300×10^{-15}	-1.615×10^{-15}

16 BP's

	<u>0 MWD/MTU</u>	<u>30,000 MWD/MTU</u>
Xenon Defect (%)	-2.685	-3.000
Xenon Concentration (atoms/cm ³) ¹	2.1334×10^{15}	2.0056×10^{15}
Xenon Defect (% /atoms/cm ³) ²	-1.259×10^{-15}	1.496×10^{-15}

1. Value averaged over entire assembly volume.
Fuel to Assembly volume ratio = .90459.
2. Defect per unit volume evaluated over entire assembly.

Table 5.3

1. Name of Codes	-	PDQ07; EPRI-CELL ¹
Code Sources		EPRI; EPRI ¹
Version		2; RAM112 ¹
2. Reference for Calculational Method	-	DPC-NF-2010
3. Assembly Solution Method	-	Two Group Diffusion Theory
4. Pin-Cell Solution Method	-	Transport Theory ¹
5. Spatial Mesh Assy/Pin-Cell		
	Assembly	- One mesh interval per pin
	Pin-Cell ¹	- Four Mesh intervals in fuel pin One mesh interval in clad Five mesh intervals in moderator Two mesh intervals in extra region
6. Neutron Cross Section Library	-	ENDF/B4 ¹
7. Number of Fast/Thermal Groups		
		<u>No. Fast Groups</u> <u>No. Thermal Groups</u>
	Assembly	1
	Pin Cell ¹	62
8. Depletion Steps	-	
	Assembly (hrs)	- 0, 150, 500, 1000, 2000, 3000, 4000, 5000, 6000, 8000, 10000, 12000, 14000, 16000, 18000, 20000, 22000, 24000, 26000, 28000, 30000, 32000, 34000, 36000, 38000, 40000
	Pin/Cell(MWD/MTU) ¹	- 0, 0.001, 100, 500, 1000, 2000, 4000, 6000, 8000, 10000, 12000, 14000, 16000, 18000, 20000, 22000, 24000, 26000, 28000, 30000, 32000, 34000, 36000, 38000, 40000

¹ - All cross-section sets for benchmark problem except
CRA and BP were calculated with EPRI-CELL.

Table 5.3 (Continued)

1.	Name of Codes	-	CASMO2E ²	
	Code Sources		STUDSVIK	
	Version		5	
2.	Reference for Calculational Method	-	DPC-NF-2010	
3.	Assembly Solution Method	-	Two Group Diffusion Theory	
4.	Pin-Cell Solution Method	-	Transport Theory ²	
5.	Spatial Mesh Assy/Pin-Cell			
	Assembly	-	One mesh interval per pin ¹	
	Pin-Cell	-	One mesh interval per pin ²	
6.	Neutron Cross Section Library	-	ENDF/B3 ²	
7.	Number of Fast/Thermal Groups			
			No. Fast Groups	No. Thermal Groups
	Assembly		4	3
	Pin-Cell		9	16
8.	Depletion Steps			
	Assembly	-	See Table 5.3 page 1	
	Pin-Cell (MWD/MTU) ²	-	0, 150, 500, 1000, 2000, 3000, 5000, 7500, 10000, 12500, 15000, 20000, 25000, 30000, 35000, 40000	

² - Refers to Burnable Poison and Control Rod Data

Figure A-3. Comparisons of Measured and Predicted Normalized Relative Power Densities for Core 1

INCORE DETECTOR	1.018	1.011	.987	.981	.997	.966	.945
	1.038	.997	.979	.975	.978	.958	.936
	.020	-.014	-.008	-.006	-.019	-.008	-.009
	1.019	1.067	1.012	1.009	1.058	.999	.945
	1.035	1.069	1.015	1.012	1.054	.988	.941
	.016	.002	.003	.003	-.004	-.011	-.004
		WATER	1.081	1.090		1.032	.953
			1.087	1.089	WATER	1.045	.947
			.006	-.001		.013	-.006
			1.054	1.104*	1.086	.989	.945
			1.070	1.117*	1.100	.994	.939
			.016	.013	.014	.005	-.006
				WATER	1.059	.965	.934
					1.062	.957	.928
					.003	-.008	-.006
					.988	.938	.923
					.986	.937	.919
					-.002	-.001	-.004
				Measured RPD	.925	.914	
				Calculated RPD	.921	.911	
				Δ RPD	-.004	-.003	
						.903	
						.903	
						.000	

$RMS(\Delta RPD) = 0.008$

$Max (ABS(\Delta RPD)) = 0.020$

*Maximum power fuel rod predicted or measured.

FIGURE 5.1

Figure A-4. Comparisons of Measured and Predicted Normalized Relative Power Densities for Core 5

INCORE- DETECTOR	1.005	.913	.170	.932	1.036	1.063	1.072
	1.026	.886	.196	.903	1.045	1.077	1.090
	.021	-.027	.026	-.029	.009	.014	.018
	.999	1.017	.931	1.007	1.125	1.094	1.089
	1.021	1.012	.901	.997	1.135	1.112	1.096
	.022	-.005	-.030	-.010	.010	.018	.007
		WATER	.988	1.087		1.158*	1.100
			.962	1.073	WATER	1.174*	1.102
			-.026	-.014		.016	.002
			.181	1.050	1.131	1.088	1.086
			.203	1.035	1.158	1.105	1.090
			.022	-.015	.027	.017	.004
				WATER	1.048	1.035	1.070
					1.018	1.018	1.070
					-.030	-.017	.000
					.187	.963	1.054
					.211	.939	1.058
					.024	-.024	.004
				Measured RPD	1.018	1.060	
				Calculated RPD	1.009	1.069	
				Δ RPD	-.009	.009	
							1.070
							1.083
							.013

UO₂-
Gd₂O₃

$$\text{RMS}(\Delta\text{RPD}) = 0.018$$

$$\text{Max}(\text{ABS}(\Delta\text{RPD})) = 0.030$$

*Maximum power fuel rod predicted or measured.

FIGURE 5.2

PDQ07 CALCULATED
ROD POWERS

0.

1.035

1.038

0.

1.037

1.035

0.

1.012

0.975

1.013

1.013

1.029

1.014

1.011

1.019

0.991

0.971

1.015

1.032

1.018

1.015

1.023

0.993

0.970

0.

1.044

1.043

0.

1.042

1.006

0.972

1.051

1.060

1.060

1.014

0.989

0.964

0.

0.975

0.961

0.942

0.951

PDQ07

0.932

0.942

0.939

0.949

PPMB

NUMBER BA

K-INFINITY

BURNUP

*MAX. ROD POWER

PDQ-7

400

0

1.18377

0

1.060

PPMB	PDQ-7
NUMBER BA	400
K-INFINITY	0
BURNUP	1.18377
*MAX. ROD POWER	0
	1.060

FIGURE 5.3

PDQ-7

400

0

1.17560

500

1.059

FIGURE 5.4

PDQ07 CALCULATED
ROD POWERS

0.								
1.032	1.012							
1.034	1.012	1.014						
0.	1.026	1.029	0.					
1.034	1.013	1.016	1.040	1.047				
1.031	1.010	1.014	1.039	1.054 *	0.	PDQ07		
0.	1.017	1.021	0.	1.038	1.013	.977		
1.011	.992	.993	1.006	.990	.965	.947	.938	
.978	.974	.973	.974	.967	.955	.947	.944	.954

PPMB	PDQ-7
NUMBER BA	400
K-INFINITY	0
BURNUP	1.12604
*MAX. ROD POWER	5000
	1.054

FIGURE 5.5

PDQØ7 CALCULATED
ROD POWERS

PPMB	PDQ-7
NUMBER BA	<u>400</u>
K-INFINITY	<u>0</u>
BURNUP	<u>1.06962</u>
	<u>10,000</u>
*MAX. ROD POWER	<u>1.046</u>

0.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		</
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

PPMB	PDQ-7
NUMBER BA	<u>400</u>
K-INFINITY	<u>0</u>
BURNUP	<u>1.06962</u>
	<u>10,000</u>
*MAX. ROD POWER	<u>1.046</u>

FIGURE 5.6

PDQ07 CALCULATED
ROD POWERS

<div>0.</div>		PPMB		PDQ-7					
		NUMBER BA		400					
		K-INFINITY		0					
		BURNUP		0.97482					
		*MAX. ROD POWER		20,000					
1.019		1.010		1.028					
1.019		1.010		1.011					
0.		1.016		1.018		0.			
1.019		1.010		1.012		1.023		1.026	
1.017		1.008		1.010		1.022		1.028 *	
0.		1.010		1.012		0.		0.	
1.005		.997		.997		1.002		.994	
.988		.986		.986		.986		.981	
								PDQ07	
								.986	
								.980	
								.969	
								.962	
								.967	
								.965	
								.969	

PPMB	PDQ-7
NUMBER BA	400
K-INFINITY	0
BURNUP	0.97482
*MAX. ROD POWER	20,000
	1.028

FIGURE 5.7

PDQ-7

400

0

0.8962430,000

*MAX. ROD POWER 1.014

PDQ07

45

PDQ07 CALCULATED
ROD POWERS

0.											
1.005	1.003										
1.005	1.003	1.004									
0.	1.005	1.005	0.								
1.005	1.004	1.004	1.007	1.008 *							
1.005	1.003	1.004	1.006	1.008 *	0.	PDQ 7					
0.	1.003	1.003	0.	1.005	1.001	.996					
1.001	.999	.999	1.000	.998	.994	.991	.988				
.997	.996	.996	.996	.995	.992	.990	.988	.989			

PPMB

NUMBER BA

K-INFINITY

BURNUP

*MAX. ROD POWER

PDQ-7

400

0

0.83305

40.000

1.008

PPMB	PDQ-7
NUMBER BA	400
K-INFINITY	0
BURNUP	0.83305
*MAX. ROD POWER	40.000
	1.008

FIGURE 5.9

PDQ-7

400

NUMBER BA

16

K-INFINITY

1.02062

BURNUP

0

*MAX. ROD POWER

1.107

PDQ07

47

$$\begin{array}{r} \text{PDQ-7} \\ 400 \\ \hline 16 \\ \hline 1.01969 \\ 500 \\ \hline 1.104 \end{array}$$

PPMB	400
NUMBER BA	16
K-INFINITY	1.01969
BURNUP	500
*MAX. ROD POWER	1.104

0.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																			
----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

48

PDQ-7

0.	PPMB <u>400</u> NUMBER BA <u>16</u> K-INFINITY <u>1.02749</u> BURNUP <u>5.000</u> *MAX. ROD POWER <u>1.073</u>							
1.046	1.023							
0.983	0.997	1.024						
0.	0.987	1.040	0.					
0.984	0.996	1.019	1.027	0.987				
1.052	1.024	0.989	0.963	0.938	0.	PDQ07		
0.	1.045	0.979	0.	0.933	0.941	0.961		
1.073 *	1.038	0.991	0.964	0.964	0.975	0.988	1.005	
1.047	1.035	1.014	1.000	0.998	1.003	1.012	1.025	1.044

49

PDQØ7 CALCULATED
ROD POWERS

0.		PPMB		PDQ-7	
1.036		NUMBER BA		<u>400</u>	
1.007		K-INFINITY		<u>16</u>	
0.		BURNUP		<u>1.02278</u>	
1.007		*MAX. ROD POWER		<u>10.000</u>	
1.038				<u>1.041</u>	
0.					
1.041*					
1.017					
1.017					
1.009					
0.998					
0.990					
0.986					
0.984					
0.986					
0.992					
1.006					

FIGURE 5.13

PDQ07 CALCULATED
ROD POWERS

<div>0.</div>		FPMB		PDQ-7					
		NUMBER BA		400					
		K-INFINITY		16					
		BURNUP		0.97150					
		*MAX. ROD POWER		20,000					
						1.021			
1.020		1.010							
1.018		1.009		1.010					
0.		1.015		0.017		0.			
1.018		1.008		1.010		1.020		1.020	
1.019		1.008		1.007		1.017		1.021*	
								0.	
0.		1.012		1.010		0.		1.012	
								1.000	
1.010		1.000		0.997		1.000		0.991	
								0.978	
0.994		0.991		0.988		0.987		0.982	
								0.976	
								0.973	
								0.973	
								0.979	

PDQØ7

FPMB	PDQ-7
NUMBER BA	400
K-INFINITY	16
BURNUP	0.97150
*MAX. ROD POWER	20,000
	1.021

PDQ07

FIGURE 5.14

PDQ07 CALCULATED
ROD POWERS

<div>0.</div>		<div>PPMB NUMBER BA K-INFINITY BURNUP *MAX. ROD POWER</div>					<div>PDQ-7 400 16 0.90103 30,000 1.016</div>										
		<div>1.011</div>		<div>1.006</div>													
		<div>1.013</div>		<div>1.007</div>		<div>1.006</div>											
		<div>0.</div>		<div>1.011</div>		<div>1.010</div>											
		<div>1.012</div>		<div>1.007</div>		<div>1.012</div>											
<div>1.010</div>		<div>1.005</div>		<div>1.006</div>		<div>1.013</div>		<div>1.016</div>		<div>0.</div>		<div>PDQ07</div>					
<div>0.</div>		<div>1.005</div>		<div>1.007</div>		<div>0.</div>		<div>1.010</div>		<div>1.002</div>		<div>0.991</div>					
<div>1.003</div>		<div>1.000</div>		<div>1.000</div>		<div>1.001</div>		<div>1.000</div>		<div>0.987</div>		<div>0.981</div>		<div>0.978</div>			
<div>0.995</div>		<div>0.993</div>		<div>0.992</div>		<div>0.991</div>		<div>0.988</div>		<div>0.984</div>		<div>0.981</div>		<div>0.980</div>		<div>0.983</div>	

PPMB
 NUMBER BA
 K-INFINITY
 BURNUP
 *MAX. ROD POWER

PDQ-7
400
16
0.90103
30,000
1.016

FIGURE 5.15

PDQØ7 CALCULATED
ROD POWERS

0.									
1.005	1.003								
1.007	1.004	1.004							
0.	1.006	1.005	0.						
1.007	1.004	1.004	1.007	1.008					
1.005	1.003	1.004	1.008	1.010	0.	PDQØ7			
0.	1.003	1.004	0.	1.007	1.002	0.995			
1.001	0.999	0.999	1.001	0.998	0.993	0.989	0.987		
0.996	0.996	0.995	0.995	0.993	0.990	0.988	0.988	0.989	

PPMB

NUMBER BA

K-INFINITY

BURNUP

*MAX. ROD POWER

PDQ-7

400

16

0.84163

40.000

1.010

PPMB
 NUMBER BA
 K-INFINITY
 BURNUP
 *MAX. ROD POWER

PDQ-7
<u>400</u>
<u>16</u>
<u>0.84163</u>
<u>40.000</u>
<u>1.010</u>

FIGURE 5.16

Q.6 Please provide the updates to DPC-NF-2010, if any, that will make it consistent with the methodologies being used by Duke Power.

A.6 The following sections address updates to the methods described in DPC-NF-2010.

1. EPRI-NODE-P Normalization:

In addition to adjusting radial albedoes, small M^2 adjustments are made for various fuel types (usually only fresh fuel) to attain better agreement with PDQ07 radial power calculations. Figures 6.1 and 6.2 show the improvement for assembly radial powers with respect to measurement. Figures 6.3 and 6.4 address assembly peak power improvements. The data in figures 6.1 through 6.4 represent McGuire Unit 1 Cycle 2.

2. Axial Nodal Modeling:

Section 11 of DPC-NF-2010 presents a benchmark analysis which employed twelve axial nodes per assembly. Core-specific axial modeling would conform to the physics requirements of the core. Answer 4 addressed the calculated-to-measured improvement shown by employing eighteen axial nodes per assembly. Should future fuel assemblies become non-uniform, i.e., axial blankets or part length burnable absorbers, the Duke Power version of EPRI-NODE-P can adequately model the core.

Since the upgrades described in parts 1 and 2 have significantly improved calculated-to-measured agreement, the ONRF values for F_Q and $F_{\Delta H}^N$ in DPC-NF-2010 are considered conservative. Therefore, even though the upgraded methods have demonstrated improved agreement, Duke Power will still employ previously derived ONRFs.

3. EPRI-NODE-P Enhancements:

EPRI-NODE-P has received several major enhancements which are discussed below. This enhanced version was used throughout the analyses shown in DPC-NF-2010. These enhancements are:

- a. Partial reactivity formulations due to xenon, moderator temperature, and doppler temperature have been revised to include third order burnup dependent multipliers.
- b. Fuel assemblies can be axially modeled as containing up to three different fuel types.
- c. Rodded M^2 is linearly adjusted according to the fraction of node length occupied by a control rod.

- d. The full power volumetric average fuel temperature has been revised to a burnup dependent fourth order polynomial.
- f. The nodal source convergence routine has been modified to use the Gauss-Seidel iterative method with the inclusion of an optional acceleration parameter.
- g. Minor enhancements have also been made which allow more user-friendly input and output features.

Likewise, Duke Power's fitting code EPRI-SUPERLINK has been modified to provide compatibility with EPRI-NODE-P. All codes are rigorously tested and certified before production usage in conformance with Duke Power's Q/A procedures.

MC GUIRE-1 CYCLE-2 ASSEMBLY RADIAL POWERS - CALC (NO MSQUARE ADJ) VS. MEAS

48 EFDP 100ZFP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .84 *	* .97 *	* 1.15 *	* .88 *	* .88 *	* .73 *	* .91 *	* 1.03 *
	* .83 *	* .94 *	* 1.11 *	* .87 *	* .90 *	* .77 *	* .98 *	* 1.06 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* .79 *	* 1.18 *	* 1.16 *	* .93 *	* .90 *	* .83 *	* 1.25 *	* 1.04 *
	* .97 *	* 1.12 *	* 1.10 *	* .91 *	* .91 *	* .85 *	* 1.26 *	* 1.05 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.16 *	* 1.16 *	* 1.16 *	* 1.20 *	* .92 *	* .86 *	* .93 *	* .96 *
	* 1.13 *	* 1.11 *	* 1.11 *	* 1.16 *	* .91 *	* .89 *	* .99 *	* .97 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* .88 *	* .94 *	* 1.20 *	* 1.16 *	* 1.15 *	* .97 *	* 1.23 *	* .76 *
	* .89 *	* .93 *	* 1.16 *	* 1.11 *	* 1.12 *	* .98 *	* 1.23 *	* .77 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .89 *	* .91 *	* .92 *	* 1.15 *	* 1.23 *	* 1.16 *	* 1.05 *	
	* .91 *	* .92 *	* .91 *	* 1.13 *	* 1.19 *	* 1.19 *	* 1.06 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

13	* .74 *	* .84 *	* .86 *	* .97 *	* 1.16 *	* .79 *	* .65 *	
	* .79 *	* .87 *	* .91 *	* .99 *	* 1.10 *	* .83 *	* .66 *	
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	

14	* .91 *	* 1.25 *	* .93 *	* 1.24 *	* 1.05 *	* .65 *		
	* .93 *	* 1.26 *	* .97 *	* 1.20 *	* 1.05 *	* .67 *		
	* * *	* * *	* * *	* * *	* * *	* * *		

15	* 1.03 *	* 1.05 *	* .96 *	* .76 *	* CALC			
	* 1.06 *	* 1.05 *	* .95 *	* .75 *	* MEAS			
	* * *	* * *	* * *	* * *				

FIGURE 6.1

MC GUIRE-1 CYCLE-2 ASSEMBLY RADIAL POWERS - CALCULATED VS. MEASURED

4B EFPD 100%FP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A
8	.83	.96	1.10	.88	.86	.75	.95	1.03
9	.83	.94	1.11	.87	.90	.77	.98	1.06
10	.98	1.13	1.12	.93	.91	.85	1.24	1.04
11	.97	1.12	1.10	.91	.91	.85	1.26	1.05
12	1.11	1.12	1.13	1.16	.93	.88	.97	.96
13	1.13	1.11	1.11	1.16	.91	.89	.99	.97
14	.88	.94	1.16	1.13	1.13	1.00	1.23	.75
15	.89	.93	1.16	1.11	1.12	.98	1.23	.77
16	.86	.91	.93	1.13	1.22	1.19	1.04	
17	.91	.92	.91	1.13	1.19	1.19	1.06	
18	.76	.86	.88	1.00	1.19	.85	.66	
19	.79	.87	.91	.99	1.20	.83	.66	
20	.96	1.24	.98	1.23	1.05	.66		
21	.98	1.26	.97	1.20	1.05	.67		
22	1.03	1.05	.96	.73	CALCULATED			
23	1.06	1.05	.95	.75	MEASURED			

FIGURE 6.2

MC GUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (NO MSQUARE ADJ) VS. MEAS

48 EFPD 100%FP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .97 *	* 1.11 *	* 1.29 *	* 1.00 *	* 1.00 *	* .81 *	* 1.06 *	* 1.30 *
	* .92 *	* 1.04 *	* 1.23 *	* .97 *	* 1.00 *	* .86 *	* 1.16 *	* 1.25 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.13 *	* 1.32 *	* 1.30 *	* 1.06 *	* 1.02 *	* .93 *	* 1.54 *	* 1.32 *
	* 1.07 *	* 1.24 *	* 1.22 *	* 1.01 *	* 1.01 *	* .97 *	* 1.48 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.30 *	* 1.31 *	* 1.31 *	* 1.33 *	* 1.03 *	* .95 *	* 1.09 *	* 1.20 *
	* 1.25 *	* 1.23 *	* 1.22 *	* 1.27 *	* 1.00 *	* 1.01 *	* 1.17 *	* 1.14 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* 1.01 *	* 1.07 *	* 1.33 *	* 1.28 *	* 1.28 *	* 1.10 *	* 1.53 *	* .94 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.25 *	* 1.12 *	* 1.45 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* 1.01 *	* 1.02 *	* 1.03 *	* 1.28 *	* 1.41 *	* 1.37 *	* 1.30 *	* * *
	* 1.00 *	* 1.02 *	* 1.00 *	* 1.25 *	* 1.34 *	* 1.37 *	* 1.23 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

13	* .82 *	* .93 *	* .95 *	* 1.10 *	* 1.37 *	* .92 *	* .78 *	* * *
	* .87 *	* .97 *	* 1.04 *	* 1.14 *	* 1.39 *	* .96 *	* .76 *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

14	* 1.06 *	* 1.55 *	* 1.10 *	* 1.54 *	* 1.30 *	* .79 *	* * *	* * *
	* 1.11 *	* 1.45 *	* 1.12 *	* 1.39 *	* 1.23 *	* .78 *	* * *	* * *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

15	* 1.30 *	* 1.32 *	* 1.21 *	* .95 *	* CALCULATED			
	* 1.26 *	* 1.25 *	* 1.12 *	* .87 *	* MEASURED			
	* * *	* * *	* * *	* * *				

FIGURE 6.3

MCGUIRE-1 CYCLE-2 ASSEMBLY PEAK AXIAL POWERS - CALC (18 LEVEL) VS. MEAS

48 EFPD 100ZFP CONTROL BANK D AT 228 STEPS WITHDRAWN

	H	G	F	E	D	C	B	A

8	* .96 *	* 1.10 *	* 1.25 *	* 1.00 *	* .98 *	* .84 *	* 1.11 *	* 1.28 *
	* .92 *	* 1.04 *	* 1.23 *	* .97 *	* 1.00 *	* .86 *	* 1.16 *	* 1.25 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

9	* 1.12 *	* 1.28 *	* 1.26 *	* 1.06 *	* 1.03 *	* .95 *	* 1.51 *	* 1.31 *
	* 1.07 *	* 1.24 *	* 1.22 *	* 1.01 *	* 1.01 *	* .97 *	* 1.48 *	* 1.24 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

10	* 1.26 *	* 1.27 *	* 1.27 *	* 1.30 *	* 1.04 *	* .97 *	* 1.14 *	* 1.19 *
	* 1.25 *	* 1.23 *	* 1.22 *	* 1.27 *	* 1.00 *	* 1.01 *	* 1.17 *	* 1.14 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

11	* 1.01 *	* 1.07 *	* 1.30 *	* 1.26 *	* 1.26 *	* 1.14 *	* 1.52 *	* .93 *
	* .99 *	* 1.03 *	* 1.26 *	* 1.22 *	* 1.25 *	* 1.12 *	* 1.45 *	* .90 *
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	* * *

12	* .98 *	* 1.03 *	* 1.04 *	* 1.26 *	* 1.39 *	* 1.40 *	* 1.28 *	*
	* 1.00 *	* 1.02 *	* 1.00 *	* 1.25 *	* 1.34 *	* 1.37 *	* 1.23 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

13	* .84 *	* .95 *	* .97 *	* 1.14 *	* 1.40 *	* .98 *	* .79 *	*
	* .87 *	* .97 *	* 1.04 *	* 1.14 *	* 1.39 *	* .96 *	* .76 *	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

14	* 1.11 *	* 1.52 *	* 1.15 *	* 1.52 *	* 1.28 *	* .80 *	*	*
	* 1.11 *	* 1.45 *	* 1.12 *	* 1.39 *	* 1.23 *	* .78 *	*	*
	* * *	* * *	* * *	* * *	* * *	* * *	* * *	*

15	* 1.29 *	* 1.31 *	* 1.20 *	* .93 *	* CALC			
	* 1.26 *	* 1.25 *	* 1.12 *	* .87 *	* MEAS			
	* * *	* * *	* * *	* * *	* * *			

FIGURE 6.4