

DEMONSTRATIVE AID # 13B

I-MOSBA-240

UNIT 1 A TRAIN DIESEL GENERATOR

DOCKETED
USNRC

AIR RECEIVER DEW POINT MEASUREMENTS

'95 OCT 20 P4:14

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

MWO NO.	DATE	RECEIVER KO1	RECEIVER KO2
190001651	4/8/90	34 F	33 F
	4/7/90	75 F	78 F
	4/7/90	75 F	80 F
	4/6/90	75 F	-----
	4/6/90	80 F	-----
	4/6/90	80 F	70 F
	4/6/90	85 F	85 F
	4/6/90	85 F	85 F
	4/5/90	83 F	85 F
	4/5/90	78 F	77 F
	4/5/90	86 F	67 F
19001513	3/31/90	80 F	60 F
19000899	3/12/90	48 F	45 F
	3/9/90	61 F	66 F
19000465	2/11/90	37 F	37 F
18906445	1/18/90	44 F	44 F
18906199	12/19/89	40 F	37 F
18905007	11/20/89	40 F	47 F
18904442	10/20/89	38 F	45 F
18903652	9/27/89	45 F	45 F
18903214	8/24/89	37 F	35 F
18902798	7/30/89	45 F	49 F
18902453	6/28/89	48 F	KO2 was tagged out for maintenance
18901066	5/18/89	39 F	78 F
18900984	3/16/89	22.6 F	20.1 F
18901008	3/13/89	-----	53.9 F
	3/3/89	-----	70 F
	3/1/89	-----	78 F
18809080	3/1/89	27.3 F	-----
18806224	10/4/88	17.1 F	12.6 F
18802991	5/10/88	43.9 F	-----

IIT requests
data 4/9/90

1 year back

2 years back

9601190323 950913
PDR ADOCK 05000424
G PDR

DATA KEY: Black : On original Exh. #82 given to IIT

Blue: On Exh. #26 (Steele Memo)

Red : Demon. Aid #4

NUCLEAR REGULATORY COMMISSION

Docket No. 50-424/425-OLA-3 EXHIBIT NO. II - 240

In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2

☐ Staff ☐ Applicant ☒ Intervenor ☐ Other

☒ Identified ☐ Received ☐ Rejected Reporter SD

Date 9/13/98 Witness KITCHENS