

I-MOSBA-244

ent. # 244

Quality Control Inspection Report

VOGTLE ELECTRIC GENERATING PLANT

14846

DOCKETED

USNRC

Page 1 of 1

MWO/Surv/Work Doc No.

19502428

System/Tag/Component ID No.

1PI 9053

Drawing/Rev. No.

NA

Work Procedure Rev No.

95 00120 PA 27

Inspection Type

☒ Visual☐ ASME VT-1 Direct☐ ASME VT-1 Remote☐ ASME VT-3☐ ASME VT-4☐ Other

Inspection

VALVE FOR PI COULD NOT ISOLATE
PRESSURE. WHEN ATTEMPTING TO BLEED PRESSURE
AND CAP FITTING A SMALL AMOUNT OF LIQUID
WAS RELEASED AND CAPTURED. UNABLE TO
DETERMINE TOTAL AMOUNT IN LINE DUE TO
INABILITY TO ISOLATE PRESSURE.

Sketch

9601220033 950914
PDR ADOCK 05000424
G PDR

Results

☐ Sat☒ Unsat☐ TBE☐ Info Only

DC/WRT No.

DC.

Inspector

Evaluator

ANII

Date

8-18-95

Level

111

Date

Level

Date

NUCLEAR REGULATORY COMMISSION
Docket No. 50-424/425-OLA-3 EXHIBIT NO. IF-244

In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2

☐ Staff ☐ Applicant ☒ Intervenor ☐ Other

☒ Identified ☐ Received ☐ Rejected ☐ Reporter SP

Date 9/14/95 Witness Ken Stokes

33