

**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

**BILLY R. CLEMENTS**  
VICE PRESIDENT, NUCLEAR OPERATIONS

November 20, 1984  
TXX-4365

Mr. D.R. Hunter, Chief  
Reactor Project Branch 2  
U.S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos.: 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
VENTILATION EXHAUST DAMPERS  
QA FILE: CP-84-27, SDAR-152  
FILE NO.: 10110

Dear Mr. Hunter:

On September 13, 1984 we verbally notified your Mr. D. Hunnicutt of a deficiency regarding ventilation exhaust dampers that have been observed to be designed/installed to fail closed which would divert radioactive releases to rooms in which operator action is required. We have submitted an interim report logged TXX-4333 dated October 12, 1984.

We are continuing our evaluation and anticipate completion by December 21, 1984.

Very truly yours,

*Billy R. Clements*

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8412050287 841120  
PDR ADCK 05000445  
S PDR

IE-2710