



William J. Cahill, Jr.
Chief Nuclear Officer

January 25, 1996
JPN-96-004

United States Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, DC 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Technical Specification Changes
Associated with Emergency Diesel Generators (JPTS-95-007)

REFERENCES:

1. Generic Letter 93-05, "Line-item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation," dated September 27, 1993
2. NUREG-1433, "Standard Technical Specifications, General Electric Plants, BWR 4," Rev. 1, dated April 1995

Dear Sir:

This application for amendment to James A. FitzPatrick (JAF) Nuclear Power Plant Technical Specifications proposes to revise the Allowed Out-of-Service Times for single inoperable Emergency Diesel Generators (EDGs) to accommodate on-line maintenance of the EDGs. In addition, two line item changes are proposed: 1) to improve safety by reducing EDG testing at power (Reference 1); and 2) to revise the AC power requirements during cold shutdown or refueling modes to make the JAF Technical Specifications consistent with the Standard Technical Specifications (Reference 2).

The signed original of the Application for Amendment to Operating License is enclosed for filing. Attachments I and III to this application contain the proposed changes to the Technical Specifications and a mark-up of the current Technical Specifications pages, respectively. Attachment II contains the associated Safety Evaluation for the proposed changes.


There are no commitments contained in this amendment application.

Handwritten signature: Aool
1/1

A copy of this application and the associated attachments are being provided to the designated New York State official in accordance with 10 CFR 50.91.

Should you have any questions regarding this request, please contact Ms. C. D. Faison.

Very truly yours,



William J. Cahill Jr.
Chief Nuclear Officer

att: as stated

cc: U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. C. E. Carpenter, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Mr. F. William Valentio, President
New York State Energy, Research and Development Authority
2 Rockefeller Plaza
Albany, NY 12223-1253