

February 12, 1985
(NMP2L 0341)

Mr. R. W. Starostecki, Director
U. S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point - Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

In our letter of June 29, 1984, we submitted a final report in accordance with 10CFR50.55(e) on a problem concerning the High Pressure Core Spray Diesel Generator Control Panel Wiring. The problem was identified in panel #2CES*IPNL413. We would like to amend that report to include similar problems with panel #2CES*IPNL414. Both panels have been repaired.

Very truly yours,

C. V. Mangan

C. V. Mangan
Vice President
Nuclear Engineering and Licensing

CVM/GG:csb
(0726H)

xc: Director of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555

R. A. Gramm, NRC Resident Inspector
Project File (2)