

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station										DOCKET NUMBER (2) 0 5 0 0 0 3 1 7 3				PAGE (3) 1 OF 2		
TITLE (4) Unsecured High Radiation Area Door																
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)						
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)			
0 2	2 0	8 5	8 5	0 2 1	0 0	0 3	0 8	8 5					0 5 0 0 0			
OPERATING MODE (9)		THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 8: (Check one or more of the following) (11)														
1		20.402(b)				20.406(a)				80.73(a)(2)(iv)				73.71(b)		
POWER LEVEL (10)		20.406(a)(1)(i)				80.38(a)(1)				80.73(a)(2)(v)				73.71(e)		
0 9 8		20.406(a)(1)(ii)				80.38(a)(2)				80.73(a)(2)(vi)				OTHER (Specify in Abstract below and in Text, NRC Form 365A)		
		20.406(a)(1)(iii)				80.73(a)(2)(i)				80.73(a)(2)(vii)(A)						
		20.406(a)(1)(iv)				80.73(a)(2)(ii)				80.73(a)(2)(vii)(B)						
		20.406(a)(1)(v)				80.73(a)(2)(iii)				80.73(a)(2)(ix)						
LICENSEE CONTACT FOR THIS LER (12)																
NAME L. R. Aldrich, extension 238										TELEPHONE NUMBER AREA CODE 8 1 5 3 5 1 7 1 - 1 6 1 7 6 1 1						
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPDOS						
A	Z	Z	9 9 9	Z	9 9 9	N										
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)												<input checked="" type="checkbox"/> NO				
ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)																
<p>At 1155 on 2/20/85, while performing a radiological survey of the solid radwaste pump room in the 663 elevation of the Turbine Building, a Radiation Chemistry Technician (RCT) found the gate which secures that high radiation area unsecured and unattended. This is contrary to Technical Specification 6.1.1. The RCT closed the gate and secured the area with the chain and lock. Contractor individuals that were authorized at 0845 on 2/20/85 to work in the area left the high radiation area gate propped open and unattended when exiting the area for the lunch break. No unauthorized radiation exposure occurred during the period in question. The individuals involved were counseled as to their responsibilities for ensuring that high radiation areas remain secured at all times. In addition, the co-workers of the specific contractor were made aware of their responsibilities for ensuring that high radiation areas remain secured at all times during a February 22, 1985 safety meeting.</p>																

8504020445 850308  
PDR ADOCK 05000373  
S PDRIE22  
1/

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

APPROVED OMB NO. 3150-0104  
EXPIRES: 8/31/85

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (5)			PAGE (3)		
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER			
LaSalle County Station Unit 1	0 5 0 0 0 3 7 3	8 5	— 0 2 1	— 0 0	0 2	OF	0 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

I. EVENT DESCRIPTION

At 1155 on February 20, 1985, while performing a radiological survey of the Solid Radwaste (WB) Pump Room in the 663 elevation of the Turbine Building (NM) a Radiation Chemistry Technician (RCT) found the gate which secures that high radiation area unsecured and unattended. This is contrary to Technical Specification 6.1.1. At the time of this event Unit 1 was in Mode 1 at 98% power.

II. CAUSE

Individuals authorized to work in the high radiation area left the area unsecured and unattended. They were authorized to enter the area at 0845 on February 20, 1985.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

Review of the dosimetry data for the period in question indicates that no unauthorized radiation exposure greater than 50 millirem occurred.

IV. CORRECTIVE ACTION

Upon finding the gate open, an RCT closed the gate and secured the area with the chain and lock. The individuals involved were counseled as to their responsibilities for ensuring that high radiation areas remain secured at all times. In addition, the co-workers of the specific contractor were made aware of their responsibilities for ensuring that high radiation areas remain secured at all times during a February 22, 1985, safety meeting.

V. PREVIOUS OCCURRENCES

There have been seven occurrences of a similar nature and they were reported as follows:

LER 373/84-034  
LER 374/84-022  
LER 374/84-038  
LER 374/84-070  
LER 373/85-004  
LER 373/85-016  
LER 373/85-020

VI. NAME AND TELEPHONE NUMBER OF PREPARER

L. R. Aldrich, 815/357-6761, extension 238.



**Commonwealth Edison**  
LaSalle County Nuclear Station  
Rural Route #1, Box 220  
Marseilles, Illinois 61341  
Telephone 815/357-6761

March 8, 1985

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #85-021-00, Docket #050-373 is being submitted to your office in accordance with 10CFR 50.73.

*CE Sargent*

*for* G. J. Diederich  
Superintendent  
LaSalle County Station

GJD/MLD/kg

Enclosure

xc: NRC, Regional Director  
INPO-Records Center  
File/NRC

*IE22*  
*11*