

March 29, 1985

54-397

Mr. J. M. Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: 10CFR 21 Report

Reference: Harlan H. Leusink's Letter, dated March 6, 1985,
Subject: 10CFR 21

Dear Mr. Taylor:

In the referenced letter, Mr. Leusink reported a series of cracked welds discovered in some generators manufactured by Louis Allis for Long Island Lighting Company, Shoreham Nuclear Plant. The welds occurred in the conical baffle section of the coil guards. Corrective action with respect to the Shoreham Plant is being implemented. However, in the referenced letter, Louis Allis recommended that an additional four units be inspected for similar problems. After some additional reflection, we believe it would be prudent to inspect all sixteen additional units built with the same configuration. While there is no basis for serious concern, the ease of inspection would make a full review seem appropriate and will remove any shadow of doubt. With that in mind, therefore, the following units should be inspected:

	<u>BPS Job No.</u>	
2 units	700508	Union Electric Co. St. Louis, Mo. Callaway #1
2 units	700508	Kansas Gas & Electric Co Kansas City P&L Co. Wolf Creek
4 units	700509	Washington Public Power Supply System WNP No. 3

8504030263 850329
PDR ADOCK 05000322
S PDR

IE19
1/0



10CFR 21 Report

March 29, 1985

4 Units	700510	Public Service Electric & Gas Co. Newark, N.J. Hope Creek #1
4 Units	700512	Public Service of Indiana Marble Hill Plant

The Louis Allis contact for all inspection and corrective action will be:

Mr. H. A. Schreiber
Manager Customer Service
Louis Allis Division
MagneTek, Inc.
427 E. Stewart St.
P.O. Box 2020
Milwaukee, WI 53201-2020
Telephone (414) 481-6000 X289

Sincerely,

Louis Allis Division
MagneTek, Inc.

J. G. Borman
Quality Control Manager

Attachment

cc: Louis Allis
Mr. E. Klessig
Mr. H. Leusink
Mr. C. Corey
Mr. D. Gaylord
Mr. H. Schreiber



March 29, 1985

cc: General Manager - Nuclear Quality Assurance
Public Service Electric & Gas Co.
P.O. Box 236
Hancocks Bridge, NJ 08038

Project Manager - Hope Creek
Bechtel Construction, Inc.
P.O. Box 3956
San Francisco, CA 94119

Project Manager - Nuclear Quality Assurance
Washington Public Power System
P.O. Box 968
Richland, WA 99352

Ebasco Services, Inc.
Quality Assurance Engineering Department
19 Rector Street
New York, NY 10006
Attn: Project Quality Assurance Engineer for WNP-3/5

Quality Engineering Manager
Public Service of Indiana
Marble Hill Nuclear Division
P.O. Box 190
New Washington, IN 47162

Sargent & Lundy Engineers
55 East Monroe Street
Chicago, IL 60603
Attn: P.L. Wallelet, Marble Hill Project Manager

Kansas Gas and Electric Co.
P.O. Box 208
Wichita, KS 67201
Attn: Quality Assurance Manager



10CFR 21 Report

March 29, 1985

cc: Project Manager
Snupps Project, Bechtel Job 10466
15740 Shady Grove Road
Gaithersburg, MD 20877

Union Electric Co.
P.O. Box 149
St. Louis, MO 63166
Attn: Quality Assurance Manager

J. M. Moriarty
Fairbanks Morse
Engine Division
701 Lawton Avenue
Beloit, WI 53511-5492