



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

November 7, 1984

Mr. James G. Keppler
Regional Administrator
U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

SUBJECT: Braidwood Station Units 1 and 2
Response to Inspection Reports Nos.
50-456/84-09 and 50-457/84-09
NRC Docket Nos. 50-456 and 50-457

REFERENCE:

- (a) R. F. Warnick letter to Cordell Reed
dated July 2, 1984
- (b) D. L. Farrar letter to J. G. Keppler
dated July 31, 1984
- (c) R. F. Warnick letter to Cordell Reed
dated August 15, 1984
- (d) D. L. Farrar letter to J. G. Keppler
dated October 22, 1984

Dear Mr. Keppler:

This letter provides additional clarification to our Reference (d) letter relative to NRC's understanding of our Reference (b) response in the area of hot linewalk inspections. We would like to confirm to the NRC that the hot linewalk inspections referred to in our Reference (d) response is Commonwealth Edison's Commitment to walk down all hot lines (greater than 180°F). These inspections are to assure that sufficient clearance exists to allow flexibility and movement of hot lines without binding or interference.

Should you or your staff have any questions regarding this matter please contact this office.

Very truly yours,

for D. L. Farrar
Director of Nuclear Licensing

8412060426 841130
PDR ADOCK 05000456
Q PDR

cc: NRC Resident Inspector - Braidwood

0194W

NOV 8 1984