

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4502

NOV 30 1984

JOHN S. KEMPER
VICE-PRESIDENT
ENGINEERING AND RESEARCH

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Docket No. 50-352

SUBJECT: Limerick Generating Station, Unit 1
Primary Reactor Containment Integrated Leakage Rate Test
Final Report

FILE: EQUIP 3-1-6 (Leak Testing)

Dear Mr. Denton:

Enclosed please find 3 copies of the Limerick Generating Station Unit No. 1 preoperational Primary Reactor Containment Integrated Leakage Rate Test final report. The subject test was conducted during August 1984, in accordance with the requirements of 10CFR50, Appendix J. The overall containment leakage rate was found to be less than the Appendix J acceptance criteria of 0.375 wt.%/day.

Please do not hesitate to contact us if you desire further discussion or clarification of any aspect of this report.

Very truly yours,

John S. Kemper

WJM/cmv/11168402

Enclosure

Copy to: Dr. Thomas E. Murley, Administrator
Office of Inspection & Enforcement
(with 3 copies of Enclosure)

S. K. Chaudhary, Site Inspector

Service List (Attached)

FS001
1/3
Amended
Best

8412070125 841130
PDR ADDCK 05000352
P PDR

cc: Judge Helen F. Hoyt	(w/o enclosure)
Judge Jerry Harbour	(w/o enclosure)
Judge Richard F. Cole	(w/o enclosure)
Judge Christine N. Kohl	(w/o enclosure)
Judge Gary J. Edles	(w/o enclosure)
Judge Reginald L. Gotchy	(w/o enclosure)
Troy B. Conner, Jr., Esq.	(w/o enclosure)
Ann P. Hodgdon, Esq.	(w/o enclosure)
Mr. Frank R. Romano	(w/o enclosure)
Mr. Robert L. Anthony	(w/o enclosure)
Ms. Phyllis Zitzer	(w/o enclosure)
Charles W. Elliot, Esq.	(w/o enclosure)
Zori G. Feekin, Esq.	(w/o enclosure)
Mr. Thomas Gerusky	(w/o enclosure)
Director, Penna. Emergency Management Agency	(w/o enclosure)
Angus R. Love, Esq.	(w/o enclosure)
David Wersan, Esq.	(w/o enclosure)
Robert J. Sugarman, Esq.	(w/o enclosure)
Martha W. Bush, Esq.	(w/o enclosure)
Spence W. Perry, Esq.	(w/o enclosure)
Jay M. Gutierrez, Esq.	(w/o enclosure)
Atomic Safety & Licensing Appeal Board	(w/o enclosure)
Atomic Safety & Licensing Board Panel	(w/o enclosure)
Docket & Service Section	(w/3 copies of enclosure)
Mr. James Wiggins	(w/o enclosure)
Mr. Timothy R. S. Campbell	(w/o enclosure)