

**Transamerica  
Delaval**



Transamerica Delaval Inc.  
Engine and Compressor Division  
550 85th Avenue  
P.O. Box 2161  
Oakland, California 94621  
(415) 577-7400

*Zeck - should  
this be backdated?  
Does anyone get a copy  
BG 2/9/85*

March 14, 1985

Director, Office of Inspection & Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Sir:

Please refer to my letter of March 12, 1985 which described a potential problem with a Check Valve in accordance with 10CFR21.

I would like to correct a statement I made in the last sentence of the third paragraph. Grand gulf did not perform an LPI inspection of the Valve Disk. The 2 which I stated were ok were visually examined only.

In the fourth paragraph I stated the Valves were supplied by the Williams Gauge Co. (Williams-Hager) of Pittsburgh. The Williams Gauge Co. was purchased by the Cloy Corporations of Oskaloosa, Iowa and the nameplates of the Valves will show Cloy Corporations as well as Williams-Hager.

We will send copies of this letter to all the Sites listed in paragraph 2 of the March 12, 1985 letter as indicated in the cc's.

Very truly yours,

*REB:mu*

R. E. Boyer  
Manager, Quality Assurance

REB:hw

RECEIVED  
1985 MAR 18 PM 1:28  
MEDICAL ADMIN.

8504080049 850314  
PDR ADDCK 05000416  
S PDR

*IE:09  
4-5-85  
10*