


*Docket IF 105*



**Florida  
Power**  
CORPORATION

# **CRYSTAL RIVER UNIT 3**

## **EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT**

**7-1-83**

**12-31-83**

8504100321 831231  
PDR ADDCK 05000302  
R PDR

*IE2501*

EFFLUENT AND WASTE DISPOSAL

SEMIANNUAL REPORT

7/1/83 - 12/31/83

FLORIDA POWER CORPORATION

CRYSTAL RIVER - UNIT 3

FACILITY OPERATING LICENSE NO. DPR-72

DOCKET NO. 50-302

FEBRUARY, 1984

Approved by:

Paul J. McGuire

Nuclear Plant Manager

Date:

2/28/84

Approved by:

R. E. Fuller

Manager, Site Nuclear Services

Date:

2/28/84

## TABLE OF CONTENTS

	<u>PAGE</u>
I Introduction	1
II Releases of and Doses from Gaseous Effluents	4
III Releases of and Doses from Liquid Effluents	18
IV Solid Waste Shipments	29
V Meteorological Data	31

## LIST OF TABLES

		<u>PAGE</u>
I-1A	Summation of Doses to Individuals from Gaseous and Liquid Effluent Releases - Third and Fourth Quarters	2
I-1B	Summation of Doses to Population from Gaseous and Liquid Effluent Releases - Third and Fourth Quarters	3
II-1	Gaseous Effluents - Summation of All Releases	12
II-2	Gaseous Effluents - Ground Level Releases	13
II-3	Doses to Individuals from Continuous Gaseous Effluent Releases - Third and Fourth Quarters	14
II-4	Doses to Individuals from Batch Gaseous Effluent Releases - Third and Fourth quarters	15
II-5	Doses to the Population from Continuous Gaseous Effluent Releases - Third and Fourth Quarters	16
II-6	Doses to the Population from Batch Gaseous Effluent Releases - Third and Fourth Quarters	17
III-1	Liquid Effluents - Summation of All Releases	24
III-2	Summation of Nuclides in Liquid Effluent Releases	25
III-3	Doses to Individuals from Liquid Effluent Releases - Third and Fourth Quarters	27
III-4	Doses to the Population from Liquid Effluent Releases - Third and Fourth Quarters	28
IV-1	Summation of Solid Waste Irradiated Fuel Shipments	30
V-1	Summation of Meteorological Conditions	32
V-2	Summation of Meteorological Conditions	39
V-3	Summation of Meteorological Conditions	46
V-4	Summation of Meteorological Conditions	53

## I. INTRODUCTION

This Effluent and Waste Disposal Report is submitted as required by Technical Specification 5.6.1.B of Appendix B to the Crystal River Unit 3 Facility Operating License No. DPR-72. The data in this report covers the period from July 1 to December 31, 1983.

There have been no changes to the Technical Specification Requirements for effluents and waste disposal in Appendix B, Section 2.0, of the Facility Operating License during the period of this report.

Crystal River Unit 3 has had no significant measurable radiological impact on the surrounding environment during the reporting period. This is based on the Radiological Environmental Monitoring Program data and the doses calculated for individuals and the population due to effluent releases being significantly below the levels required by 10 CFR 50, Appendix I.

The summations of gaseous and liquid effluents, solid waste shipments and meteorological data are in accordance with the tables in Regulatory Guide 1.21 (Rev. 1, 6/74) Appendix B.

The individual and population doses were calculated using GASPAR (for gaseous effluents) and LADTAP (for liquid effluents) computer codes obtained from the Nuclear Regulatory Commission and revised to include site specific data wherever possible. These doses are summarized in Tables I-1A and B.

The values reported for the activity of nuclides released are the actual measured activities. If no activity for a nuclide was detected for a quarter, the total of the lower limits of detection for all samples is reported as "<X.XXE-X". The totals of activity released is a total of only the nuclides that had measured activity.

TABLE I-1A  
SUMMATION OF DOSES TO INDIVIDUALS FROM  
GASEOUS AND LIQUID EFFLUENT RELEASES

Beta Air Dose =  $1.17\text{E}-03$   
Gamma Air Dose =  $2.59\text{E}-05$

Third Quarter  
(Design Objective =  $2.00\text{E}+01$  mrad/yr)  
(Design Objective =  $1.00\text{E}+01$  mrad/yr)

Whole Body Dose

<u>Effluent Release</u>	<u>Distance (Mi.) and Direction</u>	<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem/yr)</u>	<u>Design Objectives (mrem/yr)</u>
Continuous Gaseous	4.00 East	Child	-	$2.82\text{E}-05$	$5.00\text{E}+00$
Batch Gaseous	4.00 East	Adult	-	$4.18\text{E}-04$	
Continuous Liquid	-	Teen	-	$3.81\text{E}-04$	$5.00\text{E}+00$
Batch Liquid	-	Teen	-	$3.50\text{E}-03$	

Organ Dose

Continuous Gaseous	4.00 East	Child	Skin	$8.36\text{E}-04$	$1.50\text{E}+01$
Batch Gaseous	4.00 East	Each	Thyroid	$4.18\text{E}-02$	
Continuous Liquid	-	Adult	GI-LLI	$1.51\text{E}-03$	$5.00\text{E}+00$
Batch Liquid	-	Adult	GI-LLI	$4.48\text{E}-02$	

Beta Air Dose =  $4.78\text{E}-04$   
Gamma Air Dose =  $1.42\text{E}-04$

Fourth Quarter  
(Design Objective =  $2.00\text{E}+0$  mrad/yr)  
(Design Objective =  $1.00\text{E}+01$  mrad/yr)

Whole Body Dose

Continuous Gaseous	4.00 East	Child	-	$1.01\text{E}-04$	$5.00\text{E}+00$
Batch Gaseous	4.00 East	Each	-	0.00*	
Continuous Liquid	-	Adult	-	$4.50\text{E}-04$	$5.00\text{E}+00$
Batch Liquid	-	Teen	-	$1.77\text{E}-03$	

Organ Dose

Continuous Gaseous	4.00 East	Child	Skin	$3.60\text{E}-04$	$1.50\text{E}+01$
Batch Gaseous	4.00 East	Each	-	0.00*	
Continuous Liquid	-	Adult	GI-LLI	$5.72\text{E}-04$	$5.00\text{E}+00$
Batch Liquid	-	Adult	GI-LLI	$3.05\text{E}-02$	

\* Fourth Quarter Batch Individual Gaseous release doses are 0.00 due to few releases and no occurrences in the special location direction.

TABLE I-1B

SUMMATION OF DOSES TO THE POPULATION  
FROM GASEOUS AND LIQUID EFFLUENT RELEASES

Third Quarter

<u>Effluent Release</u>	<u>Whole Body Dose</u>		<u>Organ</u>	<u>Organ Dose</u>	
	<u>Dose</u> (MAN-REM/YR)	<u>Design Objectives</u> (MAN-REM/YR)		<u>Dose</u> (MAN-REM/YR)	<u>Design Objectives</u> (MAN-REM/YR)
Continuous Gases	9.00E-04	5.00E+02	Skin	6.38E-02	5.00E+02
Batch Gaseous	2.17E-02		Thyroid	1.24E-01	
Continuous Liquid	2.85E-02	-	GI-LLI	1.61E-01	-
Batch Liquid	1.98E-01	-	GI-LLI	5.24E+00	-

Fourth Quarter

Continuous Gaseous	2.99E-03	5.00E+02	Skin	1.47E-02	5.00E+02
Batch Gaseous	1.85E-04		Thyroid	2.10E-03	
Continuous Liquid	5.70E-02	-	GI-LLI	6.96E-02	-
Batch Liquid	1.57E-01	-	GI-LLI	3.54E+00	-

## II. RELEASES OF AND DOSES FROM GASEOUS EFFLUENTS

There are three normal methods of releasing gaseous effluents to the atmosphere: 1) continuous release via the Auxiliary Building Exhaust; 2) batch release from the Waste Gas Decay Tanks; and 3) batch and continuous releases from the Reactor Building purge. All three methods release to the atmosphere from one point, the Plant Vent.

### 1. Regulatory Limits

The Technical Specification limits for gaseous effluent releases are as follows:

#### Specification 2.4.2

The terms used in these Specifications are as follows:

subscripts v, refers to vent releases

i, refers to individual noble gas nuclide

(Refer to Table 2.4-5 for the noble gas nuclides considered)

$Q_T$  = the total noble gas release rate (Ci/sec)

=  $\sum_i Q_i$  sum of the individual noble gas radionuclides determined to be present by isotopic analysis

$\bar{K}$  = the average total body dose factor due to gamma emission (rem/yr per Ci/sec)

$\bar{L}$  = the average skin dose factor due to beta emissions (rem/yr per Ci/sec)

$\bar{M}$  = the average air dose factor due to beta emissions (rad/yr per Ci/sec)

$\bar{N}$  = the average air dose factor due to gamma emissions (rad/yr per Ci/sec)

The values of  $\bar{K}$ ,  $\bar{L}$ ,  $\bar{M}$  and  $\bar{N}$  are to be determined each time isotopic analysis is required as delineated in Specification 2.4.2.J. Determine the following using the results of the noble gas radionuclide analysis:

$$\bar{K} = (1/Q_T) \sum_i Q_i K_i$$

$$\bar{L} = (1/Q_T) \sum_i Q_i L_i$$

$$\bar{M} = (1/Q_T) \sum_i Q_i M_i$$

$$\bar{N} = (1/Q_T) \sum_i Q_i N_i$$

where the values of  $K_i$ ,  $L_i$ ,  $M_i$  and  $N_i$  are provided in Table 2.4-5 and are site dependent gamma and beta dose factors.

Table 2.4-5

GAMMA AND BETA DOSE FACTORS FOR CRYSTAL RIVER UNIT 3

$x/Q = 1.46 \times 10^6 \text{ sec/m}^3$  at 1450 meters, ENE

Noble Gas Radionuclide	Dose Factors for Vent			
	$K_{iv}$	$L_{iv}$	$M_{iv}$	$N_{iv}$
	Total Body $\frac{\text{rem/yr}}{\text{Ci/sec}}$	Skin $\frac{\text{rem/yr}}{\text{Ci/sec}}$	Beta Air $\frac{\text{rad/yr}}{\text{Ci/sec}}$	Gamma Air $\frac{\text{rad/yr}}{\text{Ci/sec}}$
Kr-83m	$7.0 \times 10^{-5}$	0	0.92	0.035
Kr-85m	0.80	2.1	2.9	0.84
Kr-85	0.0096	2.0	2.8	0.010
Kr-87	2.5	14	15	2.6
Kr-88	6.1	3.5	4.3	6.4
Kr-89	2.79	15	15	0.83
Xe-131m	2.28	0.69	1.6	0.35
Xe-133m	0.22	1.5	2.2	0.29
Xe-133	0.26	0.55	1.5	0.31
Xe-135m	1.2	1.0	1.1	1.1
Xe-135	1.2	2.7	3.6	1.3
Xe-137	0.12	18	19	0.12
Xe-138	2.4	6.0	6.9	2.5

Q = The measured release rate of the radioiodines and radioactive materials in particulate forms with half-lives greater than eight days. (Ci/sec)

- A. (1) The release rate limit of noble gases from the site shall be such that

$$2.0 (Q_{TV} \bar{K}_V) \leq 1$$

and

$$0.33 (Q_{TV} (\bar{L}_V + 1.1 \bar{N}_V)) \leq 1$$

- (2) The release rate limit of all radioniodines and radioactive materials in particulate form with half-lives greater than eight days, released to the environs as part of the gaseous wastes from the site shall be such that

$$3.5 \times 10^4 Q_V \leq 1$$

- B. (1) The average release rate of noble gases from the site during any calendar quarter shall be such that

$$13 (Q_{TV} \bar{N}_V) \leq 1$$

and

$$6.3 (Q_{TV} \bar{M}_V) \leq 1$$

- (2) The average release rate of noble gases from the site during any 12 consecutive months shall be

$$25 (Q_{TV} \bar{N}_V) \leq 1$$

$$13 (Q_{TV} \bar{M}_V) \leq 1$$

- (3) The average release rate per site of all radioiodines and radioactive materials in particulate form with half-lives greater than eight days during any calendar quarter shall be such that

$$13 (3.5 \times 10^4 Q_V) \leq 1$$

- (4) The average release rate per site of all radioiodines and radioactive materials in particulate form with half-lives greater than eight days during any period of 12 consecutive months shall be that

$$25 (3.5 \times 10^4 Q_V) \leq 1$$

- (5) The amount of iodine-131 released during any calendar quarter shall not exceed 2 Ci/reactor.
  - (6) The amount of iodine-131 released during any period of 12 consecutive months shall not exceed 4 Ci/reactor.
- C. Should any of the conditions of 2.4.2.C(1), (2) or (3) listed below exist, the licensee shall make an investigation to identify the causes of the release rates, define and initiate a program of action to reduce the release rates to design objective levels listed in Section 2.4, and report these actions to the NRC within 30 days from the end of the quarter during which the releases occurred.
- (1) If the average release rate of noble gases from the site during any calendar quarter is such that
 
$$50 (Q_{TV} \bar{N}_V) > 1$$
 or
 
$$25 (Q_{TV} \bar{M}_V) > 1$$
  - (2) If the average release rate per site of all radioiodines and radioactive materials in particulate form with half-lives greater than eight days during any calendar quarter is such that
 
$$50 (3.5 \times 10^4 Q_V) > 1$$
  - (3) If the amount of iodine-131 released during any calendar quarter is greater than 0.5 Ci/reactor.
- D. During the release of gaseous wastes from the primary system waste gas holdup system the effluent monitor for the Waste Gas Storage Tanks shall be operated and set to alarm and to initiate the automatic closure of the waste gas discharge valve prior to exceeding the limits specified in 2.4.2.A above. The operability of each automatic isolation valve listed in Table 2.4-4 shall be demonstrated quarterly.
- E. The maximum activity to be contained in one waste gas storage tank shall not exceed 47,000 Curies (considered as Xe-133).

## 2. Maximum Permissible Concentrations

The maximum permissible concentrations of nuclides in gaseous releases is based on the resultant doses at the site boundary as determined from the concentrations of nuclides at the release point. The Technical Specifications provide the equations and dose factors that relate the gaseous activity to be released to doses at the site boundary and restrictions are placed on instantaneous, quarterly and yearly release rates. The gaseous releases do not exceed the concentration limits specified in 10 CFR 20 and are as low as reasonably achievable in accordance with the requirements of 10 CFR 50.

## 3. Measurements and Approximations of Total Radioactivity

The gaseous effluent release via the Auxiliary Building Exhaust is treated as a continuous release subdivided into discrete periods of filter changes and the radioactivity measured as follows:

- A. Fission and Activation Gases - The total activity released is determined from the net count rate of the gaseous monitor (RMA-2G), its calibration factor, and the total exhaust flow. The activity of radiogas is determined by the isotopic distribution of radiogas in the analysis of the Auxiliary Building vent for that period.
- B. Iodines - The activity released as Iodine-131, 133, and 135 is based on the charcoal cartridge activities (RMA-2I), the particulate filters activities (RMA-2P) and the total vent flow.
- C. Particulates - The activity released via particulates with half-lives greater than eight days is determined by isotopic analysis of particulate filters (RMA-2P) and the total vent flow.
- D. Tritium - The activity released as tritium is based on monthly grab sample analysis and total vent flow.

The radioactivity released by batch releases of the Waste Gas Decay Tanks via the Auxiliary Building Exhaust is measured as follows:

- A. Fission and Activation Gases - The activity released is based on the volume released and the activity of the individual nuclides obtained from an isotopic analysis of a grab sample taken prior to the release.
- B. Iodines - The iodines from batch releases are included in the iodine determination from the continuous Auxiliary Building releases.
- C. Particulates - The particulates from batch releases are included in the particulate determination from the continuous Auxiliary Building release.
- D. Tritium - The activity released as tritium is based on a grab sample analysis of each batch and the batch volume.

The radioactivity released by purge releases of the Reactor Building through the Reactor Building vent is measured as follows:

- A. Fission and Activation Gases - The activity released is determined from the net count rate of the gaseous monitor (RMA-1G), the monitor calibration factor and the total vent flow. The release of each radiogas is a product of the total curies released times the fraction of that radiogas in the isotopic analysis for that purge.
- B. Iodines - The total curies released as iodine-131, 133 and 135 was determined from the charcoal cartridge activities (RMA-1I) and the particulate filter activities (RMA-1P).
- C. Particulate - The total curies released via particulates with half-lives greater than eight days is determined by isotopic analysis of each purge particulate filter (RMA-1P).
- D. Tritium - The total curies released as tritium is based on grab samples taken for each purge (or the average if more than one grab sample was taken).

Estimated errors are based on errors in counting equipment calibration, counting statistics, vent flow rates, vent sample flow rates, nonsteady release rates, chemical yield factors and sample losses for such items as charcoal cartridges.

- A. Fission and Activation Gas Total Release as calculated from process monitor readings and grab sample isotopics.

Monitor Statistical Error	30%
Monitor Error in Calibration	50%
Vent Flow Rate	10%
Non-Steady Release Rate	20%
	<u>110%</u>

- B. I-131 Total Release as calculated from charcoal and particulate filter activity.

Statistical Error	60%
Counting Equipment Calibration	10%
Vent Flow Rate	10%
Vent Sample Flow Rate	10%
Non-Steady Release Rate	10%
Losses from Charcoal Cartridge	10%
	<u>110%</u>

- C. Particulates with half-lives greater than eight days release as calculated from particulate filter activities.

Statistical Error	60%
Counting Equipment Calibration	10%
Vent Flow Rate	10%
Vent Sample Flow Rate	10%
Non-Steady Release Rate	10%
	<u>100%</u>

- D. Total Tritium release as calculated from periodic grab sample analyses.

Water Vapor in Sample Stream	
Determination	20%
Vent Flow Rate	10%
Counting Calibration and Statistics	10%
Non-Steady Release Rate	50%
	<u>90%</u>

#### 4. Batch and Unplanned Releases

The batch gaseous effluent releases may be summarized as follows:

	Third Quarter	Fourth Quarter
Number of Batch Releases	8.00E+00	3.00E+00
Total time for all releases (minutes)	2.83E+03	1.31E+03
Maximum time for any one release (minutes)	1.44E+03	7.85E+02
Average time for all releases (minutes)	3.53E+02	3.28E+02
Minimum time for any one release (minutes)	5.00E+00	1.00E+00
Number of Unplanned Releases	4.00E+00	2.00E+00
Total Unplanned Activity Released (Curies)	1.19E-02	1.86E-03

The summation of gaseous effluent releases is in Table II-1 and the summation of nuclides in gaseous effluent ground level releases is in Table II-2.

The unplanned releases for the third and fourth quarters of 1983 are listed below giving the date, the Nonconforming Operations Report Number, and the cause of each release.

<u>Date</u>	<u>NCOR #</u>	<u>Description</u>
7-26-83	83-216	Possible unmonitored release from the steam relief valves during a plant trip.
8-5-83	83-224	Possible unmonitored release from the steam relief valves during a plant trip.
8-22-83	83-237	Possible unmonitored release from the steam relief valves during a plant trip.
8-26-83	83-242	Possible unmonitored release from the steam relief valves during a plant trip.
10-20-83	83-289	Possible unmonitored release from the steam relief valves during a plant trip.
11-12-83	83-324	Possible unmonitored release from the steam relief valves during a plant trip.

TABLE II-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 7/1/83 - 12/31/83

## GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est.Total Error %
--	------	--------------	--------------	----------------------

## A. Fission and Activation Gases

1. Total Release	Ci	9.55E+02	3.61E+02	1.10E+02
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	1.22E+02	4.71E+01	
3. Percent of Technical Specification Limit	%	2.19E-01	5.67E-02	

## B. Iodines

1. Total Iodine - 131	Ci	6.35E-04	8.78E-05	1.01E+02
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	8.16E-05	1.12E-05	
3. Percent of Technical Specification Limit	%	3.17E-02	4.39E-03	

## C. Particulates

1. Particulates with half-lives > 8 days	Ci	5.86E-04	1.12E-04	1.00E+02
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	7.53E-05	1.42E-05	
3. Percent of Technical Specification Limit	%	3.43E-03	6.46E-04	
4. Gross Alpha Radioactivity	Ci	1.61E-07	7.67E-08	

## D. Tritium

1. Total Release	Ci	3.29E+00	2.03E+00	9.00E+01
2. Average Release Rate for Period	$\mu\text{Ci/sec}$	4.23E-01	2.42E-01	
3. Percent of Technical Specification Limit	%	N/A	N/A	

TABLE II-2

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT - 7/1/83 - 12/31/83

## GASEOUS EFFLUENTS - GROUND-LEVEL RELEASES

CONTINUOUS MODE

BATCH MODE

Nuclides Released	Unit	Quarter 3	Quarter 4	Quarter 3	Quarter 4
-------------------	------	-----------	-----------	-----------	-----------

## 1. Fission gases

krypton-85	Ci	9.14E+02	7.05E+01	<5.05E-01	2.10E+00
krypton-85m	Ci	<3.05E+01	<3.54E+01	<8.92E-03	<1.04E-02
krypton-87	Ci	<8.17E+00	<1.43E+01	<2.50E-03	<1.51E-03
krypton-88	Ci	<1.45E+01	2.24E-01	<5.21E-03	<3.36E-03
krypton-89	Ci	<2.05E+04	<2.52E+04	<5.41E+00	<3.27E+00
xenon-133	Ci	1.34E+01	1.99E+02	2.01E+01	6.12E+01
xenon-135	Ci	2.31E-01	2.35E+01	1.54E-01	9.78E-02
xenon-135m	Ci	2.06E+00	<2.98E+01	<6.71E-03	<1.41E-03
xenon-137	Ci	5.27E+00	<5.03E+03	<7.78E-01	<5.10E-01
xenon-138	Ci	<8.07E+01	<1.11E+02	<2.54E-02	<1.02E-02
argon-41	Ci	<6.26E+00	<1.04E+01	<1.88E-03	<8.52E-04
xenon-133m	Ci	2.47E-01	4.80E-01	2.26E-01	5.37E-01
xenon-131m	Ci	<1.61E+02	<2.12E+02	1.21E-01	2.86E+00
unidentified	Ci				
Total for Period	Ci	9.35E+02	2.94E+02	2.06E+01	6.69E+01

## Iodines

iodine-131	Ci	4.07E-06	1.16E-05	6.31E-04	7.61E-05
iodine-133	Ci	<6.70E-05	<8.46E-05	3.42E-04	3.31E-04
iodine-135	Ci	<1.24E-01	<1.64E-01	<4.55E-01	<1.02E-02
Total for Period	Ci	4.07E-06	1.16E-05	9.73E-04	4.08E-04

## 3. Particulates

strontium-89	Ci	<9.46E-06	<6.60E-07	<6.62E-07	<3.71E-09
strontium-90	Ci	<1.22E-05	<2.59E-06	<8.59E-07	<4.23E-09
cesium-134	Ci	<1.70E-06	<1.29E-06	6.16E-05	1.06E-05
cesium-137	Ci	6.70E-07	<1.81E-06	1.87E-04	3.14E-05
barium-lanthanum 140	Ci	<3.10E-06	<2.23E-06	<7.90E-06	<1.32E-06
cobalt-57	Ci	<3.86E-07	<1.79E-07	<2.37E-06	<3.74E-07
cobalt-58	Ci	1.24E-06	3.53E-08	3.09E-06	<8.35E-07
cobalt-60	Ci	<3.37E-06	1.65E-07	<6.61E-06	<1.65E-06
chromium-51	Ci	<9.73E-06	<6.68E-06	<5.09E-05	<1.02E-05
manganese-54	Ci	<1.53E-06	<1.21E-06	<4.80E-06	<6.35E-07
iron-59	Ci	<4.50E-06	<3.67E-06	<1.50E-05	<2.10E-06
zinc-65	Ci	<3.68E-06	<3.00E-06	<1.07E-05	<1.83E-06
niobium-95	Ci	<1.60E-06	2.04E-07	<4.75E-06	<1.15E-06
zirconium-95	Ci	<2.80E-06	<2.11E-06	<9.57E-06	<1.41E-06
silver-110m	Ci	<2.29E-06	<2.15E-06	<8.42E-06	<1.13E-06
antimony-126	Ci	<1.61E-06	<1.24E-06	<4.02E-06	<8.78E-07
cerium-141	Ci	2.17E-08	4.80E-08	<5.42E-06	<9.26E-07
iodine-131	Ci	<1.30E-06	<1.09E-06	<3.32E-04	6.92E-05
Total	Ci	1.93E-06	4.52E-07	5.84E-04	1.13E-04

TABLE II-3  
Doses to Individuals from Continuous Gaseous Effluent Releases

THIRD QUARTER

Beta Air Dose =  $1.16\text{E-}03$  mrad/yr (4.0 miles, E)  
Gamma Air Dose =  $2.23\text{E-}05$  mrad/yr (4.0 miles, E)

Pathway	Whole Body Dose			Organ Dose			
	Distance (Mi.) and Direction	Age Group	Dose (mrem/yr)	Distance (Mi.) and Direction	Age Group	Organ	Dose (mrem/yr)
Plume Immersion	4.00 at E	Each	$1.44\text{E-}05$	4.00 at E	Each	Skin	$8.22\text{E-}04$
Ground Contamination	4.00 at E	Each	$7.32\text{E-}08$	4.00 at E	Each	Skin	$8.55\text{E-}08$
Inhalation	4.00 at E	Teen	$2.60\text{E-}06$	4.00 at E	Teen	Thyroid	$2.63\text{E-}06$
Vegetable Consumption	4.00 at E	Child	$5.05\text{E-}06$	4.00 at E	Child	Thyroid	$5.98\text{E-}06$
Cow Milk Consumption	4.00 at E	Infant	$3.04\text{E-}06$	4.00 at E	Infant	Thyroid	$2.24\text{E-}05$
Goat Milk Consumption	4.00 at E	Infant	$6.19\text{E-}06$	4.00 at E	Infant	Thyroid	$2.94\text{E-}05$
Meat Consumption	4.00 at E	Adult	$4.12\text{E-}07$	4.00 at E	Adult	Thyroid	$5.00\text{E-}07$
Total	4.00 at E	Child	$2.82\text{E-}05$	4.00 at E	Child	Skin	$8.36\text{E-}04$

FOURTH QUARTER

Beta Air Dose =  $4.78\text{E-}04$  mrad/yr (4.0 miles, E)  
Gamma Air Dose =  $1.42\text{E-}04$  mrad/yr (4.0 miles, E)

Pathway	Whole Body Dose			Organ Dose			
	Distance (Mi.) and Direction	Age Group	Dose (mrem/yr)	Distance (Mi.) and Direction	Age Group	Organ	Dose (mrem/yr)
Plume Immersion	4.00 at E	Each	$8.72\text{E-}05$	4.00 at E	Each	Skin	$3.46\text{E-}04$
Ground Contamination	4.00 at E	Each	$1.13\text{E-}09$	4.00 at E	Each	Skin	$1.36\text{E-}09$
Inhalation	4.00 at E	Teen	$2.70\text{E-}06$	4.00 at E	Teen	Thyroid	$2.88\text{E-}06$
Vegetable Consumption	4.00 at E	Child	$5.23\text{E-}06$	4.00 at E	Child	Thyroid	$7.95\text{E-}06$
Cow Milk Consumption	4.00 at E	Infant	$3.18\text{E-}06$	4.00 at E	Infant	Thyroid	$5.85\text{E-}05$
Goat Milk Consumption	4.00 at E	Infant	$6.42\text{E-}06$	4.00 at E	Infant	Thyroid	$7.28\text{E-}05$
Meat Consumption	4.00 at E	Adult	$4.24\text{E-}07$	4.00 at E	Adult	Thyroid	$6.88\text{E-}07$
Total	4.00 at E	Child	$1.01\text{E-}04$	4.00 at E	Child	Skin	$3.60\text{E-}04$

TABLE II-4  
Doses to Individuals from Batch Gaseous Effluent Releases

THIRD QUARTER

Beta Air Dose =  $1.07\text{E-}05$  mrad/yr (4.0 miles, E)

Gamma Air Dose =  $3.64\text{E-}06$  mrad/yr (4.0 miles, E)

Pathway	Whole Body Dose			Organ Dose			
	Distance (Mi.) and Direction	Age Group	Dose (mrem/yr)	Distance (Mi.) and Direction	Age Group	Organ	Dose (mrem/yr)
Plume Immersion	4.00 at E	Each	$2.13\text{E-}06$	4.00 at E	Each	Skin	$6.09\text{E-}06$
Ground Contamination	4.00 at E	Each	$9.63\text{E-}05$	4.00 at E	Each	Skin	$1.12\text{E-}04$
Inhalation	4.00 at E	Adult	$5.94\text{E-}08$	4.00 at E	Child	Thyroid	$7.36\text{E-}06$
Vegetable Consumption	4.00 at E	Adult	$6.90\text{E-}05$	4.00 at E	Child	Thyroid	$9.34\text{E-}04$
Cow Milk Consumption	4.00 at E	Adult	$6.29\text{E-}05$	4.00 at E	Infant	Thyroid	$1.89\text{E-}02$
Goat Milk Consumption	4.00 at E	Adult	$1.81\text{E-}04$	4.00 at E	Infant	Thyroid	$2.27\text{E-}02$
Meat Consumption	4.00 at E	Adult	$7.04\text{E-}06$	4.00 at E	Child	Thyroid	$9.86\text{E-}05$
Total	4.00 at E	Adult	$4.18\text{E-}04$	4.00 at E	Each	Thyroid	$4.18\text{E-}02$

FOURTH QUARTER\*

Beta Air Dose =  $0.00$  mrad/yr (4.0 miles, E)

Gamma Air Dose =  $0.00$  mrad/yr (4.0 miles, E)

Pathway	Whole Body Dose			Organ Dose			
	Distance (Mi.) and Direction	Age Group	Dose (mrem/yr)	Distance (Mi.) and Direction	Age Group	Organ	Dose (mrem/yr)
Plume Immersion	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Ground Contamination	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Inhalation	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Vegetable Consumption	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Cow Milk Consumption	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Goat Milk Consumption	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Meat Consumption	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00
Total	4.00 at E	Each	0.00	4.00 at E	Each	Each	0.00

\* Fourth Quarter Batch Individual Gaseous release doses are 0 due to having few releases during the quarter and no occurrences in the special location direction.

TABLE II-5

Doses to the Population from Continuous Gaseous Effluent Releases

THIRD QUARTER

<u>Pathway</u>	<u>Whole Body Dose (Man-Rem)</u>	<u>Organ</u>	<u>Organ Dose (Man-Rem)</u>
Plume Immersion	4.90E-04	Skin	6.34E-02
Ground Contamination	3.24E-06	Skin	3.78E-06
Inhalation	2.06E-04	Thyroid	2.08E-04
Vegetable Consumption	1.53E-04	Thyroid	1.80E-04
Milk Consumption	2.03E-05	Thyroid	7.04E-05
Meat Consumption	2.80E-05	Thyroid	3.05E-05
Total	9.00E-04	Skin	6.38E-02

FOURTH QUARTER

<u>Pathway</u>	<u>Whole Body Dose (Man-Rem)</u>	<u>Organ</u>	<u>Organ Dose (Man-Rem)</u>
Plume Immersion	2.73E-03	Skin	1.44E-02
Ground Contamination	4.16E-06	Skin	4.90E-06
Inhalation	1.23E-04	Thyroid	1.30E-04
Vegetable Consumption	1.03E-04	Thyroid	2.07E-04
Milk Consumption	1.46E-05	Thyroid	4.37E-04
Meat Consumption	1.86E-05	Thyroid	3.40E-05
Total	2.99E-03	Skin	1.47E-02

TABLE II-6

Doses to the Population from Batch Gaseous Effluent Releases

THIRD QUARTER

<u>Pathway</u>	<u>Whole Body Dose (Man-Rem)</u>	<u>Organ</u>	<u>Organ Dose (Man-Rem)</u>
Plume Immersion	1.31E-02	Skin	4.53E-02
Ground Contamination	6.13E-03	Skin	7.16E-03
Inhalation	2.54E-05	Thyroid	5.91E-04
Vegetable Consumption	8.54E-04	Thyroid	2.74E-02
Milk Consumption	1.38E-03	Thyroid	7.41E-02
Meat Consumption	2.27E-04	Thyroid	3.10E-03
Total	2.17E-02	Thyroid	1.24E-01

FOURTH QUARTER

<u>Pathway</u>	<u>Whole Body Dose (Man-Rem)</u>	<u>Organ</u>	<u>Organ Dose (Man-Rem)</u>
Plume Immersion	1.11E-05	Skin	4.32E-05
Ground Contamination	1.30E-04	Skin	1.52E-04
Inhalation	1.07E-07	Thyroid	3.11E-06
Vegetable Consumption	4.03E-06	Thyroid	1.23E-04
Milk Consumption	3.57E-05	Thyroid	1.79E-03
Meat Consumption	3.39E-06	Thyroid	4.77E-05
Total	1.85E-04	Thyroid	2.10E-03

### III. RELEASES OF AND DOSES FROM LIQUID EFFLUENTS

There are three sources of liquid effluents released to the discharge canal: 1) the Laundry and Shower Sump Tanks, 2) the Evaporator Condensate Storage Tanks and 3) the Regeneration Waste Neutralization Tank. The Laundry and Evaporator Condensate are batch type releases made through the plant liquid release monitor RML-2. The Regeneration Waste Tank discharges are continuous type releases made through the plant liquid release monitor RML-7.

#### 1. Regulatory Limits

The Technical Specification limits for liquid effluent releases are as follows:

##### Specification 2.4.1

- A. The instantaneous concentration of radioactive materials released in liquid waste effluents from all reactors at the site shall not exceed the values specified in 10 CFR Part 20, Appendix B, Table II, Column 2, for unrestricted areas.
- B. The cumulative release of radioactive materials in liquid waste effluents excluding tritium and dissolved gases, shall not exceed 10 Ci/reactor/calendar quarter.
- C. The cumulative release of radioactive materials in liquid waste effluents excluding tritium and dissolved gases, shall not exceed 20 Ci/reactor in any 12 consecutive months.
- D. During release of radioactive wastes, the effluent control monitor shall be set to alarm and to initiate the automatic closure of each waste isolation valve prior to exceeding the limits specified in 2.4.1.A above.
- E. The operability of each automatic isolation valve in the liquid radwaste discharge lines shall be demonstrated quarterly.
- F. The equipment installed in the liquid radioactive waste system shall be maintained and shall be operated to process radioactive liquid wastes prior to their discharge when the projected cumulative release could exceed 1.25 Ci/reactor/calendar quarter, excluding tritium and dissolved gases.
- G. The maximum radioactivity to be contained in any liquid radwaste tank that can be discharged directly to the environs shall not exceed 10 Ci, excluding tritium and dissolved gases.
- H. If the cumulative release of radioactive materials in liquid effluents, excluding tritium and dissolved gases, exceeds 2.5 Ci/reactor/calendar quarter, the licensee shall make an investigation to identify the causes for such releases, define and

initiate a program of action to reduce such releases to the design objective levels listed in Section 2.4, and a report of these actions shall be made to the USNRC in accordance with Section 5.6.2.C(1).

## 2. Maximum Permissible Concentrations

The maximum permissible concentration values used in determining allowable liquid radwaste release concentrations are taken from 10 CFR Part 20, Appendix B, Table II, Column 2. Release rate and dilution ratio for each batch are determined by a mixed nuclide MPC calculation performed before the release of the batch. To facilitate the measurements and calculations, the nuclides of Column 2 which can be produced in a fission reactor have been grouped according to MPC value and type of radiation as shown in Figure III-1.

The concentration of each of the 23 gamma emitting nuclides specifically noted in Figure III-1 is measured individually because of interest in that nuclide. For any of the 23 nuclides not detected in the gamma scan, the MDA Limit is computed from the measured data for that sample.

Only two pure beta emitters, Sr-89 and Sr-90, have MPC values less than  $9 \times 10^{-6}$   $\mu\text{Ci/ml}$ . Individual measurements are made on proportional composite liquid radwaste samples to determine the Sr-89 and Sr-90 concentration or MDA value to be applied to individual batch release calculations.

Although the MPC limit for tritium is greater than  $9 \times 10^{-6}$   $\mu\text{Ci/ml}$ , a separate measurement is made for tritium. A distillation and liquid scintillation counting technique is used to measure tritium concentration.

The measured and calculated concentration values for each batch are used to calculate the dilution ratio, release rate, and dilution rate prior to release of each batch. Both the concentration and release data are stored on a computer disc file. The disc file data is used to assure that quarterly and annual release limits are not exceeded. Bases used for the data of Table III-1 are as follows:

- A. Fission and activation products - The total release values (not including tritium, gases, alpha) are comprised of the sum of the individual radionuclide activities in each batch released to the discharge canal for the respective quarter. These values represent the activity known to be present in the liquid radwaste effluent. Percent of applicable limit is determined from a mixed nuclide MPC calculation. The average concentration for each nuclide summed over all batches is divided by the corresponding individual MPC value. The sum over all nuclides of the C/MPC ratios times 100 is the percent of applicable limit for effluent releases during the quarter.
- B. Tritium - The measured tritium concentration in a composite sample is used to calculate the total release and average diluted concentration during each period. Average diluted concentration divided by the MPC

limit,  $3 \times 10^{-3}$   $\mu\text{Ci/ml}$ , is converted to percent to give the percent of applicable limit.

- C. Dissolved and entrained gases - Concentrations of dissolved and entrained gases in liquid effluents are measured by Ge(Li) spectroscopy on a sample from each liquid radwaste batch. Dissolved and entrained gases for which measured or MDA concentrations are determined include noble gases with half lives greater than 8 hours: Xe-135, Xe-133m, Xe-133, and Kr-85. Iodine radionuclides in any form are determined during the isotopic analysis for each batch, therefore a separate analysis for possible gaseous forms is not performed because it would not provide additional information.

A conservative release limit, the maximum sensitivity limit of  $4 \times 10^{-5}$   $\mu\text{Ci/ml}$  of each dissolved and entrained gaseous radionuclide as specified in Table Note 5, Table 2.4-1, Environmental Technical Specifications, has been applied in determining the percent of applicable limit.

### 3. Measurements and Approximations of Total Radioactivity

Details of the analytical procedures for liquid radwaste analysis are as follows:

	<u>Measurement</u>	<u>Frequency</u>	<u>Method</u>
1.	Gamma Isotopic	Each Batch	Ge(Li) spectrometry with on-line computer
2.	Gross Beta	Each Batch	Liquid scintillation
3.	Sr-89	Monthly Composite	Chemical separation and gas flow proportional counting
4.	Sr-90	Monthly Composite	Chemical separation and gas flow proportional counting
5.	Tritium	Monthly Composite	Distillation and liquid scintillation counting
6.	Alpha	Monthly Composite	Gas flow proportional counting
7.	Dissolved Gases	Each Batch	Ge(Li) spectrometry with on-line computer

Estimated errors are based on errors in counting equipment calibration, counting statistics, nonsteady release flow rate, chemical yield factors, sampling and mixing losses, and volume determinations.

- A. Fission and Activation Products Total Release as calculated for each batch.

Statistical Error at MDA	60%
Waste Volume	10%
Counting Equipment Calibration	10%
Sampling and Mixing	20%
	<u>100%</u>

B. Total Tritium Release as calculated from a monthly composite.

Waste Volume	10%
Counting Equipment Calibration	10%
Sampling and Mixing	20%
	<u>40%</u>

C. Dissolved and Entrained Gases Total Release as calculated from one batch per month.

Statistical Error at MDA	60%
Waste Volume	10%
Counting Equipment Calibration	10%
Sampling and Mixing	20%
	<u>100%</u>

D. Total Gross Alpha Radioactivity Release as calculated from a monthly composite.

Statistical Error at MDA	60%
Waste Volume	10%
Counting Equipment Calibration	10%
Sampling and Mixing	20%
	<u>100%</u>

4. Batch and Unplanned Releases

The batch liquid effluent releases may be summarized as follows:

	<u>Third Quarter</u>	<u>Fourth Quarter</u>
Number of Batch Releases	9.10+E01	1.55E+02
Total Time for all Releases (minutes)	7.28E+03	9.34E+03
Maximum Time for any one Release (minutes)	2.20E+02	2.10E+02
Average Time for all Releases (minutes)	8.00E+01	6.00E+01
Minimum time for any one Release (minutes)	1.00E+01	3.00E+00
Average dilution flow of Units 1, 2, and 3 during all Releases (liters/minutes)	1.20E+08	1.31E+08
Number of Unplanned Releases	0.00E+00	0.00E+00
Total Unplanned Activity Releases (Curie)	0.00E+00	0.00E+00

The summation of liquid effluent releases is in Table III-1 and the summation of nuclides in liquid effluent releases is in Table III-2. These releases are based on the dilution of the radioactive liquid effluent by the condenser cooling and nuclear services water of Unit 3.

The doses to individuals from liquid effluent releases are in Table III-3 and the doses to the population from liquid effluent releases are in Table III-4. These doses are based on the dilution of the radioactive liquid effluents by the condenser cooling water of Units 1, 2, and 3.

There were no unplanned releases for the third and fourth quarters of 1983.

Figure III-1

## METHODS OF MEETING 10 CFR 20, APPENDIX B, TABLE II, COLUMN 2 MPC LIMITS

MPC RANGE ( $\mu\text{Ci/ml}$ )	GAMMA-RAY EMITTERS	BETA EMITTERS	ALPHA EMITTERS
< $9 \times 10^{-6}$	<u>I-131, I-132, I-133</u>	Sr-89, Sr-90	
	<u>I-135, Cs-134</u>	(Separation and Gas Flow Counting)	
	(Ge(Li) Gamma-Ray Spectroscopy)		All (Gas Flow Counting Sensitivity $10^{-7} \mu\text{Ci/ml}$ as Pu-239)
> $9 \times 10^{-6}$	<u>Ba-La-140, Na-24, Cu-64</u>	<u>Tritium</u>	
	<u>Co-60, Fe-59, Zn-65</u>	(Distillation and Liquid Scintillation Counting $10^{-5} \mu\text{Ci/ml}$ )	
	<u>Ag-110m, Mn-54, Co-58</u>		
	<u>Zr-Nb-95, Cs-Ba-137</u>		
	<u>As-76, F-18, Cr-51</u>	<u>All others</u>	
	<u>Np-239, Ce-141</u>	(Liquid Scintillation Counting $10^{-5} \mu\text{Ci/ml}$ as Cs-137)	
	<u>Mo-Tc-99, Ce-Pr-144</u>		
	(Ge(Li) Gamma-Ray Spectroscopy)		

TABLE III-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 7/1/83 - 12/31/83  
LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	Unit	Quarter 3	Quarter 4	Est.Total Error %
A. Fission and Activation Products				
1. Total Release (not including tritium, gases, alpha)	Ci	4.14E-02	1.68E-02	1.00E+02
2. Average diluted concentration during period	μCi/ml	5.60E-08	2.73E-08	
3. Percent of applicable limit	%	9.20E-01	2.43E-01	
B. Tritium				
1. Total Release, Batch Mode	Ci	4.85E+01	8.20E+01	4.00E+01
2. Average diluted concentration during period	μCi/ml	6.57E-05	1.33E-04	
3. Percent of applicable limit	%	2.19E+00	4.45E+00	
4. Total release, Continuous Mode	Ci	1.53E-01	3.92E-02	4.00E+01
C. Dissolved and entrained gases				
1. Total release	Ci	1.02E-01	1.30E+00	1.00E+02
2. Average diluted concentration during period, Batch Mode	μCi/ml	1.38E-07	2.12E-06	
3. Percent of applicable limit, Batch Mode	%	3.45E-01	5.30E+00	
D. Gross alpha radioactivity				
1. Total release	Ci	3.02E-04	8.95E-06	1.00E+02
E. Volume of Waste released (prior to dilution)				
1. Batch and Continuous Modes	liters	2.81E+07	1.67E+07	1.00E+01
F. Volume of dilution water used during period				
1. Batch and Continuous Modes	liters	7.11E+08	5.98E+08	1.00E+01

TABLE III-2

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 7/1/83 - 12/31/83

## LIQUID EFFLUENTS

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
strontium-89	Ci	<4.55E-05	<2.82E-05	7.91E-05	8.30E-05
strontium-90	Ci	<4.73E-05	7.70E-05	2.96E-05	1.71E-05
cesium-134	Ci	1.57E-04	3.32E-06	1.68E-03	1.01E-03
cesium-137	Ci	1.23E-03	7.73E-06	1.90E-03	1.48E-03
iodine-131	Ci	<4.64E-04	4.30E-06	7.33E-04	1.59E-04
cobalt-58	Ci	6.13E-04	4.29E-05	9.31E-03	4.81E-03
cobalt-60	Ci	8.34E-04	1.72E-04	1.07E-02	3.72E-03
iron-59	Ci	<1.11E-03	<5.92E-04	6.47E-06	3.26E-04
zinc-65	Ci	<9.10E-04	<4.24E-04	<2.68E-04	3.12E-06
manganese-54	Ci	<4.43E-04	8.43E-06	5.43E-04	2.57E-04
chromium-51	Ci	4.92E-05	5.00E-05	<1.18E-03	9.12E-06
zirconium-niobium-95	Ci	4.43E-05	3.81E-06	2.03E-06	2.98E-04
molybdenum-99	Ci	<3.52E-03	<1.39E-03	<9.19E-04	1.52E-05
technetium-99m	Ci	<3.74E-04	<1.58E-04	1.42E-04	<1.39E-04
barium-lanthanum-140	Ci	<1.42E-03	<6.19E-04	9.59E-04	5.11E-04
cerium-141	Ci	<6.99E-04	<3.22E-04	<2.46E-04	9.68E-07
antimony-126	Ci			3.12E-06	2.34E-06
sodium-24	Ci	<5.21E-04	<2.64E-04	<7.05E-05	1.56E-06
copper-64	Ci	<1.03E-01	<5.40E-02	9.80E-04	3.13E-05
iodine-135	Ci	<1.63E-03	<8.08E-04	4.76E-06	2.22E-06
silver-110m	Ci	<6.24E-04	<2.99E-04	2.86E-03	2.17E-03
iodine-132	Ci	<5.05E-04	<2.42E-04	<1.07E-04	9.33E-07
arsenic-76	Ci	<8.32E-04	<3.91E-04	<2.82E-04	<2.28E-04
iodine-133	Ci	6.14E-06	3.75E-06	1.14E-04	1.66E-05
neptunium-239	Ci	<2.62E-03	<1.09E-03	<7.95E-04	8.27E-06
cerium-144	Ci	<2.94E-03	<1.30E-03	7.22E-05	9.35E-04
zirconium-niobium-97	Ci			7.96E-07	3.32E-07
cesium-136	Ci			1.01E-04	1.20E-05
cobalt-57	Ci			2.94E-05	2.63E-06
tungsten-187	Ci	2.54E-05			4.80E-05
ruthenium-103	Ci	1.27E-05	1.70E-06		
antimony-125	Ci	3.23E-05		7.35E-03	4.10E-04
antimony-124	Ci			3.62E-04	5.15E-05
unidentified	Ci	. E	. E	. E	. E
Total for period (above)	Ci	3.01E-03	3.75E-04	3.84E-02	1.64E-02

TABLE III-2 (Continued)

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 7/1/83 - 12/31/83

## LIQUID EFFLUENTS

Dissolved & Entrained Gases	Unit	CONTINUOUS MODE		BATCH MODE	
		Quarter 3	Quarter 4	Quarter 3	Quarter 4
xenon-133	Ci	2.47E-05	7.39E-04	7.80E-02	1.26E+00
xenon-135	Ci	2.41E-05	8.99E-05	1.07E-02	2.98E-02
xenon 133m	Ci	<3.51E-03	<1.54E-03	2.98E-03	1.50E-02
krypton-85	Ci	<1.49E-01	<6.08E-02	1.04E-02	<3.82E-02
krypton-85m	Ci	<4.35E-04	<1.98E-04	<1.31E-04	7.92E-05
xenon-131m	Ci	<1.81E-02	<7.94E-03	<6.30E-03	9.34E-05

TABLE III-3

## Doses to Individuals from Liquid Effluent Releases

THIRD QUARTER - CONTINUOUS RELEASES

Pathway	Whole Body Dose		Organ Dose		
	Age Group	Dose (mrem/yr)	Age Group	Organ	Dose (mrem/yr)
Fish	Adult	1.67E-04	Adult	GI-LLI	1.11E-03
Invertebrates	Adult	6.33E-05	Adult	GI-LLI	3.58E-04
Shoreline Use	Teen	2.29E-04	Teen	Skin	2.68E-04
Total	Teen	3.81E-04	Adult	GI-LLI	1.51E-03

FOURTH QUARTER - CONTINUOUS RELEASES

Pathway	Whole Body Dose		Organ Dose		
	Age Group	Dose (mrem/yr)	Age Group	Organ	Dose (mrem/yr)
Fish	Adult	3.36E-04	Adult	GI-LLI	4.27E-04
Invertebrates	Adult	1.09E-04	Adult	GI-LLI	1.41E-04
Shoreline Use	Teen	2.57E-05	Teen	Skin	3.02E-05
Total	Adult	4.50E-04	Adult	GI-LLI	5.72E-04

THIRD QUARTER - BATCH RELEASES

Pathway	Whole Body Dose		Organ Dose		
	Age Group	Dose (mrem/yr)	Age Group	Organ	Dose (mrem/yr)
Fish	Adult	9.88E-04	Adult	GI-LLI	3.40E-02
Invertebrates	Adult	7.11E-04	Teen	GI-LLI	7.33E-03
Shoreline Use	Teen	2.15E-03	Teen	Skin	2.53E-03
Total	Teen	3.50E-03	Adult	GI-LLI	4.48E-02

FOURTH QUARTER - BATCH RELEASES

Pathway	Whole Body Dose		Organ Dose		
	Age Group	Dose (mrem/yr)	Age Group	Organ	Dose (mrem/yr)
Fish	Adult	8.62E-04	Adult	GI-LLI	2.25E-02
Invertebrates	Adult	5.41E-04	Adult	GI-LLI	7.81E-03
Shoreline Use	Teen	7.62E-04	Teen	Skin	8.94E-04
Total	Teen	1.77E-03	Adult	GI-LLI	3.05E-02

TABLE III-4  
Doses to the Population from Liquid Effluent Releases

THIRD QUARTER - CONTINUOUS RELEASES			
Pathway	Whole Body Dose (Man-Rem)	Organ	Organ Dose Dose (Man-Rem)
Sport Fish	2.44E-02	GI-LLI	1.45E-01
Commercial Fish	2.51E-05	GI-LLI	1.42E-04
Sport Invertebrate	2.99E-03	GI-LLI	1.43E-02
Commercial Invertebrate	2.15E-05	GI-LLI	1.03E-04
Shoreline Use	1.02E-03	Skin	1.20E-03
Swimming	3.35E-06	Thyroid	3.35E-06
Boating	3.35E-06	Thyroid	3.35E-06
Total	2.85E-02	GI-LLI	1.61E-01

FOURTH QUARTER - CONTINUOUS RELEASES			
Pathway	Whole Body Dose (Man-Rem)	Organ	Organ Dose Dose (Man-Rem)
Sport Fish	5.19E-02	GI-LLI	6.35E-02
Commercial Fish	5.35E-05	GI-LLI	6.48E-05
Sport Invertebrate	4.87E-03	GI-LLI	5.89E-03
Commercial Invertebrate	3.51E-05	GI-LLI	4.24E-05
Shoreline Use	1.15E-04	Skin	1.35E-04
Swimming	4.27E-07	Thyroid	4.27E-07
Boating	4.27E-07	Thyroid	4.27E-07
Total	5.70E-02	GI-LLI	6.96E-02

THIRD QUARTER - BATCH RELEASES			
Pathway	Whole Body Dose (Man-Rem)	Organ	Organ Dose Dose (Man-Rem)
Sport Fish	1.53E-01	GI-LLI	4.83E+00
Commercial Fish	1.57E-04	GI-LLI	4.87E-03
Sport Invertebrate	3.50E-02	GI-LLI	4.07E-01
Commercial Invertebrate	2.51E-04	GI-LLI	2.91E-03
Shoreline Use	9.65E-03	Skin	1.13E-02
Swimming	5.19E-05	Thyroid	5.19E-05
Boating	5.19E-05	Thyroid	5.19E-05
Total	1.98E-01	GI-LLI	5.24E+00

FOURTH QUARTER - BATCH RELEASES			
Pathway	Whole Body Dose (Man-Rem)	Organ	Organ Dose Dose (Man-Rem)
Sport Fish	1.29E-01	GI-LLI	3.22E+00
Commercial Fish	1.32E-04	GI-LLI	3.25E-03
Sport Invertebrate	2.39E-02	GI-LLI	3.12E-01
Commercial Invertebrate	1.69E-04	GI-LLI	2.21E-03
Shoreline Use	3.41E-03	Skin	4.01E-03
Swimming	2.09E-05	Thyroid	2.09E-05
Boating	2.09E-05	Thyroid	2.09E-05
Total	1.57E-01	GI-LLI	3.54E+00

#### IV. SOLID WASTE SHIPMENTS

Solid waste shipments from the plant may include irradiated fuel, solidified liquid waste and compressed solid waste.

##### 1. Regulatory Limits

The Technical Specifications for solid waste shipment are as follows:

##### Specification 2.4.3

- A. The total curie quantity and principle radionuclide composition shall be determined by measurement or estimates for all radioactive solid waste shipped offsite.
- B. Reports of the radioactive solid waste shipments, volumes, principle radionuclides, and total curie quantity, shall be submitted in accordance with Section 5.6.1.

The summation of solid waste and irradiated fuel shipments is presented in Table IV-1.

TABLE IV-1  
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT - 7/1/83 - 12/31/83  
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Non irradiated fuel)

1. Type of waste	Unit	Second 6-month period	Est. Total Error, %
a. Spent resins, filter sludges, evaporator bottoms, etc.	m <sup>3</sup> Ci	1.31E+2 5.06E+2	2.00E+1
b. Dry compressible waste, contaminated equip, etc.	m <sup>3</sup> Ci	1.58E+2 5.96E+0	5.00E+1
c. Irradiated components, control rods, etc.	m <sup>3</sup> Ci	0.00E+0 0.00E+0	0.00E+0
d. Other (describe)	m <sup>3</sup> Ci	. E+ . E+	. E+

2. Estimate of major nuclide composition (by type of waste)

a.	Cs-134	%	1.77E+1
	Cs-137	%	3.85E+1
	Co-58	%	2.04E+1
	Co-60	%	5.20E+0
	Ag-110m	%	1.00E+0
	Cr-51	%	7.98E-1
	I-131	%	7.20E+0
b.	Cs-134	%	3.25E+0
	Cs-137	%	7.90E+0
	Co-58	%	6.23E+1
	Co-60	%	5.28E+0
	Cr-51	%	6.52E+0
	Nb-95	%	3.90E+0
	Nb-97	%	1.79E+0
	Mn-54	%	1.74E-1

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
28	Transport Truck - Exclusive Use Vehicle	Chem-Nuclear Systems, Inc. Barnwell, SC

B. IRRADIATED FUEL SHIPMENTS (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	NA	NR

## V METEOROLOGICAL DATA

The meteorological data at 33 feet (10 meters) is summarized in Tables V-1, V-2, V-3, and V-4 .

The classification of atmosphere stability is as follows:

Stability Classification	Pasquill Categories	Temperature change with height(°C/100m)
Extremely unstable	A	<-1.9
Moderately unstable	B	>-1.9 to <-1.7
Slightly unstable	C	>-1.7 to <-1.5
Neutral	D	>-1.5 to <-0.5
Slightly stable	E	>-0.5 to < 1.5
Moderately stable	F	> 1.5 to < 4.0
Extremely stable	G	> 4.0

The data recovery rates are:

Third Quarter ..... 34%  
Fourth Quarter ..... 55%

The meteorological data for this period was manually recovered from strip charts except for the last two months of the year.

The new meteorological tower and data recovery unit should improve the historical data recovery rate significantly.

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - A

ELEVATION - 33 FT.

WIND DIR -----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	1	1	0	0	0	2
NE	0	1	4	0	0	0	5
ENE	5	6	7	0	0	0	18
E	10	10	15	0	0	0	35
ESE	6	7	4	0	0	0	19
SE	5	3	3	0	0	0	11
SSE	5	9	4	0	0	0	18
S	6	5	0	0	0	0	11
SSW	5	15	2	1	0	0	23
SW	5	31	10	0	0	0	46
WSW	6	12	8	0	0	0	26
W	2	6	5	0	0	0	13
WNW	1	11	12	0	0	0	24
NW	1	7	5	1	0	0	14
NNW	2	1	0	0	0	0	3
TOTAL	61	125	80	2	0	0	268

PERIODS OF CALM (HOURS) - 14

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - B

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	1	0	0	0	1
NE	0	1	2	0	0	0	3
NNE	1	1	4	0	0	0	6
E	0	1	4	0	0	0	5
ESE	0	1	4	0	0	0	5
SE	0	1	0	0	0	0	1
SSE	0	0	1	1	0	0	2
S	1	0	1	0	0	0	2
SSW	1	0	0	0	0	0	1
SW	3	3	0	0	0	0	6
WSW	3	1	0	0	0	0	4
W	0	2	1	0	0	0	3
WNW	1	1	1	0	0	0	3
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	10	12	19	1	0	0	42

PERIODS OF CALM (HOURS) - 2

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - C

ELEVATION - 53 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNF	0	0	0	0	0	0	0
NE	0	0	1	1	0	0	2
ENF	0	2	0	0	0	0	2
E	0	2	1	1	0	0	4
ESE	0	0	3	0	0	0	3
SE	0	1	1	1	0	0	3
SSF	0	0	0	1	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	1	0	0	0	0	0	1
WSW	2	0	0	0	0	0	2
W	0	1	0	0	0	0	1
WNW	0	0	0	0	0	0	0
NW	0	1	0	0	0	0	1
NNW	0	0	0	0	0	0	0
TOTAL	3	7	6	4	0	0	20

PERIODS OF CALM (HOURS) - 1

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - D

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	1	7	0	0	0	8
NE	1	8	8	0	0	0	17
ENE	2	10	9	1	0	0	22
E	8	19	27	1	0	0	55
ESE	1	6	7	2	1	0	17
SE	4	4	14	7	0	0	29
SSE	1	10	7	2	0	0	20
S	3	9	5	0	0	0	17
SSW	4	10	3	0	0	0	17
SW	2	6	2	1	0	0	11
WSW	0	6	2	0	0	0	8
W	3	3	0	0	0	0	6
WNW	1	3	3	0	0	0	7
NW	0	5	3	2	0	0	10
NNW	1	0	0	0	0	0	1
TOTAL	31	100	97	16	1	0	245

PERIODS OF CALM (HOURS) - 4

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - E

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	4	0	0	0	0	4
ENE	3	3	2	0	0	0	8
E	3	5	0	0	0	0	8
ESE	4	2	1	0	0	0	7
SE	1	3	0	0	0	0	4
SSE	1	13	1	0	0	0	15
S	2	10	0	0	0	0	12
SSW	2	5	1	0	0	0	6
SW	3	2	0	0	0	0	5
WSW	1	2	2	0	0	0	5
W	0	0	1	0	0	0	1
WNW	0	1	0	1	0	0	2
NW	0	0	0	2	0	0	2
NNW	0	3	0	0	0	0	3
TOTAL	20	51	6	3	0	0	82

PERIODS OF CALM (HOURS) - 4

TABLE V-1

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1963 THROUGH SEPTEMBER 30, 1963

STABILITY CLASS - F

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	1	4	0	0	0	0	5
E	5	5	0	0	0	0	10
ESE	10	2	0	0	0	0	12
SE	4	2	0	0	0	0	6
SSE	0	4	0	0	0	0	4
S	3	1	0	0	0	0	4
SSW	7	6	0	0	0	0	13
SW	0	0	0	0	0	0	0
WSW	1	0	0	0	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	31	25	0	0	0	0	56

PERIODS OF CALM (HOURS) - 5

TABLE V-1

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983

STABILITY CLASS - G

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
NNE	1	0	0	0	0	0	1
E	0	0	1	0	0	0	1
ESE	0	1	1	1	0	0	3
SE	1	0	1	0	0	0	2
SSE	1	1	0	1	0	0	3
S	0	2	2	0	0	0	4
SSW	0	1	1	0	0	0	2
SW	0	4	2	0	0	0	6
WSW	0	1	0	1	0	0	2
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	9	10	6	3	0	0	30

PERIODS OF CALM (HOURS) - 1

TABLE V-2

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - A

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNF	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	0	0	0	0	0	1
ESE	1	0	0	0	0	0	1
SE	1	0	0	0	0	0	1
SSE	1	0	0	0	0	0	1
S	0	0	0	0	0	0	0
SSW	1	1	0	0	0	0	2
SW	0	2	2	0	0	0	4
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	1	0	0	0	0	1
NNW	0	0	0	0	0	0	0
TOTAL	5	4	2	0	0	0	11

PERIODS OF CALM (HOURS) - 2

TABLE V-2

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - B

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNF	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESF	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSF	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	1	1	0	0	0	2
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	1	1	0	0	0	2

PERIODS OF CALM (HOURS) - 0

TABLE V-2

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - C

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	1	0	0	0	0	1
NNW	0	0	0	0	0	0	0
TOTAL	0	1	0	0	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-2

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - D

ELEVATION - 53 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	1	0	0	0	0	1
E	2	0	0	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	2	0	0	0	0	2
NW	0	0	0	0	0	0	0
NNW	1	0	0	0	0	0	1
TOTAL	3	3	0	0	0	0	6

PERIODS OF CALM (HOURS) - 0

TABLE V-2

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - E

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	1	0	0	0	0	0	1
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	1	1	0	0	0	0	2

PERIODS OF CALM (HOURS) - 0

TABLE V-2

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - F

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	0	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
Sw	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	1	0	0	0	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-2

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - JULY 1, 1983 THROUGH SEPTEMBER 30, 1983 BATCH RELEASE

STABILITY CLASS - G

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - A

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	1	0	0	1
NNE	0	1	16	0	0	0	17
NE	2	4	24	14	0	0	44
ENE	0	9	17	0	0	0	26
E	0	7	9	0	0	0	16
ESE	0	3	10	0	0	0	13
SE	1	3	0	0	0	0	4
SSE	0	5	9	1	0	0	15
S	1	3	3	3	0	0	10
SSW	2	1	2	0	0	0	5
SW	0	2	5	0	0	0	7
WSW	0	1	2	0	0	0	3
W	0	1	1	3	0	0	5
WNW	0	1	4	3	5	0	13
NW	0	3	6	2	0	0	11
NNW	0	2	10	12	0	0	24
TOTAL	6	46	118	39	5	0	214

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - B

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	2	0	0	0	2
NNF	0	3	8	2	0	0	13
NE	0	2	24	9	0	0	35
ENE	0	2	5	0	0	0	7
E	1	2	1	0	0	0	4
ESE	0	1	3	0	0	0	4
SE	0	0	3	0	0	0	3
SSE	2	3	2	0	0	0	7
S	1	2	1	2	0	0	6
SSW	0	1	1	0	0	0	2
SW	1	2	2	1	0	0	6
WSW	0	1	1	0	0	0	2
W	0	0	0	0	1	0	1
WNW	0	1	1	0	3	0	5
NW	0	1	2	1	0	0	4
NNW	0	0	17	4	0	0	21
TOTAL	5	21	73	19	4	0	122

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - C

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	1	0	0	0	1
NNE	0	0	5	1	0	0	6
NE	0	2	13	1	0	0	16
ENE	0	3	1	0	0	0	4
E	1	4	1	0	0	0	6
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	1	1	0	0	0	2
S	0	1	1	1	0	0	3
SSW	0	1	3	0	0	0	4
SW	0	0	0	2	0	0	2
WSW	0	0	1	0	1	0	2
W	0	1	0	0	0	0	1
WNW	0	0	2	1	0	0	3
NW	0	1	1	0	0	0	2
NNW	0	3	7	0	0	0	10
TOTAL	1	17	38	6	1	0	63

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - D

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	5	0	0	0	5
NNE	0	3	18	2	0	0	23
NE	2	9	32	7	0	0	50
ENE	1	16	17	1	0	0	35
E	1	15	26	3	0	0	45
ESE	0	8	15	1	0	0	24
SE	2	7	10	1	0	1	21
SSE	5	12	18	8	0	1	44
S	5	19	4	15	0	0	43
SSW	1	5	7	0	0	0	13
SW	2	6	2	4	0	0	14
WSW	1	7	3	2	0	0	13
W	0	5	4	1	0	0	10
WNW	1	4	2	0	0	0	7
NW	0	7	8	6	0	0	23
NNW	0	3	9	5	0	0	17
TOTAL	21	126	180	58	0	2	387

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - E

ELEVATION - 53 FT.

WIND DIR ----	WIND SPEED (MPH)					19-24 -----	24+ -----	TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----			
N	0	0	1	0	0	0	0	1
NNE	0	4	2	1	0	0	0	7
NE	3	13	8	0	0	0	0	24
NNE	0	25	6	0	0	0	0	31
E	2	10	13	0	0	0	0	25
ESE	0	12	5	0	0	0	0	17
SE	1	14	3	1	0	0	0	19
SSE	2	5	8	1	1	1	1	18
S	3	4	4	1	0	0	0	12
SSW	3	7	4	0	0	0	0	14
SW	2	2	5	0	0	0	0	9
WSW	1	1	2	0	0	0	0	4
W	0	0	2	0	0	0	0	2
WNW	1	4	0	1	0	0	0	6
NW	3	11	1	0	0	0	0	15
NNW	0	2	1	1	0	0	0	4
TOTAL	21	114	65	6	1	1	1	208

PERIODS OF CALM (HOURS) - 1

TABLE V-3

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - F

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	1	4	0	0	0	0	5
NE	3	11	6	0	0	0	20
ENE	0	40	2	0	0	0	42
E	3	13	6	0	0	0	22
ESE	1	7	5	0	0	0	13
SE	1	6	0	0	0	0	7
SSE	2	2	1	1	0	0	6
S	2	2	2	1	0	0	7
SSW	1	3	1	0	0	0	5
SW	1	1	4	0	0	0	6
WSW	0	0	0	0	0	0	0
W	1	1	0	0	0	0	2
WNW	0	1	0	0	0	0	1
NW	2	3	1	0	0	0	6
NNW	1	1	0	0	0	0	2
TOTAL	19	95	30	2	0	0	146

PERIODS OF CALM (HOURS) - 0

TABLE V-3

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983

STABILITY CLASS - G

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	2	21	0	0	0	0	23
E	1	3	0	0	0	0	4
ESE	4	4	1	0	0	0	9
SE	4	7	1	0	0	0	12
SSE	7	9	0	0	0	0	16
S	2	2	2	1	0	0	7
SSW	0	0	1	0	0	0	1
SW	0	0	2	0	0	0	2
WSW	1	0	0	0	0	0	1
W	0	0	4	0	0	0	4
WNW	0	4	1	0	0	0	5
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	21	51	12	1	0	0	85

PERIODS OF CALM (HOURS) - 1

TABLE V-4

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH REL

STABILITY CLASS - A

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	1	0	0	1
TOTAL	0	0	0	1	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-4

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH RELEASE

STABILITY CLASS - B

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-18 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	0	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-4

## FLORIDA POWER CORPORATION

HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH RELEASE

STABILITY CLASS - C

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS) - 0

TABLE V-4

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH RELEASE

STABILITY CLASS - D

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)					24+	TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----		
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
E	0	0	1	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	0	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-4

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH RELEASE

STABILITY CLASS - E

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	1	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	0	0	0	1

PERIODS OF CALM (HOURS) - 0

TABLE V-4

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 BATCH RELEASE

STABILITY CLASS - F

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 -----	4-7 -----	8-12 -----	13-16 -----	19-24 -----	24+ -----	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS) - 0

TABLE V-11

## FLORIDA POWER CORPORATION

## HOURS AT EACH WIND SPEED AND DIRECTION

PERIOD OF RECORD - OCTOBER 1, 1983 THROUGH DECEMBER 31, 1983 PATCH RELEA

STABILITY CLASS - G

ELEVATION - 33 FT.

WIND DIR ----	WIND SPEED (MPH)						TOTAL -----
	1-3 ----	4-7 ----	8-12 ----	13-18 ----	19-24 ----	24+ ----	
N	0	0	0	0	0	0	0
NNF	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	0	0	0	0

PERIODS OF CALM (HOURS) - 0