


LOUISIANA
POWER & LIGHT

142 DELARONDE STREET • P.O. BOX 8008
NEW ORLEANS, LOUISIANA 70174-8008 • (504) 388-2345

January 11, 1985

W3P84-3618
3-A1.01.04
A4.05

Mr. Robert D. Martin
Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011



Dear Mr. Martin:

Subject: Waterford 3 SES
Docket No. 50-382
Supplemental Response to Emergency Preparedness Inspection
Report 50-382/84-10

- References:
1. NRC Letter dated April 5, 1984 to R.S. Leddick from E.H. Johnson
 2. LP&L Letter W3F84-0067 dated May 23, 1984 to E.H. Johnson from R.S. Leddick
 3. Documentation of Telephone Conversation between C. Hackney and J. Lewis dated August 22, 1984.

The reference 2 letter provided the Louisiana Power & Light Company responses to the items of NRC Inspection Report 50-382/84-10. The attachment is a status report on all of the inspection items and it includes some supplemental responses to complete the LP&L reply to the Emergency Preparedness Inspection Report.

Please contact R.G. Azzarello at (504) 464-3347 if you have any questions regarding this matter.

Very truly yours,

K.W. Cook
Nuclear Support & Licensing Manager

KWC:GEW:sms

cc: NRC, Director, Office of I&E, G.W. Knighton, D.M. Crutchfield,
NRC Resident Inspectors Office, INPO Records Center (D.L. Gillispie),
E.L. Blake, W.M. Stevenson, C.A. Hackney (NRC Region IV),
D.J. Perrotti (NRC-EPB)

8504160312 850329
PDR ADOCK 05000382
Q PDR

Louisiana Power & Light Company
Waterford 3 - Docket No. 50-382
Supplemental Response to NRC Inspection Report No. 50-382/84-10

1. Control Room

- a. 382/8410-01 - Completed April 4, 1984.
- b. 382/8410-02 - Completed May 23, 1984.
- c. 382/8410-03 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- d. 382/8410-04 - Completed October 25, 1984.
- e. 382/8410-05 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.

2. Technical Support Center

- a. 382/8410-06 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- b. 382/8410-07 - Completed October 25, 1984.
- c. 382/8410-08 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- d. 382/8410-09 - Completed April 4, 1984.
- e. 382/8410-10 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.

3. Emergency Operations Facility

- a. 382/8410-11 - Completed June 29, 1984.
- b. 382/8410-12 - Completed June 29, 1984.
- c. 382/8410-13 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- d. 382/8410-14 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- e. 382/8410-15 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.

- f. 382/8410-16 - Completed October 25, 1984.
- g. 382/8410-17 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- h. 382/8410-18 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- i. 382/8410-19 - Completed October 25, 1984.
- j. 382/8410-20 - Completed May 7, 1984.
- k. 382/8410-21 - Completed May 23, 1984.
- l. 382/8410-22 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.
- m. 382/8410-23 - Completed April 5, 1984.

4. Operational Support Center

- a. 382/8410-24 - Completed October 1, 1984. Revised response: The Search and Rescue Team is assembled in the Operational Support Center when needed and is not staged at the +7 ft. msl assembly point. The Fire Brigade and First Aid Team is staged at the +7 ft. msl assembly point. The procedure has been corrected to reflect the +7 ft. msl assembly point for the Fire Brigade and First Aid Team.
- b. 382/8410-25 - Completed October 1, 1984. Revised response: The Search and Rescue Team is assembled in the Operational Support Center when needed and is not staged at the +7 ft. msl. The Fire Brigade and First Aid Team are staged at the +7 ft. msl assembly point. The consideration of health physics coverage for the Fire Brigade and First Aid Team has been incorporated in EP-2-101.
- c. 382/8410-26 - Completed September 1, 1984.
- d. 382/8410-27 - Completed October 25, 1984.
- e. 382/8410-28 - Completed October 1, 1984. This item has also been incorporated in an action item tracking system for review during drill development and evaluation.
- f. 382/8410-29 - Completed November 1, 1984.
- g. 382/8410-30 - Completed November 28, 1984. This item has been emphasized in training drills and incorporated in an action item tracking system for review during drill development and evaluation.

5. Offsite Monitoring

- a. 382/8410-31 - Completed October 25, 1984.
- b. 382/8410-32 - Completed October 25, 1984.
- c. 382/8410-33 - Completed April 4, 1984.

6. Security/Accountability

- a. 382/8410-34 - Completed December 14, 1984. An unannounced Accountability and Station Evacuation drill was conducted on December 14, 1984 at 1:30 p.m. for the entire Waterford 3 site. Personnel were evacuated from the Protected Area and the Owner Controlled Area to the parking lots. 277 persons were processed through the Primary Access Point during the drill. 30 individuals remained within the Protected Area including shift personnel (participants), drill observers and 3 NRC personnel. The time to ascertain the names of missing individuals in the Protected Area was 27 minutes. All Protected Area personnel were accounted for within 30 minutes. No search activities were necessary.

7. News Center

- a. 382/8410-35 - Response provided on May 23, 1984.

8. Medical/First Aid Team

- a. 382/8410-36 - Completed June 18, 1984.