

LOUISIANA
POWER & LIGHT

142 DELARONDE STREET • P.O. BOX 8008
NEW ORLEANS, LOUISIANA 70174-8008 • (504) 366-2345


February 20, 1985

W3P85-0392

3-A1.01.04

3-A45

A4 1985



Mr. Robert D. Martin
Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Dear Mr. Martin:

Subject: Waterford 3 SES
Docket No. 50-382
Response to Emergency Preparedness Appraisal
Item 382/83-08-62

Reference: W3P83-4210 from K.W. Cook to E. Johnson, dated 12/28/83

In the above referenced letter, LP&L responded to Emergency Preparedness Appraisal Item 382/83-08-62 in the following manner:

"The original in-plant paging system was designed to account for high noise areas within the plant. The system will be reviewed for possible modifications resulting from equipment changes within the plant. Actual noise levels will be measured during 5% power operation. Following evaluation of this data the PA system will be expanded or supplemented by strobe lights to ensure emergency messages can be transmitted to all areas within the plant."

At this time LP&L would like to clarify the last sentence in the above response by restating it in the following manner:

"Following evaluation of this data the PA system will be expanded or supplemented by visual enhancements to ensure emergency messages can be transmitted to all areas within the plant."


This will allow LP&L the flexibility to use high-intensity strobe lights, rotating beacons or other visual aides to enhance the PA system, depending on a particular set of circumstances.

8504160368 850411
PDR ADOCK 05000382
Q PDR

Mr. Eric Johnson
W3P85-0392
Page 2

If you have any questions, please contact Mr. G.E. Wuller at
(504) 464-3499.

Yours very truly,

A handwritten signature in cursive script, appearing to read "K.W. Cook".

K.W. Cook
Nuclear Support & Licensing Manager

KWC:GEW:sms

cc: W.M. Stevenson, E.L. Blake, B. Churchill, E. Johnson, G.L. Constable