

## OPERATING DATA REPORT

DOCKET NO. 50-244

DATE November 12, 1984

COMPLETED BY Andrew E. McNamara  
Andrew E. McNamaraTELEPHONE (315) 524-4446  
Ext. 301OPERATING STATUS

1. Unit Name: GINNA STATION, UNIT #1  
 2. Reporting Period: October, 1984  
 3. Licensed Thermal Power (MWt): 1520  
 4. Nameplate Rating (Gross MWe): 490  
 5. Design Electrical Rating (Net MWe): 470  
 6. Maximum Dependable Capacity (Gross MWe): 490  
 7. Maximum Dependable Capacity (Net MWe): 470

## Notes

The reactor power level was maintained at 100% for the entire report period.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level to Which Restricted, If Any (Net MWe):  
 10. Reasons For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	745**	7,320.00	130,986.00
12. Number of Hours Reactor Was Critical	745**	5,384.73	98,984.71
13. Reactor Reserve Shutdown Hours	0	56.23	1,687.55*
14. Hours Generator On-Line	745**	5,316.75	96,828.38
15. Unit Reserve Shutdown Hours	0	0	8.5*
16. Gross Thermal Energy Generated (MWH)	1,127,040	7,816,968	134,074,737
17. Gross Electrical Energy Generated (MWH)	373,434	2,585,999	43,750,369
18. Net Electrical Energy Generated (MWH)	355,279	2,457,207	41,483,452
19. Unit Service Factor	100%	72.63%	73.97%
20. Unit Availability Factor	100%	72.63%	73.98%
21. Unit Capacity Factor (Using MDC Net)	101.46%	71.42%	69.13%
22. Unit Capacity Factor (Using DER Net)	101.46%	71.42%	69.13%
23. Unit Forced Outage Rate	0%	4.75%	7.80%

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

March 2, 1985 - 60 days

25. If Shut Down At End Of Report Period, Estimated Date of Startup:

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

\*Cumulative Total Commencing January 1, 1975

\*\*Eastern Daylight Savings Time to Eastern Standard Time

8412110506 841031  
 PDR ADOCK 05000244  
 R PDR

49-88 (REV. 1/78)

IF 24  
 11

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-244  
 UNIT #1, Ginna Station  
 DATE November 12, 1984  
 COMPLETED BY Andrew E. McNamara  
 Andrew E. McNamara  
 TELEPHONE 1 (315) 524-4446  
Ext. 301 at Ginna

MONTH October, 1984

## DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

1.	<u>474</u>
2.	<u>474</u>
3.	<u>475</u>
4.	<u>475</u>
5.	<u>476</u>
6.	<u>476</u>
7.	<u>477</u>
8.	<u>477</u>
9.	<u>477</u>
10.	<u>478</u>
11.	<u>477</u>
12.	<u>476</u>
13.	<u>476</u>
14.	<u>477</u>
15.	<u>478</u>
16.	<u>479</u>

## DAY AVERAGE DAILY POWER LEVEL (MWe-Net)

17.	<u>478</u>
18.	<u>478</u>
19.	<u>479</u>
20.	<u>478</u>
21.	<u>477</u>
22.	<u>477</u>
23.	<u>477</u>
24.	<u>478</u>
25.	<u>478</u>
26.	<u>477</u>
27.	<u>477</u>
28.	<u>478 (25 hrs)*</u>
29.	<u>477</u>
30.	<u>477</u>
31.	<u>477</u>

\*Eastern Daylight Savings Time to Eastern Standard Time.

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

# UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH OCTOBER, 1984

DOCKET NO. 50-244  
 UNIT NAME #1 Ginna Station  
 DATE November 12, 1984  
 COMPLETED BY Andrew E. McNamara  
 Andrew E. McNamara  
 TELEPHONE (315) 524-4446  
 Ext. 301 Ginna Station

No.	Date	Type 1	Duration (Hours)	Reason 2	Method of Shutting Down Reactor 3	Licencee Event Report #	System Code 4	Component Code 5	Cause & Corrective Action to Prevent Recurrence
									No outages or power reductions to report.

1  
 F: Forced  
 S: Scheduled

2  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

3  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

4  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5  
 Exhibit I - Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-244

UNIT Ginna Station, Unit #1

DATE November 12, 1984

COMPLETED BY Andrew E. McNamara  
Andrew E. McNamara

TELEPHONE 1 (315) 524-4446  
EXT. 301 at Ginna

MONTH October 1984

The reactor power level was maintained at 100% for the report period.

GINNA STATION  
MAINTENANCE REPORT SUMMARY

OCTOBER, 1984

During the month of October, routine maintenance and inspections were performed.



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649



TELEPHONE  
AREA CODE 716 546-2700

GINNA STATION  
November 12, 1984

Director, Office of Management Information and Program Analysis  
U.S. NUCLEAR REGULATORY COMMISSION  
Washington, DC 20555

Subject: Monthly Report for October, 1984  
Operating Status Information  
R. E. Ginna Nuclear Power Plant Unit No. 1  
Docket No. 50-244

Dear Sir:

Pursuant to our Technical Specification 6.9.1, attached herewith is the monthly operating status report for Ginna Station for the month of October, 1984.

Very truly yours,

*Sm Snow*  
for Bruce A. Snow  
Plant Superintendent

BAS/eeg

Attachments

cc: Dr. Thomas E. Murley NRC (1)

IE24  
11