

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102
402/536-4000

April 12, 1985
LIC-85-146

Mr. James R. Miller, Chief
Office of Nuclear Reactor Regulation
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

- References: (1) Docket No. 50-285
(2) Letter from OPPD (R. L. Andrews) to NRC (J. R. Miller) dated February 28, 1985.

Dear Mr. Miller:

**Auxiliary Feedwater System Technical Specifications
Auxiliary Feedwater Pump Testing Frequency**

Based upon Reference (2), the Omaha Public Power District has received notification from our Project Manager that an appeals meeting on the Auxiliary Feedwater System Technical Specifications is necessary. In preparation for this meeting, the District has continued to research this subject. Our research has led us to the conclusion that an appeals meeting is no longer necessary and that the District will submit a change to our Technical Specifications incorporating the monthly testing of the auxiliary feedwater pumps.

The District plans to submit a proposed change to our Technical Specifications within 60 days of this letter which incorporates monthly testing of both the electric and steam driven auxiliary feedwater pumps.

Sincerely,

8504170153 850412
PDR ADOCK 05000285
P PDR

R L Andrews for
R. L. Andrews
Division Manager
Nuclear Production

RLA/JKG/rh

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, DC 20036

Mr. E. G. Tourigny, NRC Project Manager
Mr. L. A. Yandell, NRC Senior Resident Inspector

*Acc'd
1/0*