

Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

April 1, 1985

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Unit 1 & 2
Proposed Amendment to Technical
Specification for Facility Operating
License NPF-11 and NPF-18
Reactor Feedwater Inboard Check
Valves Type C Test
NRC Docket No. 50-373 and 50-374

References (a): USFSAR Figure 6.2-31

(b): Technical Specification Page 3/4 6-32

(c): C. W. Schroeder letter to H. R. Denton
dated November 17, 1983

(d): Confirmatory Action letter dated
November 28, 1983.

(e): C. W. Schroeder letter to J. G. Keppler dated
December 14, 1983

(f): D. L. Farrar letter to J. G. Keppler dated
February 9, 1984.

Dear Mr. Denton:

Pursuant to 10 CFR 50.59, Commonwealth Edison proposes to amend Appendix A, Technical Specification, to Facility Operating Licenses NPF-11 and NPF-18. These amendment changes are being submitted for your staff's review and approval as an exigent change request. LaSalle Unit 1 is now in a forced extension of a planned outage to implement repairs of the inboard feedwater check valve soft seats necessitated by failure of a Type C leak rate test.

The proposed change is enclosed in Attachment A. The attached change has received both On-Site and Off-Site review and approval. We have reviewed this amendment request and find that no significant hazards consideration exists. Our review is documented in Attachment D. Commonwealth Edison is notifying the State of Illinois of our request for this amendment by transmitting a copy of this letter and its attachments to the designated State Official.

8504180053 850401
PDR ADOCK 05000373
P PDR

*AO17
3/40
w/chuck
#150
#0005013*

H. R. Denton

- 2 -

April 1, 1985

Please direct any questions you may have concerning this matter to this office. A fee remittance of \$150.00 is enclosed.

Three (3) signed originals and thirty-seven (37) copies of this transmittal and its attachments are provided for your use.

Very truly yours,

J. G. Marshall

J. G. Marshall
Nuclear Licensing Administrator

Attachments (A): Technical Specification Change to NPF-11
(B): Background
(C): FSAR Figure
(D): Evaluation of Significant Hazards Consideration

cc: Region III Inspector - LaSalle
A. Bournia - NRR
G. Wright - Ill.

SUBSCRIBED and SWORN to
before me this 1st day
of April, 1985

Krisa M. Gorman
Notary Public