



PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Donald C. Shelton
SENIOR VICE PRESIDENT
NUCLEAR

March 1, 1996
PY-CEI/NRR-2032L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Correction of Information in a February 27, 1996 Letter on Drywell Shield Doors

Gentlemen:

A license amendment request was submitted on February 27, 1996 (PY-CEI/NRR-2030L) involving Updated Safety Analysis Report descriptions of analyses that were performed to demonstrate the drywell personnel air lock shield doors and their supporting structures would remain functional with the doors open during power operation. On page 6 of Attachment 1 to that letter, the demand and acceptance criteria listed for the engineering evaluations of the platform structure should be corrected to accurately reflect the criteria used in the evaluations. These are:

$D + SRV_i + OBE_i < F_y$	
$D + SRV_i + SSE_i + PS_{i/D} + PS_{LP} < 1.7S$	(Plastic section modulus permitted) ^(a)
$D + SRV_i + SSE_i + PS_i < 1.7S$	(Plastic section modulus permitted) ^(a)
$D + SRV_i + SSE_i + CHUG_i < 1.6S$	(Plastic section modulus permitted) ^(a)

The engineering evaluations supporting the license amendment request have not changed; the above information simply reflects the criteria actually used therein. The conclusions stated in the February 27, 1996 letter also have not changed.

If you have questions or require additional information, please contact
Mr. James D. Kloosterman, Manager - Regulatory Affairs at (216) 280-5833.

Very truly yours,

BSF:bf

9603060222 960301
PDR ADOCK 05000440
P PDR

cc: NRC Project Manager
NRC Resident Inspector Office

NRC Region III
State of Ohio

060016

Adol
1/6