

Exhibit B-13

ENGINE 101 LOAD HISTORY
SHOREHAM NUCLEAR POWER STATION

Event and Date	Hours at Load, L (%)					Total Hours, All Loads
	L<75	75<L<100	L=100	100<L<110	L>110	
Original Crankshaft Hours	164.0	262.5	188.5	--	19.0	634
<u>Crankshaft replaced</u> <u>Restart 12/29/83</u>						
Testing Hours	78.0	179.0	20.0	91.0	4.5	372.5
<u>Outage 3/18/84</u> <u>Block Inspection 3/20/84</u>						
Qual. Testing Hours 4/10/84	43.0	10.0	29.5	.5	2.0	85
Total	285.0	451.5	238.0	91.5	25.5	1091.5