

Exhibit B-14



ENGINE 102 LOAD HISTORY  
SHOREHAM NUCLEAR POWER STATION

Hours at Load, L (%)

Event and Date	L<75	75<L<100	L=100	100<L<110	L>110	Total Hours, All Loads
<u>Original Crankshaft Hours</u>	83.0	325.0	259.0	22.0	--	689
<u>Crankshaft Replaced Restart 12-22-83 Hours</u>	34.5	183.0	36.5	41.0	29.0	324
<u>Outage on 2/09/84 for 1st Block Inspection on 2/10/84</u>						
<u>Qual. Testing from 3/9/84 thru 3/16/84 Hours</u>	90.0	3.5	16.0	--	0.5	110
<u>Post Qual. Test Outage for Block Inspection on 3/26/84</u>						
Total Hours	207.5	511.5	311.5	63.0	29.5	1123

8412130353 841022  
PDR ADOCK 05000322  
Q PDR