

Exhibit B-15

ENGINE 103 LOAD HISTORY
SHOREHAM NUCLEAR POWER STATION

Event and Date	Hours at Load, L (%)					Total Hours, All Loads
	L<75	75<L<100	L=100	100<L<110	L>110	
Original Crankshaft Hours	103.0	432.0	257.0	---	23.0	815
<u>Crankshaft Replaced</u> <u>Restart 12/17/83</u>						
Testing Hours	67.0	170.5	69.0	34.5	6.0	347
<u>Outage 3/11/84</u> <u>Block Inspection 3/11/84</u>						
Qual. Testing Hours	64.5	5.5	24.5	13.0	1.0	108.5
<u>Block Failure 4/14/84</u> <u>Block Inspection 4/16/84</u>						
Total Hours	234.5	608.0	350.5	47.5	30.0	1270.5

8412130354 841022
PDR ADOCK 05000322
G PDR