

## CONTAINMENT SYSTEMS

PY-CEI/NRR-2033L

Attachment

Page 1 of 2

### DRYWELL BYPASS LEAKAGE

#### LIMITING CONDITION FOR OPERATION

---

3.6.2.2 Drywell bypass leakage shall be less than or equal to 10% of the minimum acceptable  $A/\sqrt{k}$  design value of 1.58 ft.<sup>2</sup>

APPLICABILITY: When DRYWELL INTEGRITY is required per Specification 3.6.2.1.

#### ACTION:

With the drywell bypass leakage greater than 10% of the minimum acceptable  $A/\sqrt{k}$  design value of 1.58 ft.<sup>2</sup>, restore the drywell bypass leakage to within the limit prior to increasing reactor coolant system temperature above 200°F.

#### SURVEILLANCE REQUIREMENTS

---

4.6.2.2 The drywell bypass leakage rate test shall be conducted at least once per 18 months\* at an initial differential pressure of 2.5 psi and the  $A/\sqrt{k}$  shall be calculated from the measured leakage. One drywell air lock door shall remain open during the drywell leakage test such that each drywell door is leak tested during at least every other leakage rate test. If any drywell bypass leakage test fails to meet the specified limit, the schedule for subsequent tests shall be reviewed and approved by the Commission. If two consecutive tests fail to meet the limit, a test shall be performed at least every 9 months until two consecutive tests meet the limit, at which time the 18 month test schedule may be resumed.

9603060575 960301  
PDR ADOCK 05000440  
P PDR

\* The performance of the drywell bypass leakage rate test is extended to the sixth refueling outage and need not be performed during the fifth refueling outage.

### 3.6 CONTAINMENT SYSTEMS

#### 3.6.5.1 Drywell

LCO 3.6.5.1 The drywell shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Drywell inoperable.	A.1 Restore drywell to OPERABLE status.	1 hour
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	12 hours
	<u>AND</u> B.2 Be in MODE 4.	36 hours

#### SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.5.1.1 Verify bypass leakage is less than or equal to the bypass leakage limit. However, during the first unit startup following bypass leakage testing performed in accordance with this SR, the acceptance criterion is $\leq 10\%$ of the drywell bypass leakage limit.	<div style="border: 1px solid black; border-radius: 50%; padding: 5px; display: inline-block;"> <p>NOTE</p> <p>18 months</p> </div>

(continued)

The performance of the drywell bypass leakage test is extended to the sixth refueling outage and need not be performed during the fifth refueling outage.