



Entergy Operations, Inc.
1448 SR 333
Russellville, AR 72801
Tel 501 853-5000

February 28, 1996

2CAN029607

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Annual Diesel Generator Data Report - 1995

Gentlemen:

Arkansas Nuclear One, Unit 2 (ANO-2) Technical Specification 6.9.1.5.d requires an annual submittal of a diesel generator data report for the previous calendar year. This report provides the number of valid tests and the number of valid failures for each diesel generator. The purpose of this letter is to provide this information for calendar year 1995.

Thirteen (13) valid tests were conducted on the 2K-4A diesel generator with no valid failures. Thirteen (13) valid tests were also conducted on the 2K-4B diesel generator with no valid failures.

This letter satisfies the reporting requirements for Technical Specification 6.9.1.5.d. Should you have any questions regarding this submittal, please contact me.

Very truly yours,

Dwight C. Mims
Director, Nuclear Safety

DCM/dwb

9603110241 960228
PDR ADDCK 05000368
R PDR

070027

ADD 1/0

U. S. NRC
February 28, 1996
2CAN029607 Page 2

cc: Mr. Leonard J. Callan
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

Mr. George Kalman
NRR Project Manager Region IV/ANO-1 & 2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-H-3
One White Flint North
11555 Rockville Pike
Rockville, MD 20852