



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37479

J. L. Wilson  
Vice President, Sequoyah Nuclear Plant

January 30, 1992

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of  
Tennessee Valley Authority

)  
)

Docket Nos. 50-327  
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - COMMITMENT SCHEDULE REVISION FOR NRC UNRESOLVED  
ITEM (URI) 90-28-02

Reference: NRC letter to TVA dated September 28, 1990, "Notice of Violation  
(NRC Inspection Report Nos. 50-327/90-28 and 50-328/90-28)"

In the referenced report, the inspector noted that certain electrical conduits were wrapped with fire barrier materials to meet the 1-hour resistance criteria of 10 CFR 50, Appendix R. The material used for the barriers varied; some were wrapped with Thermal System Insulation and others were wrapped with KAOWOOL. However, the conduits that were wrapped with KAOWOOL did not have the conduit supports wrapped in a consistent manner, i.e., some were wrapped eighteen inches, some were wrapped four inches, and some were not wrapped. Nuclear Engineering reviewed the installation of the KAOWOOL-wrapped conduits and concluded that the lack of wrap on some supports still met the requirements of Appendix R. However, TVA agreed to enhance the fire protection of the KAOWOOL-wrapped conduits by wrapping all the supports in a consistent manner and to a uniform height.

The initial schedule was to complete the installation by January 30, 1992. Changes in outage duration and implementation scope have resulted in delays in field implementation. The projected completion date for the wrapping activity is April 17, 1992.

9202040114 920130  
PDR ADOCK 05000327  
G PDR

ADOCK 1/0


U.S. Nuclear Regulatory Commission

Page 2

January 30, 1992

If you have any questions concerning this submittal, please telephone  
M. A. Cooper at (615) 843-8924.

Sincerely,

  
J. L. Wilson

cc: Mr. D. E. LaBarge, Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

NRC Resident Inspector  
Sequoyah Nuclear Plant  
2600 Igou Ferry Road  
Soddy-Daisy, Tennessee 37379

Mr B. A. Wilson, Project Chief  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323