

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5255

JOHN D. SIEBER
Vice President - Nuclear Group

January 21, 1992

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request Nos. 160/20
Revision 1 (TAC Nos. M76680/M76681)

Enclosed are the following:

1. An application for amendment to the above licenses to modify BV-1 Table 3.3-5, concerning feedwater isolation time and correcting errors; revise BV-1 Table 3.6-1 applicable valve stroke times to less than 60 seconds, add radiation monitor containment isolation valves, and add note (1) to instrument air containment isolation valves; delete Table 3.6-1 for both units in accordance with Generic Letter 91-08. In addition, Specification 3.9.4.a, for both units, includes an administrative change by replacing "door" with "hatch".
2. Documents designated Attachment A, B, C, D and E which set forth respectively, the change in the technical specifications, the safety analysis (including the no significant hazards evaluation), the typed replacement technical specification pages, a description of the isolation valve changes, and the UFSAR changes.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The request target date for approval of this proposed change is September 30, 1992.

Sincerely,

J. D. Sieber
J. D. Sieber

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. M. L. Bowling (VEPCO)

9202060200 920121
PDR ADOCK 05000334
PDR

Accol
1/1

