

PETER E. KATZ
Plant General Manager
Calvert Cliffs Nuclear Power Plant

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657
410 495-4101



February 29, 1996

U. S. Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318
1995 Steam Generator Inspection Results Report

REFERENCE: (a) Calvert Cliffs Units 1 and 2 Technical Specifications 6.9.1.5.b

Reference (a) requires that we report, on an annual basis, the results of steam generator tube examinations conducted in the past year. This report includes the number and extent of tubes examined, imperfections noted, and the identity of tubes plugged. Attached please find the report of steam generator tube examinations conducted on the Unit 2 steam generators in March 1995. The Unit 2 steam generator tube inspection results required 340 total tubes to be plugged in No. 21 Steam Generator and 183 total tubes to be plugged in No. 22 Steam Generator. The number of circumferential flaws detected were 29 in No. 21 Steam Generator and 86 in No. 22 Steam Generator. No similar examinations were conducted on the Unit 1 steam generators in 1995.

Should you have questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

PEK/RCG/bjd

Attachment

9603110151 960229
PDR ADL/K 05000318
G PDR

070029

Limited List
Encls To: Files
1/1 2 Vols
PM
FOR

cc: D. G. McDonald, Jr., NRC
T. T. Martin, NRC
Resident Inspector, NRC
R. I. McLean, DNR
J. H. Walter, PSC

(Without Attachment)

D. A. Brune, Esquire
J. E. Silberg, Esquire
L. B. Marsh, NRC