



Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402) 825-3811

CNSS928591

March 10, 1992

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Monthly Operating Status Report for February 1992, Docket No. 50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for February 1992. The report includes Operating Status, Average Daily Unit Power Level, Unit Shutdown Data and a Narrative Summary of Operating Experience.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,

J. M. Meacham
Division Manager of
Nuclear Operations

JMM:JTC:kap

Enclosures

cc: G. D. Watson w/enclosures
R. D. Martin w/enclosures

9203160245 920229
PDR ADOCK 05000298
R PDR

IF24
11

OPERATING DATA REPORT

DOCKET NO. 050-0298
UNIT CNS
DATE March 10, 1992
TELEPHONE (402) 825-5766

OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: February 1992
3. Licensed Thermal Power (MWT): 2331
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restriction, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>696.0</u>	<u>1,440.0</u>	<u>154,873.0</u>
12. Number of Hours Reactor Was Critical	<u>576.7</u>	<u>1,320.7</u>	<u>117,821.0</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>565.0</u>	<u>1,309.0</u>	<u>116,081.5</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,280,256.0</u>	<u>3,041,544.0</u>	<u>236,586,820.0</u>
17. Gross Electric Energy Generated (MWH)	<u>426,823.0</u>	<u>1,018,966.0</u>	<u>76,589,118.0</u>
18. Net Electric Energy Generated (MWH)	<u>414,200.0</u>	<u>987,589.0</u>	<u>73,917,976.0</u>
19. Unit Service Factor	<u>81.2</u>	<u>90.9</u>	<u>75.0</u>
20. Unit Availability Factor	<u>81.2</u>	<u>90.9</u>	<u>75.0</u>
21. Unit Capacity Factor (Using MDC Net)	<u>77.9</u>	<u>89.8</u>	<u>62.5</u>
22. Unit Capacity Factor (Using DER Net)	<u>76.5</u>	<u>88.2</u>	<u>61.3</u>
23. Unit Forced Outage Rate	<u>18.0</u>	<u>9.1</u>	<u>4.6</u>
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

Battery replacement shutdown - April 17, Duration 7 days

25. If Shut Down At End of Report Period, Estimated Date of Start-up: _____
26. Units In Test Status (Prior to Commercial Operation): Forecast
Achieved

INITIAL CRITICALITY _____
INITIAL ELECTRICITY _____
COMMERCIAL OPERATION _____

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298
UNIT CNS
DATE March 10, 1992
TELEPHONE (402) 825-5766

MONTH February 1992

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>797</u>
2	<u>791</u>
3	<u>683</u>
4	<u>624</u>
5	<u>793</u>
6	<u>789</u>
7	<u>795</u>
8	<u>795</u>
9	<u>792</u>
10	<u>589</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>225</u>

17	<u>683</u>
18	<u>717</u>
19	<u>748</u>
20	<u>800</u>
21	<u>793</u>
22	<u>797</u>
23	<u>794</u>
24	<u>797</u>
25	<u>797</u>
26	<u>797</u>
27	<u>796</u>
28	<u>797</u>
29	<u>796</u>
30	<u></u>
31	<u></u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	March 10, 1992
COMPLETED BY	J. T. Cawley
TELEPHONE	(402)825-5766

REPORT MONTH February 1992[illegible]

Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUJREG-0161)

3. Method:

- 1 - Manual
- 2 - Manual Scram
- 3 - Automatic Scram
- 4 - Continued
- 5 - Reduced Load
- 6 - Other

Reason:

A - Equipment Failure (Explain)

B - Maintenance or Test

C - Refueling

D - Regulatory Restriction

E - Operator Training & License Examination

F - Administrative

G - Operational Error (Explain)

H - Other (Explain)

F: Forced	2	Reason:
S: Scheduled		A - Equip

OPERATIONS NARRATIVE
COOPER NUCLEAR STATION
FEBRUARY 1992

NORMAL POWER OPERATION WAS EXPERIENCED FOR THE MONTH OF FEBRUARY, WITH 2 EXCEPTIONS. POWER WAS REDUCED FEBRUARY 3 AND 4 DUE TO NBI LEVEL SWITCH RE-CALIBRATION REQUIREMENTS. THE PLANT WAS SHUTDOWN FROM FEBRUARY 10 TO FEBRUARY 15 DUE TO DEGRADED 250 VDC BATTERIES. BATTERIES REPLACED AND FULL POWER OPERATION RESUMED FEBRUARY 19. A CAPACITY FACTOR 77.9% WAS ACHIEVED FOR THE MONTH.