

## UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482  
 WOLF CREEK GENERATING STATION  
 WOLF CREEK NUCLEAR OPERATING CORPORATION  
 DATE 04-07-92  
 COMPLETED BY S. Wideman  
 TELEPHONE 316-364-8831

REPORT MONTH December, 1991

No	Date	TYPE	DURATION (HOURS)	REASON (1)	METHODS SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED S: SCHEDULED				
3	911201	S	73.4	C	4	Continued refueling outage.
4	911204	F	670.6	H	4	Unit enters forced outage for resolution of motor operated valve issues

SUMMARY: The unit remained in a refueling outage throughout the month. The unit entered day 76 of a scheduled 75 day outage December 4, 1991.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL  
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM  
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM  
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUE  
 5. REDUCED LOAD  
 9. OTHER

Wolf Creek Generating Station  
 Monthly Operating Report  
 December 1991  
 Page 4 of 5