

OPERATING DATA REPORT

DOCKET NO. 50-346
 DATE March 9, 1992
 COMPLETED BY Bilal Sarsour
 TELEPHONE (419) 321-7384

OPERATING STATUS

1. Unit Name Davis-Besse Unit #1
2. Reporting Period February, 1992
3. Licensed Thermal Power (MWt): 2772
4. Nameplate Rating (Gross MWe) 925
5. Design Electrical Rating (Net MWe): 906
6. Maximum Dependable Capacity (Gross MWe): 921
7. Maximum Dependable Capacity (Net MWe): 877
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons

Notes

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reasons For Restrictions, If Any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	696.0	1440.0	119,089
12. Number Of Hours Reactor Was Critical	696.0	1440.0	67,615.8
13. Reactor Reserve Shutdown Hours	0.0	0.0	5,507.2
14. Hours Generator On-Line	696.0	1440.0	65,473.1
15. Unit Reserve Shutdown Hours	0.0	0.0	1,732.5
16. Gross Thermal Energy Generated (MWH)	1,927,316	3,987,023	160,596,316
17. Gross Electrical Energy Generated (MWH)	648,018	1,341,534	53,234,911
18. Net Electrical Energy Generated (MWH)	616,914	1,277,058	50,069,546
19. Unit Service Factor	100.0	100.0	55.0
20. Unit Availability Factor	100.0	100.0	56.4
21. Unit Capacity Factor (Using MDC Net)	101.1	101.1	47.9
22. Unit Capacity Factor (Using DER Net)	97.8	97.9	46.4
23. Unit Forced Outage Rate	0.0	0.0	24.8

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

Forecast

Achieved
