ATTACHMENT A

NPF-38-124

PROCEDURES AND PROGRAMS (Continued)

1. Training of personnel,
2. Procedures for monitoring, and
3. Provisions for maintenance of sampling and analysis equipment.

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

1. Identification of a sampling schedule for the critical variables and control points for these variables,
2. Identification of the procedures used to measure the values of the critical variables,
3. Identification of process sampling points, which shall include monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
4. Procedures for the recording and management of data,
5. Procedures defining corrective actions for all off-control point chemistry conditions, and
6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Post-accident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

1. Training of personnel,
2. Procedures for sampling and analysis, and
3. Provisions for maintenance of sampling and analysis equipment.

e. Basemat Monitoring

A program for monitoring of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat to ensure the continued integrity of the Basemat. The program shall include:

1. settlement of the basemat
2. changes in ground water chemistry that could effect corrosion of reinforcing steel
3. seasonal variation in ground water levels
4. mapping of significant cracking in the basemat and adjacent walls.

ATTACHMENT B

NPF-38-124

PROCEDURES AND PROGRAMS (Continued)

1. Training of personnel,
2. Procedures for monitoring, and
3. Provisions for maintenance of sampling and analysis equipment.

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

1. Identification of a sampling schedule for the critical variables and control points for these variables,
2. Identification of the procedures used to measure the values of the critical variables,
3. Identification of process sampling points, which shall include monitoring the discharge of the condensate pumps for evidence of condenser in-leakage,
4. Procedures for the recording and management of data,
5. Procedures defining corrective actions for all off-control point chemistry conditions, and
6. A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action.

d. Post-accident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

1. Training of personnel,
2. Procedures for sampling and analysis, and
3. Provisions for maintenance of sampling and analysis equipment.

e. Basemat Monitoring

A program for monitoring of the Nuclear Plant Island Structure (NPIS) Common Foundation Basemat to ensure the continued integrity of the Basemat. The program shall include:

1. settlement of the basemat
2. changes in ground water chemistry that could effect corrosion of reinforcing steel
3. seasonal variation in ground water levels
4. mapping of significant cracking in the basemat, and adjacent walls.

INSERT

REMOVE

REMOVE