



Tennessee Valley Authority, Post Office Box 2000, Soddy-Daisy, Tennessee 37379-2000

March 6, 1996

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

)
)

Docket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - ADDITIONAL INFORMATION FOR AMERICAN
SOCIETY OF MECHANICAL ENGINEERS (ASME) SECTION XI RELIEF REQUEST -
SNUBBERS

Reference: TVA letter to NRC dated October 26, 1995, "Sequoyah Nuclear Plant
(SQN) - American Society of Mechanical Engineers (ASME) Section XI
Relief Request - Snubbers"

This letter provides additional information requested by the NRC staff concerning
TVA's snubber relief request (see referenced letter). The additional information
concerns SQN's alternative to the reporting requirements of ASME, Section XI Code
(Subsection IWA-6230). In response to NRC request, the following paragraph is
provided to describe TVA's alternative to the IWA-6230 requirement:

"SQN will continue to submit reports of adverse conditions for snubbers in
accordance with SQN's Corrective Action Program. SQN's Corrective
Action Program is part of SQN's Nuclear Quality Assurance Plan."

Please direct questions concerning this issue to D. V. Goodin at (423) 843-7734.

Sincerely,

R. H. Shell

R. H. Shell
Manager
SQN Site Licensing

cc: See page 2

140007

9603140028 960306
PDR ADOCK 05000327
P PDR

AD47.10

U.S. Nuclear Regulatory Commission
Page 2
March 6, 1996

cc: Mr. D. E. LaBarge, Project Manager
Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igoe Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711