

GULF STATES UTILITIES COMPANY

RIVER BEND STATION POST OFFICE BOX 220 ST FRANCISVILLE, LOUISIANA 70775

AREA CODE 504 535-8094 348-8061

June 12, 1992
RBG- 36963
File Nos. G9.5, G4.25


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

River Bend Station - Unit 1
Docket No. 50-458

Gulf States Utilities Company has enclosed the May 1992 Monthly Operating Report for River Bend Station (RBS) - Unit 1. This report is submitted in accordance with RBS Technical Specification 6.9.1.6.

Sincerely,



W.H. Odell
Manager - Oversight
River Bend Nuclear Group

DMX DMX 106
LAE/DNL/KDG/kvm

cc: U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Resident Inspector
P.O. Box 1051
St. Francisville, LA 70775

INPO Records Center
1100 Circle 75 Parkway
Atlanta, GA 30339

Chester R. Oberg
PUCT
7800 Shoal Creek Blvd.
Suite 400N
Austin, TX 78757

Cajun Electric Power Coop, Inc.

9206230101 920531
PDR ADDCK 05000458
PDR
R

100025

TE24

DOCKET NO. 50/458
RIVER BEND STATION UNIT 1
REPORT NO. R-92-05
DATE June 9, 1992
COMPLETED BY G. F. Hendl
TITLE Sr. Compliance
Analyst
TELEPHONE 504-381-4732

MONTH MAY, 1992

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	0	17.	0
2.	0	18.	0
3.	0	19.	0
4.	0	20.	0
5.	0	21.	0
6.	0	22.	0
7.	0	23.	0
8.	0	24.	0
9.	0	25.	0
10.	0	26.	0
11.	0	27.	0
12.	0	28.	0
13.	0	29.	0
14.	0	30.	0
15.	0	31.	0
16.	0		

DOCKET NO. 50/458
 RIVER BEND STATION UNIT 1
 REPORT NO. R-92-05
 DATE June 9, 1992
 COMPLETED BY G. F. Hendl
 TITLE Sr. Compliance
 Analyst
 TELEPHONE 504-381-4732

PAGE 1 OF 2

OPERATING STATUS

1. REPORTING PERIOD: May, 1992 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt): 2894
 MAX. DEPEND CAPACITY (MWe-Net): 936
 DESIGN ELECTRICAL RATING (MWe-Net): 936
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): N/A
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.	<u>0.0</u>	<u>1,044.88</u>	<u>42,096.98</u>
6. REACTOR RESERVE SHUTDOWN HOURS.	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0.0</u>	<u>969.74</u>	<u>39,661.50</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH).	<u>0</u>	<u>2,724,600</u>	<u>105,044,023</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>918,361</u>	<u>35,507,860</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>862,896</u>	<u>33,231,848</u>

DOCKET NO. 50/458
 RIVER END STATION UNIT 1
 REPORT NO. R-92-05
 DATE June 9, 1992
 COMPLETED BY G. F. Hendl
 TITLE Sr. Compliance
 Analyst
 TELEPHONE 504-381-4732

PAGE 2 OF 2

OPERATING STATUS

	THIS MONTH	YR TO DATE	CUMU- LATIVE
12. REACTOR SERVICE FACTOR.	0.0	28.7	73.9
13. REACTOR AVAILABILITY FACTOR	0.0	28.7	73.9
14. UNIT SERVICE FACTOR	0.0	26.6	71.7
15. UNIT AVAILABILITY FACTOR.	0.0	26.6	71.7
16. UNIT CAPACITY FACTOR (Using MDC).	0.0	25.3	66.1
17. UNIT CAPACITY FACTOR (Using Design MWe) .	0.0	25.3	66.1
18. UNIT FORCED OUTAGE RATE	0.0	43.3	10.3
19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH): N/A			
20. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): N/A			

UNIT SHUTDOWNS AND POWER REDUCTIONS

NO.	DATE	TIME START OF OCCURANCE	TIME RECOVER FROM OCCURANCE	DURATION (HOURS)	TYPE NOTE (1)	REASON NOTE (2)	METHOD NOTE (3)	CORRECTIVE ACTION/COMMENTS
92-03	03/12/92	0600	N/A	1937	S	C	4	Refueling Outage Expected duration: 156 days

SUMMARY:

NOTE (1) TYPE OF OCCURANCE: ENTER CODE

F: FORCED

S: SCHEDULED

DOCKET NO. 50/458

RIVER BEND STATION UNIT 1

NOTE (2) REASON FOR OCCURANCE: ENTER CODE

A: EQUIPMENT FAILURE (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)

B: MAINTENANCE OR TEST

C: REFUELING

D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION

F: ADMINISTRATIVE

G: OPERATIONAL ERROR (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)

H: OTHER (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)

REPORT NO. R-92-05

REPORT MONTH MAY, 1992

DATE June 9, 1992

G. F. Hendy

COMPLETED BY

NOTE (3) METHOD OF SHUTTING DOWN REACTOR OR REDUCING POWER: ENTER ONE

1. MANUAL

2. MANUAL SCRAM

3. AUTOMATIC SCRAM

4. OTHER (EXPLAIN IN CORRECTIVE ACTIONS/COMMENTS)

SIGNATURE

Sr. Compliance Analyst

TITLE

TELEPHONE 504-381-4732