



**Northern States Power  
Company**

**Prairie Island Nuclear Generating Plant**

1717 Wakonade Dr. East  
Welch, Minnesota 55089

March 18, 1996

10 CFR Part 50  
Section 50.73

U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**PRAIRIE ISLAND NUCLEAR GENERATING PLANT**  
Docket Nos. 50-282 License Nos. DPR-42  
50-306 DPR-60

**Cooling Water Surveillance Tests Missed  
as Result of a Rescheduling Error**

The Licensee Event Report for this occurrence is attached. In the report, we made one new NRC commitment:

Surveillance procedure SP-1158 will be re-written to split the Unit 1 and shared equipment testing into two procedures, one for Unit 1 and one for shared equipment.

Please contact us if you require additional information related to this event.

*Michael D Wadley*  
Michael D Wadley  
Plant Manager

Prairie Island Nuclear Generating Plant

c: Regional Administrator - Region III, NRC  
NRR Project Manager, NRC  
Senior Resident Inspector, NRC  
Kris Sanda, State of Minnesota

Attachment

9603220221 960318  
PDR ADOCK 05000282  
S PDR

*JE221*