

OPERATING DATA REPORT

DOCKET NO. 50-364

DATE May 6, 1992

COMPLETED BY D. N. Morey

TELEPHONE (205)899-5156

OPERATING STATUS

1. Unit Name: Joseph M. Farley - Unit 2
2. Reporting Period: April 1992
3. Licensed Thermal Power (MWt): 2,652
4. Nameplate Rating (Gross MWe): 860
5. Design Electrical Rating (Net MWe): 829
6. Maximum Dependable Capacity (Gross MWe): 864.3
7. Maximum Dependable Capacity (Net MWe): 824.0
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: N/A
9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

Notes

- 1) Cumulative data since 7-30-81, date of commercial operation.

	This Month	Yr-to-Date	Cumulative
11. Hours In Reporting Period	719.0	2,903.0	94,272.0
12. Number Of Hours Reactor Was Critical	0.0	1,565.1	80,429.4
13. Reactor Reserve Shutdown Hours	0.0	0.0	138.0
14. Hours Generator On-Line	0.0	1,546.1	79,474.6
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	0.0	4,036,228.3	203,025,549.9
17. Gross Electrical Energy Generated (MWH)	0.0	1,339,768.0	66,635,852.0
18. Net Electrical Energy Generated (MWH)	(4800)	1,265,154.0	63,199,216.0
19. Unit Service Factor	0.0	53.3	84.3
20. Unit Availability Factor	0.0	53.3	84.3
21. Unit Capacity Factor (Using MDC Net)	N/A	52.9	81.8
22. Unit Capacity Factor (Using DER Net)	N/A	52.6	80.9
23. Unit Forced Outage Rate	0.0	2.3	4.1
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):	N/A		

25. If Shut Down At End Of Report Period, Estimated Date of Startup: May 9, 1992

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast	Achieved
05/06/81	05/08/81
05/24/81	05/25/81
08/01/81	07/30/81