

SHAW, PITTMAN, POTTS & TROWBRIDGE

A PARTNERSHIP OF PROFESSIONAL CORPORATIONS

1800 M STREET, N. W.
WASHINGTON, D. C. 20036

(202) 822-1000

TELECOPIER

(202) 822-1099 & 822-1199

RARI FAX 100

(202) 822-1072

TELEX

89-2693 (SHAWLAW WSH)

CABLE SHAWLAW

VIRGINIA OFFICE

1501 FARM CREDIT DRIVE
MCLEAN, VIRGINIA 22102

JOHN F. DEALY*

B. SCOTT CUSTER, JR.

RICHARD S. BEATTY

ROBERT E. CONN

COUNSEL

DAVID J. CYNAMON
JACK A. HORN*
LOUISE A. MATHEWS
SETH H. HOOGASIAN
SHEILA MCC. HARVEY
DELISSA A. RIDGWAY
KENNETH J. HAUTMAN
DAVID LAWRENCE MILLER
FREDERICK L. KLEIN
STEVEN P. DITLER
RICHARD J. PARRINO
ELLEN A. FREDER
ROBERT C. BOEHM
MARIE N. DOLAND*
THOMAS C. HILL
DIANE E. BURKLEY*
L. DUANE CHEEK
MICHAEL K. MADDEN
RALPH A. TAYLOR JR.
HANNAH E. M. LIEBERMAN
JUDITH A. SANDLER
ANDREW D. ELLIS
RICHARD A. SAMP
THOMAS E. CROCKER, JR.
VICKI R. HARDING
PETER J. FERRARA
HELEN TORELLI
MARTHA BOONE ROWAN**
KENNETH R. MILLER
JOHN H. MORE
PAUL S. PILECKI*
WENDELIN A. WHITE

STANLEY M. BARG
LESLIE K. SMITH
VIRGINIA S. RUTLEDGE
KATHERINE P. CHEEK
TRAVIS T. BROWN, JR.
STEPHEN B. HEIMANN
EILEEN J. BROWNELL
PAMELA H. ANDERSON
ALEXANDER D. TOMASZCZUK
JEFFREY J. A. GIBBS
LAURENCE W. COHEN
DEREK W. LINDEN
SYLVIA M. LOTRECK
JEFFREY R. SNYDER*
PHILIP D. PORTER
MICHAEL A. SWIGER
ELLEN SHERIFF
ANITA J. FINKELSTEIN
DAVID R. SAHR
C. BOWDOIN TRAIN
JEFFREY W. KAMPELMAN
KENNETH A. GALLO
DAVID R. LEWIS
A. PATRICK LEIGHTON III*
JEFFREY G. BERMAN
KENNETH O. AUERBACH
ALAN D. WASSERMAN
RICHARD K. A. BECKER
WILBERT WASHINGTON II
DOROTHEA W. DICKERMAN
JONATHAN T. CAIN
DOUGLAS L. HILLEBOE*

* NOT ADMITTED IN D.C.

* ADMITTED IN VIRGINIA

WRITER'S DIRECT DIAL NUMBER

(202) 822-1178

December 21, 1984

James P. Gleason, Chairman
513 Gilmore Drive
Silver Spring, Maryland 20901

Dr. Jerry R. Kline
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Glenn O. Bright
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: The Cleveland Electric Illuminating Co.
(Perry Nuclear Power Plant, Units 1 and 2)
Docket Nos. 50-440 and 50-441 OL

Gentlemen:

For your information, please find enclosed the following documents:

Letter from Murray R. Edelman to Harold R. Denton (October 29, 1984) (with attachments)

Letter from Murray R. Edelman to Harold R. Denton (August 20, 1984) (with attachments)

DS03

Messrs. Gleason, Kline & Bright
December 21, 1984
Page 2

The attachments to these letters contain clarifications on several items related to SER review comments on the Emergency Plan for the Perry Nuclear Power Plant. Clarifications which include changes to the Emergency Plan will be incorporated into Revision 4 of the Plan, which is scheduled for issuance in January 1985.

Sincerely,

Michael A. Swiger

Michael A. Swiger
Counsel for Applicants

MAS/jbm
cc: Service List



THE CLEVELAND ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

October 29, 1984
PY-CEI/NRR-0149 L

Mr. Harold R. Denton
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Clarifications to Revision 3
Submittal of the Emergency
Plan OM-15A

Dear Mr. Denton:

The third revision of the Emergency Plan for Perry Nuclear Power Plant (PNPP) which was submitted on April 28, 1984 included changes which resulted from the NRC review comments as outlined in Safety Evaluation Report (SER) Supplement 4, Section 13. Additional clarification is provided on several of the items related to the SER review comments. The necessary clarifications are individually addressed in the attachments to this letter. Those clarifications which include changes to the Emergency Plan will be incorporated into Revision 4 of the Plan, which is scheduled for issuance in January 1985. The attachments follow the format of the SER to facilitate review and resolution in a future SER supplement.

It is expected that this information should close Outstanding Issue 19 dealing with onsite emergency planning for PNPP. Please contact us if there are any questions.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

MRE:njc

Attachments

cc: J. Silberg, Esq.
J. Stefano
J. Grobe

13.3.2.1

Revisions will be made as follows to indicate the interface and provisions for coordination with the Commonwealth of Pennsylvania on ingestion pathway control measures.

Add new section:

"2.5.2.6 Pennsylvania Emergency Management Agency (PEMA), Commonwealth of Pennsylvania Disaster Operations Plan, Annex E, "Fixed Nuclear Facility Incidents."

Add to Section 3.2.1

"Coordination with the Pennsylvania Emergency Management Agency for ingestion pathway control measures is also provided by the State of Ohio."

Add to Section 6.4.5

"Interface with the Pennsylvania Emergency Management Agency for ingestion pathway exposure control measures is provided by the State of Ohio."

13.3.2.2 (1)

13.3.2.9 (1)

The following changes will be made in Revision 4 to address staff augmentation in the area of radiation monitoring:

Section 5.2.2.2 Item 3

"3. Radiation Monitoring Teams"

Section 5.2.2.4, Page 5-9, Paragraph 1

"Radiation Monitoring Teams (RMTs) are composed of two members. The RMT Leader is a trained member of the Radiation Protection Section. The RMT Helper may be any RMT trained individual of the permanently assigned PNPP staff. The number of teams responding is dependent on the emergency classification. For an Alert, two (2) Radiation Monitoring Teams will respond to perform monitoring; for a Site Area or General Emergency, three (3) teams will respond. Additional teams may be organized as the situation warrants. RMTs will obtain radio equipped, four-wheel-drive vehicles from Security. RMTs are equipped to perform direct radiation measurements, airborne radioactivity sampling and measurement, and environmental sample collection."

Section 5.2.3 Page 5-11 Paragraph 5

"Radiation Monitoring Teams (RMTs), during the initial phase, will consist of qualified RMT personnel available and equipped in the Operations Support Center (OSC), and under the direction of the Shift Supervisor. During the interim phase, two (2) RMTs will assemble and will be under the direction of the Radiation Protection Coordinator in the Technical Support Center (TSC). During the final phase, three (3) RMTs will assemble and be under the direction of the Offsite Radiation Advisor."

Table 5-1 page 5-22

PNPP Emergency Response Organization functions and Shift Staff Augmentation Plan (see next page).

TABLE 5-1 (Cont.)

MAJOR FUNCTIONAL AREA	MAJOR TASKS	POSITION TITLE OR EXPERTISE (FROM NUREG 0654 TABLE B-1)	ON SHIFT MIN. NO./TITLE (LOCATION)	GOALS FOR ADDITION	
				30 MIN TITLE (LOCATION)	60 MIN TITLE (LOCATION)
	Onsite (out of plant) and Offsite Surveys			2 Rad. Prot. Tech (OSC) 2 I&C Tech. (OSC)	1 Rad. Prot. Tech. 1 I&C Tech. (OSC/EOF)
	In Plant Surveys	HP Technicians	HP Tech (3)	1 HP Tech. (HPSR)	1 HP Tech. (HPSR)
	Chemistry/Radio- chemistry	Rad/Chem Tech.	1 Chem. Tech.		1 Chem. Tech. (Chem Lab)
Plant System Engineering, Repair & Corrective Actions	Technical Support	Shift Tech. Adv.	1 Shift Tech. Advisor	1 Tech. Sec. GS (TSC) NL&FM	1 ND&A GSE (TSC)
		Core/Thermal Hydraulics Electrical		1 Nuclear Eng (TSC)	1 ND&A Elect. Eng. (TSC)
		Mechanical			1 Tech. Sec. Mech Eng (TSC)
	Repair and Cor- rective Actions	Mech. Maint. RW Operator Elec. Maint. Instrument & Control (I&C) Tech.	1 Perry Plant Operator (4) 1 Radwaste Tech. 1 Perry Plant Operator (4) 1 I&C Tech. (2)	1 Maint. Supv. (Mech) (OSC)	1 Maint. Supv. (Elec) (OSC) 1 Maint. Gen. Supv. (OSC) 1 I&C Unit Supv. (TSC)

13.3.2.3 (2)

The last paragraph of Section 7.3.9 will be revised as follows to clarify the laboratory facilities available in the EOF:

"Should it become necessary, there is space available in the decontamination room and whole body counting room of the Emergency Operations Facility to relocate the equipment provided in the back up counting room of the Technical Support Center to analyze samples obtained by the Radiation Monitoring Teams."

13.3.2.6 (1)

To clarify backup communications capabilities at PNPP, Section 7.2.2 of the PNPP Emergency Plan will be revised as follows:

"7.2.2 EMERGENCY COMMUNICATIONS

The various communications systems described in Section 7.2.1 provide reliable and redundant means for communicating between areas throughout the PNPP. To enhance the reliability of communications with offsite areas, agencies and authorities, various dedicated leased telephone lines with a direct ring capability are employed. In the event that one or more of the dedicated line networks are inoperative the Private Branch Exchange (PBX) and Off-Premise Exchange (OPX) systems will provide back-up means of communications both within PNPP and between PNPP and all state/local governmental authorities with primary responsibilities during an emergency. A block diagram of the emergency communications network is provided in Figure 7-6."

13.3.2.10 (1)

The first paragraph of Section 6.4.1 will be revised as follows:

"In the event of a Site Area or General Emergency, site personnel will be instructed to begin personnel accountability. This notification will be performed essentially immediately using the Public Address and Exclusion Area Paging Systems described in Section 7.2.1. To accomplish personnel accountability within 30 minutes, all personnel without an emergency response function will be directed to exit the site areas via normal exit routes and exit procedures."

13.3.2.4 (3)

13.3.2.10

The following changes will be made in Revision 4 of the PNPP Emergency Plan to clarify the use of protective actions based on the potential for releases of radioactive material.

"Section 4.1.4, page 4-4

While the EALs identified for a General Emergency indicate that time should be available to provide confirmative assessments prior to implementation of extensive protective actions, the Emergency Plan Implementing Instructions (EPI's) provide that upon declaration of a General Emergency, the Emergency Coordinator will recommend, as a precautionary measure, shelter for the general public within 2 miles of the plant and in at least 3 downwind sectors to 5 miles. Also, protective actions based on the potential for releases of radioactive material will be recommended as follows (see Figure 4-1 for directions on using curves):

<u>Indication</u>	<u>Protective Actions</u>
1. Above Curve 4	-360 degree shelter to 2 miles -Precautionary shelter in at least 3 downwind sectors to 5 miles
2. Above Curve 3	-360 degree evacuation to 2 miles -360 degree shelter between 2 and 3 miles -Shelter in at least 3 downwind sectors between 3 and 5 miles
3. Above Curve 2	-360 degree evacuation to 2 miles -Evacuation in at least 3 downwind sectors between 2 and 5 miles -Shelter between 2 and 3 miles in unaffected areas
4. Above Curve 1	-360 degree evacuation to 3 miles -Evacuation in at least 3 downwind sectors between 3 and 5 miles -Shelter between 3 and 4 miles in unaffected areas

The above protective action recommendations assume that conditions listed in Table 4-1 for a General Emergency have been met or exceeded. As noted above, assessment activities as described in the EPI's will continue to determine if additional protective actions should be recommended."

Section 6.4.3 on page 6-11:

<u>Indication</u>	<u>Protective Actions</u>
1. Above Curve 4	-360 degree shelter to 2 miles -Precautionary shelter in at least 3 downwind sectors to 5 miles
2. Above Curve 3	-360 degree evacuation to 2 miles -360 degree shelter between 2 and 3 miles -Shelter in at least 3 downwind sectors between 3 and 5 miles
3. Above Curve 2	-360 degree evacuation to 2 miles -Evacuation in at least 3 downwind sectors between 2 and 5 miles -Shelter between 2 and 3 miles in unaffected areas
4. Above Curve 1	-360 degree evacuation to 3 miles -Evacuation in at least 3 downwind sectors between 3 and 5 miles -Shelter between 3 and 4 miles in unaffected areas

13.3.2.14 (1)

Section 8.5.4.1 of the Emergency Plan will be revised as follows:

- "1. A major exercise appropriate to a Site Area or General Emergency will be conducted within one year prior to issuance of a full power operating license and annually thereafter in accordance with federal regulations to include conducting exercises under varying weather conditions.
2. The degree of participation by state and local agencies will be in accordance with Federal Regulations. Each exercise will include testing of the Prompt Alerting System.
3. Delete
4. (Renumber as #3, otherwise no change)"

Note that this change includes changes committed to in the August 20, 1984 letter from M. R. Edelman to H. R. Denton letter PY-CEI/NRR-0135L.

13.3.2.16 (1)

The following will be added to the end of Section 8.2:

"The PNPP Operational Quality Assurance Program describes the management controls that exist to provide documentation and correction of deficient areas and incorporation of these corrections into the Emergency Preparedness Program."



P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN

VICE PRESIDENT
NUCLEAR

August 20, 1984
PY-CEI/NRR-0135 L

Mr. Harold R. Denton
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Clarifications to Revision 3
Submittal of the Emergency
Plan OM-15A

Dear Mr. Denton:

The third revision of the Emergency Plan for Perry Nuclear Power Plant (PNPP) which was submitted on April 28, 1984 included changes which resulted from the NRC review comments as outlined in Safety Evaluation Report (SER) Supplement 4, Section 13. Additional clarification is provided on several of the items previously addressed in that revision. The necessary clarifications are individually addressed in the attachments to this letter. Those clarifications which include changes to the Emergency Plan will be incorporated into Revision 4 of the Plan. The attachments follow the format of the SER to facilitate review and resolution in a future SER supplement. Please contact us if there are any questions.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

MRE:njc

Attachments

cc: J. Silberg, Esq.
J. Stefano
J. Grobe

13.3.2.2 (1) and 13.3.2.9 (1)

Table 5-1 of the Emergency Plan will be revised to more accurately reflect present plans for Radiation Monitoring Team (RMT) staffing. The RMT's are composed of one (1) Radiation Protection Section Technician and one (1) I & C Technician. The RMT's are responsible for monitoring all areas from the Protected Area fences out to the EPZ boundary. This includes both onsite (out-of-plant) and offsite areas. Table 5-1 will reflect staffing of one team (2 individuals) at 30 minutes and an additional two teams (4 individuals) at 60 minutes. Each team will have a radio equipped vehicle and the equipment necessary to perform field surveys (see RMT Kit contents; OM15A Appendix C). This allows the teams to be utilized in all areas of the EPZ in order to effectively monitor for radioactive releases.

13.3.2.4 (1)

Table 4-1 details the Initiating Conditions and Emergency Action Levels (EAL's) used for determining emergency classifications. In the first EAL listed under the Site Area Emergency classification, the use of AND logic rather than OR logic is necessary to preclude the unwarranted declaration of a Site Area Emergency that could result from either case being exceeded as a result of a non-emergency condition. The second EAL listed under the Site Area Emergency classification will be revised in Revision 4 of the Emergency Plan as follows:

a. Reactor water level below TAF AND;

1). Very high coolant activity as indicated by confirmed reactor water sample results of 300 uCi/gm dose equivalent I-131;

OR

2.) Containment High Range Radiation Monitor above curve 3 of Figure 4-1;

OR

3.) Main Steam Line Radiation Monitor reading greater than 3.6 x full power background.

13.3.2.5. (1)

Current drafts of the Standard Operating Procedure (SOP) for the Emergency Communications Center (ECC) provide instructions to the ECC Watch Commander in the event of a rapidly escalating emergency. If one of the County Commissioners or the Disaster Services Agency Director cannot be reached within a limited time of the notification (12 minutes), the ECC Watch Commander will act appropriately in accordance with his instructions as outlined in the SOP for activation of the sirens and EBS messages.

13.3.2.4 (2)

The third paragraph of Section 8.2 of the Emergency Plan will be revised as follows:

"The PNPP Emergency Plan, including appended letters of agreement and Emergency Action Levels will be reviewed and agreed upon by State and local officials, and will be reviewed at least annually thereafter."

13.3.2.6 (1)

Figure 7-6 will be revised to delete the "OPX (Dimension) Conference Loop" and "PBX (Roim) Conference Loop."

13.3.2.6 (2)

Section 7.2.2.8 will be revised as follows:

7.2.2.8 Medical Support

Communications between PNPP and the Perry Township Fire Department are via telephone. Communications between PNPP and Lake County Memorial Hospital, East are via telephone. Communications between the Perry Township Fire Department's ambulance and Lake County Memorial Hospital, East are via radio.

13.3.2.8 (2)

The second paragraph of Section 8.3 in the PNPP Emergency Plan will be revised to read "Emergency equipment will be calibrated using approved PNPP calibration instructions at the same frequency as equipment in routine use." In addition, the Plan will be revised to indicate that the following equipment will be available to the control room for emergency use:

- 10 Full sets of protective clothing
- 10 O-5R dosimeters
- 8 Self-Contained Breathing Apparatus with plug-in capability.
- 1 High Range Survey meter (ion chamber) 1 mR/HR to 50 R/HR range.

13.3.2.8 (3)

A letter of agreement is being obtained from the Cleveland-Hopkins branch of the National Weather Service to provide back-up meteorology for PNPP. Section 7.3.7 will be revised to reflect this and a copy of the letter will be included in Appendix B of the Plan.

13.3.2.14 (1)

Section 8.5.4.1 of the Emergency Plan will be revised as shown below:

1. (No change).
2. The degree of participation by State and local agencies will be in accordance with Federal Regulations. Each exercise will include testing of the Prompt Alerting System.
3. (Delete)
4. (Renumber as #3, otherwise no change).

13.3.2.14 (3)

Section 8.5.4.3 of the Emergency Plan will be revised so that #5 will read "Each Communications Test listed above will involve evaluating the aspect of understanding the contents of the message including a check of hardware, voice quality and message clarity."

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

Before the Atomic Safety and Licensing Board

In the Matter of)	
)	
THE CLEVELAND ELECTRIC)	Docket Nos. 50-440
ILLUMINATING COMPANY, <u>ET AL.</u>)	50-441
)	
(Perry Nuclear Power Plant,)	
Units 1 and 2))	

SERVICE LIST

James P. Gleason, Chairman
513 Gilmore Drive
Silver Spring, Maryland 20901

Atomic Safety and Licensing
Appeal Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Jerry R. Kline
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docketing and Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Glenn O. Bright
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Colleen P. Woodhead, Esquire
Office of the Executive Legal
Director
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Christine N. Kohl, Chairman
Atomic Safety and Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson Avenue
Mentor, Ohio 44060

Dr. W. Reed Johnson
Atomic Safety and Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Terry Lodge, Esquire
618 N. Michigan Street, Suite 105
Toledo, Ohio 44060

Gary J. Edles, Esquire
Atomic Safety and Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Donald T. Ezzone, Esquire
Assistant Prosecuting Attorney
Lake County Administration Center
105 Center Street
Painesville, Ohio 44077

Atomic Safety and Licensing
Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

John G. Cardinal, Esquire
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047