



STATE OF ILLINOIS
DEPARTMENT OF NUCLEAR SAFETY
1035 OUTER PARK DRIVE
SPRINGFIELD, IL 62704
(217) 785-9900

THOMAS W. ORTCIGER
DIRECTOR

JIM EDGAR
GOVERNOR

July 5, 1991

Dr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Document Control Desk


Subject: Byron/Braidwood Application for Amendment to Facility Operating
License NPF-37, NPF-66, NPF-72, and NPF-77

In Response Please Refer to 91-39

Dear Dr. Murley:

Pursuant to 10 CFR 50.91, the Illinois Department of Nuclear Safety (IDNS) hereby submits final comments to the proposed license amendment by Commonwealth Edison dealing with surveillance requirements for venting Emergency Core Cooling System discharge lines at Byron and Braidwood. The attached report concludes that the transient analyzed presents safety significant conditions that were not analyzed by the licensee. IDNS recommends, therefore, that NRC consider this analysis in their "no significant hazards" determination.

Sincerely,


Frank Niziolek
Reactor Safety Section Head

FN:ec

Attachment: Byron/Braidwood Unit 1 RHR/SI Piping Water Hammer Acoustic
Analysis

220136



recyclable

9206250023 910705
PDR ADOCK 05000454
P PDR

Handwritten:
Aool
1/1
Luid
6/22/92
QCB