

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

March 26, 1996

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 96-144
NL/RPC
Docket No. 50-338
License No. NPF-4


Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 1
STEAM GENERATOR TUBE PLUGGING REPORT

North Anna Unit 1 recently completed its 1996 refueling outage. During the outage, eddy current examinations were conducted for fifty percent of the tubes in steam generator "B." In addition, nine percent of the tubes in steam generator "B" were examined at the top of the tubesheet on the hot leg with rotating pancake coil probes. Technical Specification 4.4.5.5.a, requires a listing of those tubes plugged during the outage to be provided within 15 days of completion. However, no tubes were plugged as a result of these examinations.

Should you have any questions or require additional information, please contact us.

Very truly yours,



M. L. Bowling, Manager
Nuclear Licensing and Operations Support

cc: U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30323

Mr. R. D. McWhorter
NRC Senior Resident Inspector
North Anna Power Station

9603290091 960326
PDR ADDCK 05000338
P PDR

ADD 1/0