



PECO NUCLEAR

A UNIT OF PECO ENERGY

PECO Energy Company
Nuclear Group Headquarters
965 Chesterbrook Boulevard
Wayne, PA 19087-5691

March 25, 1996

Docket Nos. 50-352
50-353

License Nos. NPF-39
NPF-85

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Limerick Generating Station Units 1 and 2
Response to Request for Additional Information Regarding Technical Specifications
Change Request No. 95-18-0

By letter dated December 22, 1995, PECO Energy Company (PECO) submitted Technical Specifications Change Request (TSCR) No. 95-18-0 "Increase Purge System Operational Time Limits" for Limerick Generating Station (LGS) Units 1 and 2. The purpose of TSCR 95-18-0 is to increase the allowable purge time limit while in OPCONs 1, 2 or 3 from 90 hours each 365 days to 180 hours each 365 days.

Subsequently, via telephone conversation dated March 25, 1996, the NRC requested that PECO Energy commit to submitting an additional TSCR within one year of issuance of the amendments approving TSCR 95-18-0. The supplemental TSCR would propose removing the purge time limit from the TS and replace it with requirements similar to those contained in the Improved Standard Technical Specifications (i.e., NUREG-1433).

PECO Energy hereby commits to submitting a TSCR, within one year of the date of issuance of the amendments approving TSCR 95-18-0, to remove the purge time limit from the TS and replace it with requirements similar to those contained in the Improved Standard Technical Specifications (i.e., NUREG-1433).

If you have any questions, please do not hesitate to contact us.

Very truly yours,

G. A. Hunger, Jr.
Director - Licensing

cc: T. T. Martin, Administrator, Region 1, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS
R. R. Janati, PA Bureau of Radiological Protection

9603290261 960325
PDR ADDCK 05000352
PDR

Acc
1/0