

Connex Pipe Systems, Inc.  
1115 Gilman Street  
Marietta  
Ohio 45750  
Telephone 614.373.7541  
Fax 614.373.8480  
Twx 810.486.2808

June 25, 1992

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

REF.: Gulf States Utilities Co. - Report of Defect  
Dated June 18, 1992--RBG-37042  
File No. G9.5 River Bend Station - Unit 1  
Document No. 50-458

Gentlemen:

We have reviewed Gulf States Utilities' Report of Defect per 10CFR21 and offer the following clarifications and additional information:

The forged replacement elbow was purchased by Connex Pipe Systems on Purchase Order E8634-2 Item #1 from Ram Forge and shipped direct to Gulf States Utilities River Bend Station Unit 1 from Ram Forge and Steel Inc., P.O. Box 592, Industrial Park Road, Navasota, Texas 77868.

The elbow was then accepted by Gulf States Utilities River Bend Station - Unit 1 and was in the process of being machined when the defect was discovered. Upon notification by Gulf States, the elbow was returned to Connex to be repaired.

Connex reworked the elbow in accordance with ASME III NB-4130. The rework of the elbow was documented on Connex sketch E8630-1. The elbow was then returned to Gulf States Utilities River Bend Station Unit 1 along with the associated documentation.

In addition, Connex took immediate corrective action by removing Ram Forge from Connex's Approved Vendors List until a full investigation could be completed.

300045  
A member of the Whessoe Group  
9206300022 920625  
PDR ADOCK 05000458  
S PDR

IE19  
110



U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

June 25, 1992


2 of 2

Preliminary results of our investigation indicate that this was an isolated occurrence; however, specific cause has yet to be determined.

We hope this additional information will help supplement the report issued by Gulf States Utilities.

Sincerely,

CONNEX PIPE SYSTEMS, INC.



D. Leininger  
V.P. Technical Services

DJL:cak

cc: U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive  
Suite 400  
Arlington, TX 76011

NRC Resident Inspection  
P.O. Box 165  
St. Francisville, LA 70775

Mr. D. C. Deddens  
Senior Vice President  
River Bend Nuclear Group  
Gulf States Utilities  
P.O. Box 220  
St. Francisville, LA 70775