

Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201
Telephone (205) 868-5131



Dave Morey
Vice President
Farley Project

Southern Nuclear Operating Company
the southern electric system

March 25, 1996

10 CFR 50.36

Docket Numbers 50-348
50-364

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555


Joseph M. Farley Nuclear Plant
1995 Annual Diesel Generator Reliability Data Report

Ladies and Gentlemen:

Attached is the Annual Diesel Generator Reliability Data Report for 1995, which is submitted in accordance with Farley Nuclear Plant (FNP) Technical Specification 6.9.1.12. This report provides the number of tests (valid or invalid) for 1995. There were no failures of an FNP diesel generator in 1995; therefore, no information identified in Regulatory Position C.3.b of Regulatory Guide 1.108, Revision 1, August 1977, is required to be reported.

If there are any questions, please advise.

Respectfully submitted,


Dave Morey

DRC/maf:dg-ar-95.doc

Attachment: 1995 Annual Diesel Generator Reliability Data Report

cc: U. S. Nuclear Regulatory Commission, Washington, DC
Mr. B. L. Siegel, NRR Senior Project Manager

U. S. Nuclear Regulatory Commission, Region II
Mr. S. D. Ebnetter, Regional Administrator
Mr. T. M. Ross, FNP Senior Resident Inspector

9604010344 951231
PDR ADOCK 05000348
R PDR

010087

A001
1/1

1995 ANNUAL DIESEL GENERATOR RELIABILITY DATA REPORT

Diesel Generator	1-2A	1B	2B	1C	Totals
Valid Successful Tests	15	17	16	14	62
Invalid Tests	15	21	23	11	70
Valid Failures	0	0	0	0	0
Invalid Failures	0	0	0	0	0